

Docket Nos.: 50-443
and 50-444

APR 22 1985

Mr. Robert J. Harrison
President & Chief Executive Officer
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Dear Mr. Harrison:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING POST-FIRE
SAFE SHUTDOWN CAPABILITY

We have completed our review of your revised submittal, "Fire Protection of Safe Shutdown Capability" dated September 14, 1984 concerning the ability of the plant to achieve and maintain a safe shutdown condition following a fire. As a result of this review, the enclosed request for additional information has been prepared. These questions have previously been discussed with Mr. R. Sweeney of your staff.

Questions or additional information regarding this matter should be directed to the Seabrook Project Manager. Mr. V. Nerses (301-492-7238).

Sincerely,

151

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Document Control 50-443/444

NRC PDR
L PDR
NSIC
PRC System
LB#3 Reading
JLee
VNerses,
R. Perlis, OLED,
EJordan, IE
DL: B#3
VNerses/yt
4/18/85

JPartlow
BGrimes
ACRS (16)
OParr
RAnand

DL: B#3
GW Knighton
4/17/85

8505090557 850422
PDR ADOCK 05000443
F PDR

Seabrook

Mr. Robert J. Harrison
President and Chief Executive Officer
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Thomas Dignan, Esq.
John A. Ritscher, Esq.
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

Mr. Bruce B. Beckley, Project Manager
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Dr. Mauray Tye, President
Sun Valley Association
209 Summer Street
Haverhill, Massachusetts 01839

Robert A. Backus, Esq.
O'Neil, Backus and Spielman
116 Lowell Street
Manchester, New Hampshire 03105

Ms. Beverly A. Hollingworth
7 A Street
Hampton Beach, New Hampshire 03842

William S. Jordan, III
Diane Curran
Harmon, Weiss & Jordan
20001 S Street, NW
Suite 430
Washington, DC 20009

Jo Ann Shotwell, Esq.
Office of the Assistant Attorney General
Environmental Protection Division
One Ashburton Place
Boston, Massachusetts 02108

D. Pierre G. Cameron, Jr., Esq.
General Counsel
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

E. Tupper Kinder, Esq.
G. Dana Bisbee, Esq.
Assistant Attorney General
Office of Attorney General
208 State House Annex
Concord, New Hampshire 03301

Resident Inspector
Seabrook Nuclear Power Station
c/o US Nuclear Regulatory Commission
Post Office Box 700
Seabrook, New Hampshire 03874

Mr. John DeVincentis, Director
Engineering and Licensing
Yankee Atomic Electric Company
1671 Worcester Road
Framingham, Massachusetts 01701

Mr. A. M. Ebner, Project Manager
United Engineers & Constructors
30 South 17th Street
Post Office Box 8223
Philadelphia, Pennsylvania 19101

Mr. Philip Ahrens, Esq.
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

Mr. Warren Hall
Public Service Company of
New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Seacoast Anti-Pollution League
Ms. Jane Doughty
5 Market Street
Portsmouth, New Hampshire 03801

Mr. Diana P. Randall
70 Collins Street
Seabrook, New Hampshire 03874

Mr. Calvin A. Canney, City Manager
City Hall
126 Daniel Street
Portsmouth, New Hampshire 03801

Ms. Letty Hett
Town of Brentwood
RFD Dalton Road
Brentwood, New Hampshire 03833

Ms. Roberta C. Pevear
Town of Hampton Falls, New Hampshire
Drinkwater Road
Hampton Falls, New Hampshire 03844

Ms. Sandra Gavutis
Town of Kensington, New Hampshire
RDF 1
East Kingston, New Hampshire 03827

Chairman, Board of Selectmen
Town Hall
South Hampton, New Hampshire 03827

Mr. Angie Machiros, Chairman
Board of Selectmen for the Town of Newbury
Newbury, Massachusetts 01950

Ms. Rosemary Cashman, Chairman
Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts 01913

Honorable Richard E. Sullivan
Mayor, City of Newburyport
Office of the Mayor
City Hall
Newburyport, Massachusetts 01950

Mr. Donald E. Chick, Town Manager
Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Mr. William B. Derrickson
Senior Vice President
Public Service Company of
New Hampshire
Post Office Box 700, Route 1
Seabrook, New Hampshire 03874

Mr. Alfred V. Sargent,
Chairman
Board of Selectmen
Town of Salisbury, MA 01950

Senator Gordon J. Humphrey
U. S. Senate
Washington, DC 20510
(Attn: Tom Burack)

Senator Gordon J. Humphrey
1 Pillsbury Street
Concord, New Hampshire 03301
(Attn: Herb Boynton)

Mr. Owen B. Durgin, Chairman
Durham Board of Selectmen
Town of Durham
Durham, New Hampshire 03824

Charles Cross, Esq.
Shaines, Mardrigan and
McEaschern
25 Maplewood Avenue
Post Office Box 366
Portsmouth, NH 03801

Mr. Guy Chichester, Chairman
Rye Nuclear Intervention
Committee
c/o Rye Town Hall
10 Central Road
Rye, New Hampshire 03870

Jane Spector
Federal Energy Regulatory
Commission
825 North Capital Street, NE
Room 8105
Washington, D. C. 20426

Mr. R. Sweeney
New Hampshire Yankee Division
Public Service of New Hampshire
Company
7910 Woodmont Avenue
Bethesda, Maryland 20814

SEABROOK STATION UNITS 1 AND 2
REQUEST FOR ADDITIONAL INFORMATION
CONCERNING POST-FIRE SAFE SHUTDOWN
AUXILIARY SYSTEMS BRANCH

410.57 A recent plant inspection at another facility revealed that for a fire in the control room, isolation transfer switches for certain hot shutdown systems/components had to be switched to the alternate or isolated position prior to damage occurring to these circuits. If this were not accomplished in time, fuses would have to be replaced in order to make safe shutdown system/component operable. This situation existed because the transfer switches did not place new/redundant fuses into the control power circuit, but left the existing (assumed blown) set of fuses in the circuit. For most of the transfer switches, the situation did not cause a problem since the desired effect after isolation was the deenergization of power. In other instances where the system/component had to be operable or where operation might be required to override a spurious actuation (such as a motor operated valve) replacement of fuses would be required if blown.

Although the present isolation switches at Seabrook do isolate the required equipment or component from the control room, it has not been demonstrated that it is unnecessary to replace fuses in order to place the equipment/component in the desired mode of operation or position. In order for us to conduct a review to determine if fuse replacement is necessary for the operation of a safety system after a control room fire, please provide the following:

- a. The results of your review of electrical design drawings for the existing isolation transfer switches to determine where and if this situation exists.
- b. If the Seabrook design necessitates the changing of fuses to achieve and maintain hot shutdown after a control room fire, provide modifications to existing switches and/or install new isolation switches where necessary to provide redundant fusing such that a blown fuse will not require replacement to achieve and maintain hot shutdown.

410.58 We have a concern regarding the potential for multi-high impedance faults in AC power circuits which could result in the loss of power to safe shutdown equipment. Figure 1 contains a sketch of circuit designs which could result in the loss of needed power to safe shutdown equipment. As can be seen in Figure 1, redundant divisions of safe shutdown cables are properly separated in accordance with Appendix R criteria. However, a fire in fire area A would result in loss of Division A safe shutdown equipment and cause damage to nonsafe shutdown cables associated with the Division B bus. Further, the individual fault current resulting from the fire damage in the nonsafe shutdown cables may not be enough to trip the individual breakers (B_1 and B_2), but the sum of the faults may be sufficient to trip the main breaker, B_3 . If this were to occur, the Division B bus and the corresponding redundant Division B safe shutdown would be lost. You must show that multi-high impedance faults in AC power circuits resulting from a single fire cannot result in the loss of function of any safety-related system as outlined above.




FIGURE 1: MULTIPLE HIGH IMPEDENCE FAULTS