



Carolina Power & Light Company

MAY 06 1985

SERIAL: NLS-85-152

Director of Nuclear Reactor Regulation
Attention: Mr. D. B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing
United States Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62
SUPPLEMENT TO REQUEST FOR LICENSE AMENDMENT
MISCELLANEOUS TECHNICAL SPECIFICATION REVISIONS

Dear Mr. Vassallo:

Carolina Power & Light Company (CP&L) requested a license amendment regarding miscellaneous Technical Specification (TS) revisions in a letter dated September 7, 1982. During recent conference calls with members of your staff, CP&L agreed to revise the footnote pertaining to surveillance requirement 4.6.1.1.a. Our original request excluded from the requirements of 4.6.1.1.a those valves, blind flanges, and deactivated automatic valves which are located inside the containment or high radiation areas. The revised footnote identifies the high radiation areas as (1) the MSIV Pit, (2) the RWCU Room, (3) the TIP Room, and (4) above the drywell head. In addition, the wording of the GE BWR/4 Standard Technical Specification regarding de-inerted containment atmosphere was adopted and reference to Specification 3.6.2.2 was changed to 3.6.2.1 in Specification 4.6.1.1.c.

The revised Brunswick-1 and Brunswick-2 TS pages are included in Enclosure 1. Please refer further questions regarding this matter to Mr. Sherwood R. Zimmerman at (919) 836-6242.

Yours very truly,

A. B. Cutter - Vice President
Nuclear Engineering & Licensing

ABC/MAT/ccc (1431MAT)
Enclosure

cc: Mr. L. W. Garner (NRC-BNP)
Dr. J. Nelson Grace (NRC-R11)
Mr. M. Grotenhuis (NRC)

A. B. Cutter, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, contractors, and agents of Carolina Power & Light Company.

Notary (Seal)

My commission expires: 11/27/89

8505100398 850506
PDR ADDCK 05000324
P PDR

Street • P. O. Box 1551 • Raleigh, N. C. 27602

