



6200 Oak Tree Boulevard
Independence OH
216-447-3100

Mail Address
P.O. Box 94661
Cleveland, OH 44101-4661

Docket Number 50-346

License Number NPF-3

Serial Number 2382

September 12, 1996

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Subject: License Amendment Application to Revise Technical Specifications
Regarding Reactivity Control Systems and Emergency Core Cooling
Systems for Conversion to a 24 Month Fuel Cycle

Ladies and Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications. The proposed changes involve: Technical Specification (TS) 3/4.1.3.4, Reactivity Control Systems - Rod Drop Time, and TS 3/4.5.2, Emergency Core Cooling Systems - $T_{avg} \geq 280^{\circ}\text{F}$.

The proposed changes would modify the presently specified 18 month surveillance frequencies in TS Surveillance Requirement (SR) 4.1.3.4.c and SR 4.5.2.b to new specified frequencies of once each Refueling Interval. These changes are in accordance with the NRC guidance provided by Generic Letter 91-04, "Changes in Technical Specification Surveillance Intervals to Accommodate a 24-Month Fuel Cycle," and will support conversion of the DBNPS from an 18 month to a 24 month fuel cycle.

The proposed changes would also modify TS SR 4.5.2.b to remove a footnote which is no longer applicable.

The DBNPS is commencing longer fuel cycles during the current Cycle 11. This license amendment application is one of several applications which will be submitted in the next several months in support of the 24 month fuel cycle conversion. These applications are being submitted to the NRC as a Cost Beneficial Licensing Action. As will be demonstrated in each license amendment application, the proposed changes will not adversely impact safety. The proposed changes will provide an estimated cost savings of \$24 million over the DBNPS's remaining operating life.

20 - 11
9609200118 960912
PDR ADOCK 05000346
P PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison


AC001/1

Docket Number 50-346
License Number NPF-3
Serial Number 2382
Page 2

Toledo Edison requests that this amendment be issued by the NRC by February 28, 1997.

Should you have any questions or require additional information, please contact Mr. James L. Freels, Manager - Regulatory Affairs, at (419) 321-8466.

Very truly yours,



J. K. Wood
Vice President - Nuclear
Davis-Besse Nuclear Power Station

MKL/laj

Enclosure

cc: L. L. Gundrum, NRC/NRR Project Manager
A. B. Beach, Regional Administrator, NRC Region III
S. Stasek, NRC Region III, DB-1 Senior Resident Inspector
J. R. Williams, Chief of Staff, Ohio Emergency Management Agency,
State of Ohio (NRC Liaison)
Utility Radiological Safety Board