

LICENSEE: Northern States Power Company (NSP) September 18, 1996
FACILITY: Prairie Island Nuclear Generating Plant
SUBJECT: MEETING WITH NSP TO DISCUSS PRAIRIE ISLAND NUCLEAR GENERATING
PLANT'S SUBMITTAL FOR AN AMENDMENT REGARDING SOLUBLE BORON
CREDIT

On August 27, 1996, the staff met with representatives from NSP, Westinghouse and the Westinghouse Owners Group to discuss issues pertaining to the Prairie Island Nuclear Generating Plant's submittal for an amendment regarding soluble boron credit. Prairie Island is requesting this amendment as the lead plant for the Westinghouse Owners Group. Attachment 1 contains a list of meeting attendees. Representatives from Westinghouse and NSP made presentations pertaining to the soluble boron credit submittal. Attachment 2 is a copy of the overhead slides used during the presentations.

The licensee and Westinghouse presented a discussion stating why they believe that the amendment submittal can be noticed as a no significant hazards determination. They specifically addressed the fact that the margin of safety would not be reduced because the K_{eff} limit will remain 0.95. However, the staff stated that the amendment cannot be noticed as a no significant hazards determination because the staff must now perform a review of a boron dilution event, which is an event that had not been previously considered. Although the licensee contends that a boron dilution accident in the Prairie Island spent fuel pool is implausible because not enough water exists onsite to create the event, the staff must still perform a technical review of the accident as part of the licensee's submittal. The staff plans to review dilution events on a plant-specific basis.

The review schedule was also briefly discussed during the meeting. The staff is currently performing its review of the Westinghouse generic topical report, which supports Prairie Island's amendment. The staff expects to have the Prairie Island plant-specific review completed by early 1997. Several other plants are interested in submitting similar amendment requests, based on the review and approval of Prairie Island's amendment.

Original signed by:

Beth A. Wetzel, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9609200287 960918
PDR ADOCK 05000282
P PDR

Docket Nos: 50-282 and 50-306

Attachments: As stated

cc w/att: See next page

DISTRIBUTION: See attached list

DOCUMENT NAME: G:\WPDOCS\PRAIRIE\PIMTG896.SUM

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PM:PD31	E	LA:PD31	E	D:PD31				
NAME	BWetzel <i>BW</i>		CJamerson <i>CJ</i>		JHannon				
DATE	9/16/96		9/13/96		9/17/96				

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

Distribution for Prairie Island Meeting Summary Dated: September 18, 1996

HARD COPY (w/atts)

Docket File(50-282/50-306)

PUBLIC

PD# 3-1 Reading

OGC

ACRS

B. Wetzel

E-MAIL

W. Russell/F. Miraglia

R. Zimmerman

J. Roe

C. Jamerson

E. Jordan (e-mail to JKR)

R. C. Jones, Jr.

L. Kopp

E. Weiss

B. McCabe

M. Jordan, RIII

S. Ray, RIII

200094

Northern States Power Company

Prairie Island Nuclear Generating
Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Mr. Roger O. Anderson, Director
Licensing and Management Issues
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Site General Manager
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
455 Minnesota Street
Suite 900
St. Paul, Minnesota 55101-2127

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
1719 Wakonade Drive East
Welch, Minnesota 55089-9642

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Jeff Cole, Auditor/Treasurer
Goodhue County Courthouse
Box 408
Red Wing, Minnesota 55066-0408

Kris Sanda, Commissioner
Department of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

Site Licensing
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

March 1995

MEETING ATTENDEES

<u>Name</u>	<u>Organization</u>
M. Reinhart	NRC
B. Wetzel	NRC
R. Jones	NRC
E. Weiss	NRC
L. Kopp	NRC
G. Eckholt	NSP
T. Breene	NSP
W. Newmyer	Westinghouse
J. Andrachek	Westinghouse
W. Cross	Southern Technical Services
N. Chapman	Bechtel
P. Sharp	FP&L
M. McBurnett	HL&P
J. Stringfellow	SNC



WOG Spent Fuel Pool Boron Credit Meeting

August 27, 1996

WOG SFP Boron Credit Meeting

- Credit for Boron in SFP is an Unreviewed Safety Question
 - Submitted for NRC review and approval
- Margin of Safety
 - Boron Credit not currently licensed
 - Margin for Spent Fuel Racks without Boron Credit
 - Margin for Spent Fuel Racks with Boron Credit
- Evaluation of Boron Dilution
- Unanalyzed Conservatisms on Keff
- Conclusions

Why Boron Credit in the SFP?

- Boron Credit Applied to SFP Racks Delays/Eliminates Need to Re-rack or Provide On-site Storage By:
 - Allowing Higher Fuel Assembly Enrichments
 - Removing Empty Cell Checkerboard Restrictions
 - Allowing Continued Use of SFP Racks with Boraflex

Margin of Safety

- No Credit for Soluble Boron is Currently Licensed for Normal Storage in Spent Fuel Racks
- Without Credit for Boron - Keff Limit is 0.95
- With Credit for Boron - Keff Limit is 0.95
(With Small Percentage of Spent Fuel Pool Soluble Boron Concentration)

Margin of Safety - Prairie Island SF Racks

- Current Licensed Storage Configuration
 - $K_{eff} = 0.94480$
- Proposed Boron Credit Storage Configuration
 - $K_{eff} = 0.94769$ with 250 ppm
- Both Storage Configuration show $K_{eff} \leq 0.95$

Dilution of SFP Boron


- No Credible Boron Dilution of the SFP can increase K_{eff} above 0.95
- Criticality prevented by Maximum Feasible K_{eff} less than 1.0
- Example Case:
 - 232,000 gallon SFP (PRA Composite Plant)
 - 2000 ppm initial soluble boron concentration
 - SFP Dilution with constant SFP volume

Dilution of SFP Boron

$$\mathbf{K_{eff} = 0.95}$$

- Significant amount of soluble boron required to dilute K_{eff} to 0.95
 - 511,000 Gallons of Water Needed to Dilute
 - 28 Hours Required to Dilute at 300 gpm


Volume to Dilute versus Keff



Dilution above $K_{eff} = 0.95$

K_{eff}	Gallons to Dilute to K_{eff} from 2000 ppm	Gallons to Dilute 0.10 Delta K	Hours to Dilute 0.10 Delta K at 300 gpm	Cumulative Hours Since $K_{eff} = 0.95$	Cumulative Hours Since 2000 ppm
0.95	511000				28
0.96	570000	60000	3.3	3.3	31.3
0.97	640000	70000	3.9	7.2	35.2
0.98	730000	90000	5	12.2	40.2
0.99	830000	100000	5.6	17.8	45.8

Volume to Dilute versus Keff



Unanalyzed Conservatism on Keff

- No Credit is taken in the criticality analysis for:
 - Remaining Boraflex
 - Assembly Grids, Sleeves, Nozzles
 - U-234 or U-236
 - Presence of Uncredited Burnable Neutron Absorbers
 - Decay of Fissile Fission Products over time
 - Buildup of Neutron Absorbing Material over time
 - Actual Fuel Assembly Enrichment or Burnups
 - Limit is calculated - Assembly must meet that limit

Conclusions

- Credit for Boron in the SFP is an USQ
- Keff limit of 0.95 is maintained with Boron Credit
- No Credible Boron Dilution can Increase Keff Above 0.95
- Several unquantified conservatisms still exist on Keff
- Therefore, this does not represent a significant hazard as defined by 10CFR50.92