Southern Nuclear Operating Company Post Office Box 1295 Birmingham, Alabama 35201 Telephone 205, 868-5086 Southern Nuclear Operating Company J. D. Woodard Vice President July 22, 1992 Docket No. 50-364 10CFR50.55a(q) 10CFR50.36 U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555 Joseph M. Farley Nuclear Plant - Unit 2 Interval 1/Period 3/Outage 3 and Interval 2/Period 1/Outage 1 Inservice Inspection Reports Gentlemen: Pursuant to the requirements of 10CFR5C.55a(g) and 10CFR50.36, Southern Nuclear Company herewith submits the Joseph M. Farley Nuclear Plant Unit 2 Interval 1/Period 3/Outage 3 and Interval 2/Period 1/Outage 1 Inservice Inspection Reports. These reports describe and summarize the inservice inspection activities performed during the Unit 2 eighth refueling outage. These activities were completed May 6, 1992. Completion of the Unit 2 First Ten Year Interval examinations were deferred until the eighth refueling outage per the ASME Code, Section XI, IWA-2400. The results of these examinations are reported in the Interval 1/Period 3/Outage 3 report. Completely separate and distinct examinations and reports were made as required for each Interval's examinations. Included in the Interval 2/Period 1/Outage 1 report are the results of the steam generator eddy current testing conducted during this outage as required by 10CFR50.55a(g) and Section 4.4.6.5.b of the Farley Nuclear Plant Unit 2 Technical Specifications. Specifically, the results and a summary may be found in Tab B. Other pertinent report information is available at Farley Nuclear Plant for your review. This information includes as applicable, examination plans and schedules, examination results and reports, examination methods and procedures, evaluation results, and corrective actions and repairs. If there are by questions, please advise. Respectfully submitted. 290011 J. D. Woodard JDW/CDP:pgr-nrc-oa Enclosure cc: Mr. S. D. Ebneter w/l encl. Mr. S. T. Hoffman Mr. G. F. Maxwell 9207310033 920722 PDR ADDCK 05000364