



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ENTERGY OPERATIONS, INC.

DOCKET NO. 50-382

WATERFORD STEAM ELECTRIC STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76
License No. NPF-38

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated April 24, 1992, as supplemented by letter dated August 27, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating license No. NPF-38 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 76 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John T. Larkins, Director
Project Directorate IV-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 18, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 76
TO FACILITY OPERATING LICENSE NO. NPF-38
DOCKET NO. 50-382

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

3/4 7-9

3/4 3-23

INSERT PAGES

3/4 7-9

3/4 3-23

PLANT SYSTEMS

MAIN STEAM LINE ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.5 Each main steam line isolation valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

MODE 1

With one main steam line isolation valve inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours; otherwise, be in at least HOT STANDBY within the next 6 hours.

MODES 2, 3, and 4

With one main steam line isolation valve inoperable, subsequent operation in MODE 2, 3, or 4 may proceed provided:

- a. The isolation valve is maintained closed.
- b. The provisions of Specification 3.0.4 are not applicable.

Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.1.5 Each main steam line isolation valve shall be demonstrated OPERABLE by verifying full closure within 4.0 seconds when tested pursuant to Specification 4.0.5.

PLANT SYSTEMS

3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION

LIMITING CONDITION FOR OPERATION

3.7.2 The temperature of the secondary coolant in the steam generators shall be greater than 115°F when the pressure of the secondary coolant is greater than 210 psig.

APPLICABILITY: At all times.

ACTION:

With the requirements of the above specification not satisfied:

- a. Reduce the steam generator pressure to less than or equal to 210 psig within 30 minutes, and
- b. Perform an engineering evaluation to determine the effect of the overpressurization on the structural integrity of the steam generator. Determine that the steam generator remains acceptable for continued operation prior to increasing its temperatures above 200°F.

SURVEILLANCE REQUIREMENTS

4.7.2 The pressure of the steam generators shall be determined to be less than 210 psig at least once per hour when the temperature of the secondary coolant is less than 115°F.

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INITIATING SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
2. <u>Pressurizer Pressure-Low</u>	
a. Safety Injection (ECCS) (1) High Pressure Safety Injection (2) Low Pressure Safety Injection	$\leq 30.0^*/18.5^{**}$ $\leq 45.5^*/34.0^{**}$
b. Containment Isolation	$\leq 23.5^*/12.0^{**}$
c. Containment Cooling	$\leq 31.0^*/19.5^{**}$
3. <u>Containment Pressure-High</u>	
a. Safety Injection (ECCS) (1) High Pressure Safety Injection (2) Low Pressure Safety Injection	$\leq 30.0^*/18.5^{**}$ $\leq 45.5^*/34.0^{**}$
b. Containment Isolation	$\leq 23.5^*/12.0^{**}$
c. Main Steam Isolation	$\leq 5.0^*/5.0^{**}$
d. Main Feedwater Isolation	$\leq 6.0^*/6.0^{**}$
e. Containment Cooling	$\leq 31.0^*/19.5^{**}$
4. <u>Containment Pressure--High-High</u>	
a. Containment Spray Pump	$\leq 15.2^*/2.7^{**}$
b. Containment Spray Valves	$\leq 11.0^*/11.0^{**}$
c. CCW to RCP Valves	$\leq 23.5^*/12.0^{**}$
5. <u>Containment Area Radiation-High#</u>	
Containment Purge Valves Isolation	$\leq 6.2^*/6.2^{**}$
6. <u>Steam Generator Pressure-Low</u>	
a. Main Steam Isolation	$\leq 5.0^*/5.0^{**}$
b. Main Feedwater Isolation	$\leq 6.0^*/6.0^{**}$
7. <u>Refueling Water Storage Pool-Low</u>	
Containment Sump Recirculation	$\leq 120.0^*/108.5^{**}$
8. <u>4.16 kV Emergency Bus Undervoltage (Loss of Voltage)</u>	
Loss of Power (0 volts)	$\leq 2^{***}$
9. <u>480V Emergency Bus Undervoltage (Loss of Voltage)</u>	
Loss of Power (0 volts)	N.A.
10. <u>4.16 kV Emergency Bus Undervoltage (Degraded Voltage)</u>	
Loss of Power	$\leq 11^{***}$

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
11. <u>Steam Generator Level-Low</u>	
Emergency Feedwater Pump and Block Valves	$\leq 54.0^*/42.0^{**}$
12. <u>Wide Range Steam Generator Level-Low</u>	
Emergency Feedwater Control Valves	$\leq 25.0^*/25.0^{**}$

NOTE: Response time for all Motor-Driven and Steam-Driven Emergency Feedwater Pumps on all ESF signal starts. ≤ 54.0

TABLE NOTATIONS

*Diesel generator starting and sequence loading delays included. Response time limit includes movement of valves and attainment of pump or blower discharge pressure.

**Diesel generator starting and sequence loading delays not included. Offsite power available. Response time limit includes movement of valves and attainment of pump or blower discharge pressure.

***Response time measured from the sensing relay to the channel output only.

#Response time does not include the detector.