



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 3, 1992

Docket Nos. 50-338
and 50-339

Mr. W. L. Stewart
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: NORTH ANNA POWER STATION, UNITS NO. 1 AND NO. 2 (NA-1&2)
EXEMPTION FROM REQUIREMENTS OF 10 CFR PART 50, APPENDIX
A, GENERAL DESIGN CRITERION-2 FOR NA-1&2 (TAC NOS.
M84103 AND M84458) AND EXEMPTION FROM REQUIREMENTS OF
10 CFR 50.49, ENVIRONMENTAL QUALIFICATION OF ELECTRIC
EQUIPMENT IMPORTANT TO SAFETY FOR NUCLEAR POWER PLANTS
FOR NA-2 (TAC NO. M84487)

The Commission has issued the enclosed exemptions from the requirements of 10 CFR Part 50, Appendix A, General Design Criterion-2 (GDC-2), for NA-1&2, and from the requirements of 10 CFR 50.49, Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants, for NA-2.

The Virginia Electric and Power Company (VEPCO) plans to perform refurbishment activities for restoration of certain portions of the service water system (SWS) at NA-1&2 during the forthcoming NA-1 steam generator replacement program (SGRP). Implementation of the SWS repair and replacement program requires removing the surrounding earth and/or concrete encasement of certain portions of normally buried SW headers. As a result, the normal design basis protection against natural phenomena afforded by earth and concrete encasement will temporarily be removed from certain SW components. Therefore, pursuant to 10 CFR 50.12(a), VEPCO has requested a temporary exemption from the requirements of 10 CFR Part 50, Appendix A, GDC-2, for NA-1&2 during the Phase 1, Stage 1 SWS restoration activities. Based on the current NA-1 SGRP outage schedule, VEPCO has requested that the GDC-2 exemption period be from December 1, 1992 until June 30, 1993.

Also, during most of the Phase 1 stage of the SW restoration project, it will be necessary to isolate SW from the NA-1 control room chillers. VEPCO plans to provide a temporary water supply and return path to the NA-1 control room chillers from the common bearing cooling water system to provide normal control room temperatures and provide a reliable backup cooling system to the NA-2 air conditioning chillers. However, this will affect the normal environmental qualification design basis for the NA-2 control room chillers. Therefore, pursuant to 10 CFR 50.12(a), VEPCO has requested a temporary exemption from the requirements of 10 CFR 50.49, Environmental Qualification

9212100072 921203
PDR ADOCK 05000338
P PDR

NRC FILE CENTER COPY

Handwritten signature and initials
1/11

December 3, 1992

of Electric Equipment Important to Safety for Nuclear Power Plants, for NA-2 for approximately the duration of the NA-1 SGRP outage.

The staff notes that Phase I Stage I of the SW restoration project is not in conformance with NRC guidance in Generic Letter 91-18, "Information to Licensees Regarding Two NRC Inspection Manual Sections on Resolution of Degraded and Nonconforming Conditions and on Operability," relative to performance of on-line preventive maintenance in that you plan repeated entering and exiting of LCO action statements. You have been made aware of the staff's concerns and have planned adequate compensatory measures and taken other steps to minimize risks.

A safety evaluation supporting the above exemptions is also enclosed. Also, a copy of the exemptions is being forwarded to the Office of Federal Register for publication.

Sincerely,

(Original Signed By)

Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Exemptions
2. Safety Evaluation

cc w/enclosures:

See next page

OFC	LA:PD22:DRPE	PM:PD22:DRPE	D:PD22:DRPE	OGC <i>g/b</i>	AD:R-II
NAME	ETANA <i>ETT</i>	LENGLER <i>mxs</i>	HBERKOW <i>HB</i>	<i>G. HOLLER</i>	GLAINAS
DATE	12/1/92	12/1/92	12/1/92	12/3/92	12/13/92
OFC	D:DSSA GHolanan	D:DRPE			
NAME	ATHADANI for	SVARGA			
DATE	12/2/92	12/3			

Doc Name: A:84103.1tr

Mr. W. L. Stewart
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:
Mr. William C. Porter, Jr.
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

Michael W. Maupin, Esq.
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Regional Administrator, RII
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Dr. W. T. Lough
Virginia State Corporation Commission
Division of Energy Regulation
P.O. Box 1197
Richmond, Virginia 23209

Mr. G. E. Kane, Manager
North Anna Power Station
P.O. Box 402
Mineral, Virginia 23117

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. M. L. Bowling, Manager
Nuclear Licensing & Programs
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
Route 2, Box 78
Mineral, Virginia 231172

Memorandum Dated December 3, 1992

Distribution

~~Docket File~~

NRC & Local PDRs

PD# II-2 Reading

T. Murley/F. Miraglia

J. Partlow

B. Grimes

J. Lieberman

S. Varga

G. Lainas

H. Berkow

E. Tana

L. Engle

OGC

E. Jordan

G. Hill

ACRS (10)

OPA

OC/LFDCB

L. Plisco, EDO

E. Merschhoff, R-II

M. Sinkule, R-II

Senior Resident Inspector, North Anna

A. Thadani

W. Beckner

C. McCracken