

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
NIAGARA MOHAWK POWER CORPORATION) Docket No. 50-220
(Nine Mile Point Nuclear Station Unit No. 1))

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of the Facility Operating License No. DPR-63, hereby requests that Section 3.6.2 and 3.6.11 Instrumentation, the associated bases, and tables of the Technical Specifications set forth in Appendix A to the License be amended. These proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. The changes represent revisions to increase surveillance test intervals (STIs) and add allowable out-of-service times (AOTs) for specified instrumentation. Included in this proposal are two editorial corrections which do not alter meaning or intent. Also, deletion of a footnote which involved a 1986 licensing condition, which is no longer applicable, is being proposed. The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analysis which demonstrate that the proposed changes involve no significant hazards consideration pursuant to 10 CFR 50.92, are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By B. Ralph Sylvia
B. Ralph Sylvia
Executive Vice President - Nuclear

Subscribed and sworn to before
me on this 4th day of Dec 1992

Beverly W. Ripka
NOTARY PUBLIC

BEVERLY W. RIPKA
Notary Public State of New York
Qual. in Oswego Co. No. 4644879
My Commission Exp. Mar. 31, 1994
2/28/94

9212100134 921204
PDR ADOCK 05000220
P PDR