December 7, 1992

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-92-042

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date.

FACILITY: River Bend Station Gulf States Utilities Docket: 50-458 Licensee Emergency Classification:
Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
X Not Applicable

SUBJECT: PLANT SHUTDOWN GREATER THAN 72 HOURS

On December 6, at 5:30 p.m., the licensee manually scrammed the reactor to complete a planned shutdown. The outage was scheduled to replace the Reactor Recirculation Pump B seal package. The licensee had indications of a degraded inboard seal. The outboard seal functioned correctly, therefore there was no increase in leakage from the pump. The scope of outage work also includes troubleshooting and repairing the CHC pressure regulator, replacing a pedestal sump pump, repairing secondary plant steam leaks, and repairing a generator hydrogen seal oil system leak. Depending on the conditions that the licensee finds in the pump seal, the outage scope may by increased to include the Recirculation Pump A seal package. The licensee plans to begin plant start up on December 11, 1992.

The state of Louisiana will be informed.

Region IV received confirmation of this occurrence from the resident inspector at 7:45 a.m., on December 7, 1992. Region IV has informed EDO, NRR, and PA.

This information has been confirmed with a licensee representative.

CONTACT: Jim Gagliardo, Region IV (817) 860-8270.

RIV:C:PSC/DRP JEGag Niardo; 1t 12/7/92

D:DRP ABBeach 12/7/92

RSLO CAHackney 12/7/92

RA/ JLMilhoan 12/7/92

10006

9212110109 921207 PDR 1&E PNO-1V-92-042 PDR

DISTRIBUTION: L-ST MAIL: DCS (Orig. IE34)
PDR DOT (Transp. Only) NMBE AEOD FAX INPO OWFN Chairman Selin OCA NMSS IRM Comm. Rogers OGC NRR NSAC Comm. Curtiss Comm. Remick TRI EWW DIG SLITP LSSA PA NL OE Comm. de Planque RES EDO

The Ellin

0