OPERATING DATA REPORT

DOCKET NO. 50-366 DATE 1-10-80 J. W. Roden TELEPHONE 912-367-7781

	Notes					
2. Reporting Period: December 1979 3. Licensed Thermal Power (MWt): 2436 MWt 4. Nameplate Rating (Gross MWe): 817.0 Gross MWe						
782.0 Gross MW	d					
749.0 Net MWe						
umber 3 Through 7) Si	nce Last Report, Give Re	asons:				
MWe):		4				
This Month	Yrto-Date	Cumulative				
744	2833	2833				
744.0	2663.5	2663.5				
0.0	0.0	0.0				
744.0	and the same of th	2414.5				
0.0	0.0	0.0				
	5494062	5494062				
AND DESCRIPTION OF THE PARTY OF	1835960	1835960				
588617	1757137	1757137				
100.0	85.2	85.2				
100.0	85.2	85.2				
105.6	82.8	82.8				
100.9	79.1	79.1				
0.0	10.6	10.6				
pe, Date, and Duration	of Each): March 1 to April	13				
The second of		***				
ted Data of Startus		*********************				
ntion):	Forecast	Achieved				
	**************************************	***************************************				
	-	ARTHUR AND STATE				
	This Month 744 744.0 0.0 1793810 612090 588617 100.0 105.6 100.9 0.0 pe, Date, and Duration lance Outage, lated Date of Startup:	This Month Yrto-Date 744.0 2663.5 0.0 2414.5 0.0 1793810 5494062 612090 1835960 588617 1757137 100.0 85.2 100.0 85.2 100.6 82.8 100.9 79.1 0.0 10.6 pe, Date, and Duration of Each): 11ance Outage, March 1 to April				

90023076

8001150 493 (1)77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-366

UNIT Hatch 2

DATE 1-10-80

COMPLETED BY J. W. Roden

TELEPHONE 912-367-7781

AVERAGE DAILY POWER LEVEL (MWe-Net) 803	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net) 802
750	18	803
794	19	802
804	20	802
802	21	802
798	22	770
798	23	761
741	24	797
799	25	798
801	26	800
796	27	802
795	28	801
791	29	768
793	30	799
757	31	800
799		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/771

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-366 UNIT NAME Hatch 2 DATE 01-10-80 COMPLETED BY J.W. Roden TELEPHONE 912-367-7781

REPORT MONTH December

Method of Shutting Down Reactors Reason-Duration (Hours) Typel Licensee Cause & Corrective No. Date Event Action to Report # Prevent Recurrence No outages for the month.

F: Forced S: Scheduled

4

Reason

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scrain.

3-Automatic Scram.

4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit I - Same Source

NARRATIVE REPORT

There was no single release of radioactivity or single radiation exposure which accounts for more than 10% of the allowable annual values during the previous month of 1979.

HATCH 2 SAFETY-RELATED MAINTENANCE REQUESTS TO BE REPORTED FOR OCTOBER 1979

NUMBER	DATE COMPLETED	DESCRIPTION
79-5906	12-15-79	Checked for loose connections on Safe Guard Equipment Cooling fans
79-5875	12-14-79	Repaired RBM Channel "A"
79-5487	12-14-79	Repaired downscale RPM indicator in Control Room for RCIC
79-5700	11-30-79	Replaced HPCI flow transmitter
79-5742	12-11-79	Repaired RWCU backwash inlet valve
79-5296	12-11-79	Repaired air line leak to HPCI steam line pot drain AOV
79-5783	12-11-79	Calibrated torus water level recorder
79-5739	12-4-79	Repaired safety relief valve; reset keylock switch
79-5743	12-6-79	Replaced HPCI steam line dP instrument
79-1759	12-5-79	Relapped safety relief valves
79-4848	12-7-79	Repaired PSW inlet AOV
79-5488	11-21-79	2C diesel generator trips on high crankcase pressure
79-5668	12-4-79	Repaired blown seat on RWCU pump "A"
79-5576	11-29-79	Broken sight glass on RWCU precoat returned
79-5606	12-2-79	Blown gasket on RWCU precoat tank flow glass

79-5544	11-29-79	Investigated and repaired B LPCI inverter
79-5238	11-29-79	Investigated and repaired operation of the level switch for fuel oil transer pumps
79-5585	12-14-79	2D PSW not pumping required flow
79-6003	12-26-79	Repaired standby diesel service water pump
79-5440	12-23-79	Repaired oil leak on Unit 2 3B RHR and core spray jockey pump

OPERATING DATA REPORT

DOCKET NO. 50-366 DATE 12-10-79 G. L. Johnson TELEPHONE 912-367-7781

OPERATING STATUS			
1. Unit Name: Hatch 2 2. Reporting Period: November 1979 3. Licensed Thermal Power (MWt): 2436 M 4. Nameplate Rating (Gross MWe): 817.0 Gr 5. Design Electrical Rating (Net MWe): 784.0 6. Maximum Dependable Capacity (Gross MWe): 7. Maximum Dependable Capacity (Net MWe):	Notes Two changes were made. Monthly Gen. on-line #14 was 607.4. Shutdown #79-30 dur- ation was changed from 48.6 to correct for round-off errors.		
8. If Changes Occur in Capacity Ratings (Items N	sumber 3 Through 7) Sin	ce Last Report, Give Rea	isons:
9. Power Level To Which Restricted, If Any (Net 10. Reasons For Restrictions, If Any:			
	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period 12. Number Of Hours Reactor Was Critical 13. Reactor Reserve Shutdown Hours 14. Hours Generator On-Line 15. Unit Reserve Shutdown Hours 16. Gross Thermal Energy Generated (MWH) 17. Gross Electrical Energy Generated (MWH) 18. Net Electrical Energy Generated (MWH) 19. Unit Service Factor 20. Unit Availability Factor 21. Unit Capacity Factor (Using MDC Net) 22. Unit Capacity Factor (Using DER Net) 23. Unit Forced Outage Rate 24. Shutdowns Scheduled Over Next 6 Months (TVent Header Deflector and Survey)	720 689.1 0.0 607.3 0.0 1385270 457910 438341 84.4 84.4 81.3 77.7 4.5 Type Date and Duration eillance Outage,	2089 1919.5 0.0 1670.5 0.0 3700252 1223870 1168520 80.0 80.0 74.7 71.3 14.6 of Each): March 1 to April	2089 1919.5 0.0 1670.5 0.0 3700252 1223870 1168520 80.0 80.0 74.7 71.3 14.6
25. If Shut Down At End Of Report Period, Estin 26. Units In Test Status (Prior to Commercial Op		Forecast	Achieved
INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION	ON		

90023082

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-366 UNIT NAME DATE TELEPHONE 912-367-7781

REPORT MONTH November

No.	Date	Type1	Duration (Hours)	Reason -	Method of Shuffing Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code5	Cause & Corrective Action to Prevent Recurrence
79-30	79-11-3	S	48.4	В	1	. NA	СВ	нтехсн	Shutdown due to inop HPCI Inboard Isolation Valve
79-31	79-11-9	F	12.7	A	3	NA	НЈ	НТЕХСН	Rx Scram: due to MSR High Level
79-32	79-11-10	F	13.6	Α	3	NA	CD	VALVEX	Rx Scram: MSIV closed due to momentary loss of power to the 4160 volt buss
79-33	79-11-14	F	19.2	A	3	NA	EC	MOTORX	Rx Scram: Loss of DC to EHC when taking LPCI inverter out of service
79-34	79-11-18	S	18.	В	1	NA ·	СВ	нтехсн	Shutdown to repair inop LPCI inverter

F: Forced S: Scheduled Reason:

A-Fquipment Failure (Explain) B-Maintenance of Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

II-Other (Explain)

Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source