


James A. FitzPatrick  
Nuclear Power Plant  
P.O. Box 41  
Lycoming, New York 13093  
315 342-3840



Harry P. Salmon, Jr.  
Resident Manager

December 14, 1992  
JAFP-92-0848

U.S. Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, D.C. 20555

Attention: Document Control Desk  
SUBJECT: OPERATING STATUS REPORT  
Reference. DOCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant Operating Status Report for the month of **November 1992**.

If there are any questions concerning this report, please contact Russell Flagg at (315) 349-6590.

Very truly yours,

  
HARRY P. SALMON, JR.

HPS:RGF:yp *RSY*  
Enclosure

CC: JAF Department Heads  
White Plains Office  
TS File  
RMS, JAF

9212180007 921130  
PDR ADOCK 05000333  
R PDR

*JE 24*

**NEW YORK POWER AUTHORITY  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
OPERATING DATA REPORT**

DOCKET NO.: 50-333  
UNIT NAME: FITZPATRICK  
DATE: DECEMBER 1992  
COMPLETED BY: RUSS FLAGG  
TELEPHONE: (315)349-6590

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 921101 - 921130
3. Licensed Thermal Power (MWT): 2436
4. Nameplate Rating (Gross MWE): 883
5. Design Electrical Rating (Net MWE): 816
6. Maximum Dependable Capacity (Gross MWE) 807
7. Maximum Dependable Capacity (Net MWE) 780

NOTES:

8. if changes occur in capacity ratings (Items 3-7) since last report, give reasons:  
\_\_\_\_\_
9. Power level to which restricted, if any (Net MWE): \_\_\_\_\_
10. Reasons for restrictions, if any: \_\_\_\_\_

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	722.0	6574.0	150600.0
12. Number of Hours Reactor was Critical:	0	0	104831.4
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	0	0	101731.2
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	0	0	223974910.0
17. Gross Electrical Energy Generated (MWH):	0	0	76322860.0
18. Net Electrical Energy Generated (MWH):	0	0	73269365.0
19. Unit Service Factor:	0	0	67.2
20. Unit Availability Factor:	0	0	67.2
21. Unit Capacity Factor (using MDC Net):	0	0	62.4
22. Unit Capacity Factor (using DER Net):	0	0	59.0
23. Unit Forced Outage Rate:	0	0	13.0

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):  
Refuel outage commenced January 11, 1992.
5. If shutdown at end of report period, estimated date of startup: December 21, 1992
26. Units in Test Status (prior to commercial operation):

	FORECAST	ACHIEVED
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NEW YORK POWER AUTHORITY  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333  
UNIT NAME: FITZPATRICK  
DATE: DECEMBER 1992  
COMPLETED BY: RUSS FLAGG  
TELEPHONE: (315)349-6590

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

SUMMARY: The FitzPatrick Plant remained shutdown for the entire reporting period.

NEW YORK POWER AUTHORITY  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 UNIT SHUTDOWNS REPORT

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333  
 UNIT NAME: FITZPATRICK  
 DATE: DECEMBER 1992  
 COMPLETED BY: RUSS FLAGG  
 TELEPHONE: (315)349-6590

NO.	DATE	TYPE	D U H R O A U T R I S T R I C T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M P O D N E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	920601	S	720	C	1	N/A	N/A	N/A	S/D for Refue'ing Commenced 920110 (Cumulative hours 7791).

1  
 F: FORCED  
 S: SCHEDULED

2  
 REASON:  
 A. EQUIPMENT FAILURE (EXPLAIN)  
 B. MAINTENANCE OR TEST  
 C. REFUELING  
 D. REGULATORY RESTRICTION  
 E. OPERATOR TRAINING AND LICENSE EXAMINATION  
 F. ADMINISTRATIVE  
 G. OPERATIONAL ERROR (EXPLAIN)  
 H. OTHER (EXPLAIN)

3  
 METHOD:  
 1. MANUAL  
 2. MANUAL SCRAM  
 3. AUTOMATIC SCRAM  
 4. CONTINUED  
 5. REDUCED LOAD  
 9. OTHER

4  
 EXHIBIT G -INSTRUCTIONS  
 FOR PREPARATION OF DATA ENTRY  
 SHEETS FOR LICENSEE EVENT  
 REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333  
UNIT NAME: FITZPATRICK  
DATE: DECEMBER 1992  
COMPLETED BY: RUSS FLAGG  
TELEPHONE: (315)349-6590

The FitzPatrick Plant remained shutdown for this entire reporting period.

The major work items during this reporting period were:

- Fire Protection System corrective maintenance/modifications
- Startup Surveillance Testing in Progress