

**SUMMARY OF IE BULLETIN 79-01 REVIEW  
BALANCE OF PLANT (INSIDE & OUTSIDE CONTAINMENT)  
AND NSSS (INSIDE CONTAINMENT)  
FOR CLASS IE EQUIPMENT**

**North Anna Power Station Units 1 & 2  
Virginia Electric and Power Company**



STONE & WEBSTER ENGINEERING CORPORATION  
BOSTON, MASSACHUSETTS

8002260 731

IE 79-01

TABLE OF CONTENTS  
PART I  
QUALIFICATION  
BOP

OPERATING ENVIRONMENT

DESCRIPTION	OPERATING ENVIRONMENT		PAGE
	(LOCA)	(MSLB)	
Air conditioning inline pumps			
HV-P-20A		x	1 b,c
HV-P-20B		x	1 b,c
HV-P-20C		x	1 b,c
HV-P-22A		x	1 b,c
HV-P-22B		x	1 b,c
HV-P-22C		x	1 b,c
Air conditioning self-cleaning strainer			
HV-S-1A		x	2,a
HV-S-1B		x	2,a
Motor Oper Vlv Units		x	3,a
Air conditioning water chillers			
HV-E-4A		x	1,a
HV-E-4B		x	1,a
HV-E-4C		x	1,a
Cable - 5 kV Al Power (General Cable)			
NGA-3 - Triplex 1000 MCM	-		4,a
NGA-4 - 3/C 500 Al Armor	x		4,a
NGA-5 - 3/C 1250 MCM st. Armor	-		4,a
NGA-6 - 3/C 1250 MCM Al Armor	-		4,a
NGA-9 - 1/C 1500 MCM	-		4,a
NGA-10 - 1/C 2000 MCM	-		4,a
NGA-12 - 3/C 1000 MCM Al Armor	-		4,a
NGA-13 - 3/C #4/0 Awg.	-		4,a
NGA-14 - Triplex #4/0 Awg.	-		4,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
Cable - 600 V Al Power (General Cable)			
NGB-5 - Triplex 500 MCM	X		5,a
NGB-7 - Triplex 250 MCM	X		5,a
NGB-11 - Triplex #2/0 Awg.	X		5,a
NGB-12 - Triplex #1 Awg.	X		5,a
Cable - 600 V - Cu Power (Okonite)			
NGA-20 - 1/C 250 MCM	X	X	6,a
NGA-21 - 1/C #2/0 Awg.	X	X	6,a
NGB-15 - Triplex #4 Awg.	X	X	6,a
NGB-16 - Triplex #6 Awg.	X	X	6,a
NGB-17 - 3/C #8 Awg.	X	X	6,a
NGB-18 - 3/C #10 Awg.	X	X	6,a
NGB-19 - 3/C #12 Awg.	X	X	6,a
Cable - High Temperature Cu (Cerro Wire)			
NGA-15 - Triplex 250 MCM	X	X	7,a
NGA-17 - Triplex #2/0 Awg.	-	-	7,a
NGA-33 - 6/C (2) #8 & (4) #12 Awg.	-	-	7,a
NGA-61 - 7/C #12 Awg.	-	-	7,a
NGA-34 - 4/C #16 Awg.	-	-	7,a
NGB-37 - 2/C #8 Awg.	-	-	7,a
Cable - 600 V Cu Control (Cerro Wire)			
NGA-19 - 2/C #2 Awg.	X	X	8,a
NGA-34 - 1/C #14 Awg.	X	X	8,a
NGA-35 - 2/C #14 Awg.	X	X	8,a
NGA-36 - 3/C #14 Awg.	X	X	8,a
NGA-37 - 5/C #14 Awg.	X	X	8,a
NGA-38 - 7/C #14 Awg.	X	X	8,a
NGA-39 - 9/C #14 Awg.	X	X	8,a
NGA-40 - 12/C #14 Awg.	X	X	8,a
NGA-44 - 1/C #12 Awg.	X	X	8,a
NGA-45 - 2/C #12 Awg.	X	X	8,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
NGA-47 - 4/C #12 Awg.	x	x	8,a
NGA-49 - 7/C #12 Awg.	x	x	8,a
NGA-57 - 4/C #10 Awg.	x	x	8,a
NGA-77 - 4/C #10 Awg.	x	x	8,a
NGB-43 - 2/C #8 Awg.	x	x	8,a
NGB-44 - 2/C #6 Awg.	x	x	8,a
NGB-45 - 4/C #6 Awg.	x	x	8,a
Cable - 300 V Cu Instrument (BIW)			
NGA-67 - 19/C #16 Awg.	x	x	9,a
NGA-68 - 12/C #16 Awg.	x	x	9,a
NGA-69 - 2/C #16 Awg.	x	x	9,a
NGA-70 - 18/C #16 Awg.	x	x	9,a
NGB-35 - 2/C #16 Awg.	x	x	9,a
NGB-39 - 3/C #16 Awg.	x	x	9,a
NGB-40 - 4/C #16 Awg.	x	x	9,a
NGB-55 - 45/C #16 Awg.	x	x	9,a
Cable - Thermocouple Extension Wire (Cerro Wire)			
NGB-68 - 1 pair #16 Cu-Const	x	x	10,a
NGB-69 - 1 pair #16 Ir-Const	x		10,a
Cable - 5KV Al Power (Okonite)			
NGA-3 - Triplex 1000 MCM	-		11,a
NGA-4 - 3/C 500 MCM	x		11,a
NGA-14 - Triplex 4/0	-		11,a
NGA-13 - 3/C #4/0 Awg.	-		11,a
Cable - 600 V Al Power (Okonite)			
NGB-5 - Triplex 500 MCM	x		12,a
NGB-7 - Triplex 250 MCM	x		12,a
NGF-11 - Triplex #2/0 Awg.	x		12,a
NGB-12 - Triplex #1 Awg.	x		12,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
Cable - 300 V Cu Instrument (Cerro)			
NGA-67 - 19/C #16 Awg.	x	x	13,a
NGA-68 - 12/C #16 Awg.	x	x	13,a
NGA-70 - 18/C #16 Awg.	x	x	13,a
NGB-35 - 2/C #16 Awg.	x	x	13,a
NGB-39 - 3/C #16 Awg.	x	x	13,a
Cable-Thermocouple (BIW)			
NGB-68 - 1 pair #16 Awg. Cu-Const	x	x	14,a
Cable - Triaxial (BIW)			
NGA-72 - Triax	x		15,a
Cable - 600 V Cu Power Cable - Heat Tracing (Okonite)			
NGB-01 - 2/C #10 Awg.	x		16,a
Chiller Room Sump Pump Motors			
DB-P-10A		x	17 b,c
Fan Motors and Motor-Operated Valve			
HV-F-40A, 40B	x	-	18,a
HV-F-71A, 71B	x	-	18,b,c
HV-F-24	-	x	2 b,c,
MOV-HV-115-1,2	-	x	17,a
MOV-HV-116-1,2	-	x	17,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
<b>Level Transmitter</b>			
LT-RS-151A, B	X		20,a
LT-RS-251A, B	X		20,a
<b>Motor Control Centers</b>			
1-EP-MC-19 (1H1-2N)	X		22,a
1-EP-MC-20 (1H1-2S)	X		22,a
1-EP-MC-21 (1J1-2N)	X		22,a
1-EP-MC-22 (1J1-2S)	X		22,a
2-EP-MC-19 (2H1-2N)	X		22,a
2-EP-MC-20 (2H1-2S)	X		22,a
2-EP-MC-21 (2J1-2N)	X		22,a
2-EP-MC-22 (2J1-2S)	X		22,a
<b>Motor Operated Valves</b>			
MOV-QS-101A, B, C, D	X		23 b,c
MOV-RS-155A, B	X		23 b,c
MOV-156A, B	X		23 b,c
MOV-SW-103A, B, C, D	X		23,a
MOV-SW-104A, B, C, D	X		23,a
MOV-SW-108A, B	X		23,a
MOV-SW-113A, B	X		23,a
MOV-QS-201A, B, C, D	X		23,a
MOV-RS-255A, B	X		23.b,c
MOV-RS-256A, B	X		23.b,c
MOV-SW-203A, B, C, D	X		23,a
MOV-SW-204A, B, C, D	X		23,a
MOV-SW-208A, B	X		23,a
MOV-SW-213A, B	X		23,a
<b>Penetrations</b>			
Type IA-Instrument	X	X	24,a,25,a
Type IB-Control	X	X	24,a,25,a
Type IC, IIA, IIB, IIC, IID, IIE-Low Voltage Power	X	X	24,a,25,a
Type III-Triaxial	X	-	24,a
Type IV-Thermocouple	X	-	24,a
Penetration Splices	X	X	26,a,27,a
Terminal Blocks (Polysulfone)	X	X	19,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
Recirculation Spray Pump Motors (Inside)			
RS-P-1A	x	x	28,a,29,a
RS-P-1B	x	x	28,a,29,a
Recirculation Spray Pump Motors (Outside)			
RS-P-2A	x		23,d,e
RS-P-2B	x		23,d,e
Solenoid Operated Valves			
ASCO #HT8344 A71		x	36,a
ASCO #HT8321A5	x		30,a
ASCO #HT830281U	x	x	35,a,37,a
ASCO #THT8320A102	x	x	40,a
ASCO #FT83201A101	x	x	38,a
ASCO #HT8349A11	x	x	36,a
Limit Switches For Use On:			
MODEL # EA-180	x		21,a
Switchgear - 480 V			
1-EE-SS-03	x		31,a
1-EE-SS-04	x		31,a
2-EE-SS-03	x		31,a
2-EE-SS-04	x		31,a
Switchgear Transformers - 480 V			
1-EE-ST-01	x		31,a
1-EE-ST-02	x		31,a
2-EE-ST-01	x		31,a
2-EE-ST-02	x		31,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
Terminal Blocks			
Connectron Type:			
NSE-3	x	x	32,a
NSS-3	x	x	32,a
PSU's	x	x	32,a
General Electric Type:			
EB5	x	x	32,a
EB25	x	x	32,a
Marathon Series:			
200	x	x	32,a
1500	x	x	32,a
Thermo-Electric			
3225's	x	x	32,a
Westinghouse Type			
TBAL	x	x	32,a
Terminating Material			
Okonite Tape - T-35	x	x	33,a
Okonite Tape - T-95	x	x	33,a
Raychem Heat Shrink			
WCSF-N	x	x	34,a
HVI	-		39,a
HVMC	-		39,a
Radiation Monitoring Pump Motor			
1-SW-P-5,6,7,8	-		41,a
2-SW-P-5,6,7,8	-		41,a



TABLE OF CONTENTS  
PART II  
QUALIFICATION  
NSSS  
INSIDE CONTAINMENT

DESCRIPTION	(LOCA)	OPERATING ENVIRONMENT		PAGE
		(MSLB)		
Steam Generator Flow Transmitters				
FT-1474, 2474	X	X		W-1,a
FT-1475, 2475	X	X		W-1,a
FT-1484, 2484	X	X		W-1,a
FT-1485, 2485	X	X		W-1,a
FT-1494, 2494	X	X		W-1,a
FT-1495, 2495	X	X		W-1,a
Pressurizer Level Transmitters				
LT-1459, 2459	X	X		W-2,a
LT-1460, 2460	X	X		W-2,a
LT-1461, 2461	X	X		W-2,a
Steam Generator Level Transmitters (Narrow Range)				
LT-1474, 2474	X	X		W-3,a
LT-1475, 2475	X	X		W-3,a
LT-1476, 2476	X	X		W-3,a
LT-1484, 2484	X	X		W-3,a
LT-1485, 2485	X	X		W-3,a
LT-1486, 2486	X	X		W-3,a
LT-1494, 2494	X	X		W-3,a
LT-1495, 2495	X	X		W-3,a
LT-1496, 2496	X	X		W-3,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
Limit Switches for Valves as denoted			
HCV-1200 A,B,C	X	X	W-4,a
HCV-2200 A,B,C	X	X	W-4,a
TV- 1842, 2842	X	X	W-4,a
Position Switch for Valves as denoted			
HCV-1201, 2201			W-5,a
Motor Operated Valves			
MOV-1380, 2380	X	X	W-6,a
Pressurizer Pressure Transmitters			
PT- 1455, 2455	X	X	W-7,a
PT- 1456, 2456	X	X	W-7,a
PT- 1457, 2457	X	X	W-7,a
RCS Pressure Transmitters (wide range)			
PT-1402, 2402	X	X	W-8,a
Solenoid Operators			
HCV-1200 A,B,C	X	X	W-9,a
HCV-2200 A,B,C	X	X	W-9,a
LCV-1460 A,B	X	X	W-10,a
LCV-2460 A,B	X	X	W-10,a
TV- 1842, 2842	X	X	W-10,a
HCV-1201, 2201	X	X	W-10,a

DESCRIPTION	(LOCA)	(MSLB)	PAGE
RCS Temperature Elements (Wide Range)			
TE-1410, 2410		x	W-11, a
TE-1413, 2413		x	W-11, a
TE-1420, 2420		x	W-11, a
TE-1423, 2423		x	W-11, a
TE-1430, 2430		x	W-11, a
TE-1433, 2433		x	W-11, a
RCS Temperature Elements (Narrow Range)			
TE-1412 B, D		x	W-12, a
TE-1422 B, D		x	W-12, a
TE-1432 B, D		x	W-12, a
TE-2412 B, D		x	W-12, a
TE-2422 B, D		x	W-12, a
TE-2432 B, D		x	W-12, a

#### GENERAL DEFINITIONS

1. Operability Requirements: Time and temperature conditions at which the equipment may be required to function, after the initial 60 minute transient period.
2. Operability Demonstrated: That testing done by the manufacturer for the stated time and temperature conditions, demonstrating the adequacy of the equipment to operate during post accident conditions. The adequacy was determined based on use of the "10 degree centigrade" rule when evaluating the test data.  
Pre-test thermal aging was not considered.

#### NOTES

1. Radiation dose is sum of 40 year dose plus 120 day LOCA.
2. Adequacy was determined based on use of the "10 degree centigrade" rule when evaluating the test data. Ref. IEEE Publication 117 and 275.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-247/1247  
Control & Relay Room A/C chillers  
Westinghouse:

1-HV-E-4A, B, C  
2-HV-E-4A, B, C

Model #PCO85W

Chiller room, Service building

DESCRIPTION OF ENVIRONMENT

MSLB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F for duration of steam discharge in vicinity of chiller room air intakes - 30 minutes.
2. High ambient moisture content saturated steam 100% RH for duration of steam discharge 30 minutes.

Normal Environment

70<sup>o</sup> to 104<sup>o</sup>F  
Motors & pumps will keep  
temperature above 70<sup>o</sup>F

Area has temperature monitors.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB  
None

Normal Environment

120<sup>o</sup>F

OPERABILITY REQUIREMENT

MSLB

30 minutes - 211<sup>o</sup>F & 100% RH

Normal Environment

104<sup>o</sup>F

OPERABILITY DEMONSTRATED

MSLB

None

Normal Environment

120<sup>o</sup>F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

MSLB

None

Normal Environment

Industrial Standard  
NEMA MG 1

QUALIFICATION DOCUMENT

None

None

Normal Environment

Specification NAS-314

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

MSLB

A. Deficiencies:

Equipment not qualified for exposure to:

- 1) High ambient temperature 211<sup>o</sup>F
- 2) Saturated atmosphere, 100% R.H.

B. Solutions:

There are three possible solutions as discussed below:

- a. Include the chiller room inside the control room pressure boundary and eliminate its communication with the turbine building. This involves determining if the compressed air system is adequate to maintain pressure with the chiller room included. Additional ducting must be added to provide cooling to the chiller room. Structural modifications to block openings to turbine building and modify door to be a pressure barrier.
- b. Replace unqualified equipment with qualified equipment.
- c. Use equipment in unaffected unit to maintain control room environment.

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

P. O. NA-276/1270  
In-line Pumps - Air Conditioning  
- Ringham-Williams Co. Company:

- 1-1W-P-20A, B, C
- 1-1W-P-22A, B, C
- 2-1W-P-20A, B, C
- 2-1W-P-22A, B, C
- Model 20's #773B51047
- 22's #773B51031

Motor with type "B" insulation.  
Chiller room, Service building

DESCRIPTION OF ENVIRONMENT

NOTE in Turbine bldg.

1. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes 30 minutes.
2. High ambient moisture content saturated steam 100% RH for duration of steam discharge 30 minutes.

Normal Environment

70° to 104°F  
Motor and pump will keep temperature above 70°F. Area has temperature monitors.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

NOTE

None

Normal Environment

104°F

OPERABILITY REQUIREMENTS

NOTE

30 minutes - 211°F & 100% RH

Normal Environment

104°F

OPERABILITY DEMONSTRATED

NOTE

None

Normal Environment

104°F

ACCURACY REQUIREMENTS

None

MANNER OF QUALIFICATION

MSLB

None

Normal Environment

Industrial Standard  
NEMA MG 1QUALIFICATION DOCUMENT

MSLB

None

Normal Environment

Specification NAS-315

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

MSLE

## A. Deficiencies:

Equipment not qualified for exposure to:

- 1) High ambient temperature 211<sup>o</sup>F
- 2) Saturated atmosphere, 100% R.H.

## B. Solutions:

There are three possible solutions as discussed below:

- a. Include the chiller room inside the control room pressure boundary and eliminate its communication with the turbine building. This involves determining if the compressed air system is adequate to maintain pressure with the chiller room included. Additional ducting must be added to provide cooling to the chiller room. Structural modifications to block openings to turbine building and modify door to be a pressure barrier.
- b. Replace unqualified equipment with qualified equipment.
- c. Use equipment in unaffected unit to maintain control room environment.

Normal Environment

None



EQUIPMENT DESCRIPTION & MARK NO.

Air Conditioning Self-Cleaning  
Strainers - Elliot Company:

P.O. NA 299/1299  
1-HV-S-1A & B  
2-HV-S-1A & B

Model #ECA

Chiller Rm. Service Bldg.

DESCRIPTION OF ENVIRONMENT

MSLB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F  
for duration of steam discharge in  
vicinity of chiller room air intakes.
2. High ambient moisture content  
saturated steam, 100% RH for  
duration of steam discha

Normal Environment  
70<sup>o</sup>F to 104<sup>o</sup>F  
Motors and pumps will keep  
temperature above 70<sup>o</sup>F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB in Turbine bldg.

None

Normal Environment

104<sup>o</sup>F

OPERABILITY REQUIREMENTS

MSLB in Turbine bldg.

30 minutes - 211<sup>o</sup>F & 100% RH

Normal Environment

70<sup>o</sup>F - 104<sup>o</sup>F

OPERABILITY DEMONSTRATED

MSLB in Turbine bldg.  
None

Normal Environment  
104<sup>o</sup>F

ACCURACY REQUIREMENT

Not required

MANNER OF QUALIFICATIONMSLB in Turbine bldg.

None

Normal EnvironmentIndustrial Standards  
ASME - VIII  
ASME - IXQUALIFICATION DOCUMENTMSLB in Turbine bldg.

None

Normal Environment

Specification #NAS-316

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONMSLB in Turbine bldg.A. Deficiencies:

1. High ambient temperature 211<sup>o</sup>F
2. Saturated atmosphere

B. Solutions:

There are three possible solutions as discussed below:

- a. Include the chiller room inside the control room pressure boundary and eliminate its communication with the turbine building. This involves determining if the compressed air system is adequate to maintain pressure with the chiller room included. Additional ducting must be added to provide cooling to the chiller room. Structural modifications to block openings to turbine building and modify door to be a pressure barrier.
- b. Replace unqualified equipment with qualified equipment.
- c. Use equipment in affected unit to maintain control room environment.

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

Propeller Fan - Aerovent Fan  
Company, Incorporated

P.O. NA 241/1241  
1-HV-F-24  
2-HV-F-24  
Model #7-216

Ins. Class F

Chiller rm, Service bldg.

DESCRIPTION OF ENVIRONMENT

MSLB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F  
for duration of steam discharge in  
vicinity of chiller room air intakes
2. High ambient moisture content  
saturated steam, 100% RH for  
duration of steam discharge.

Normal Environment

70<sup>o</sup>F to 104<sup>o</sup>F  
Motors and pumps will keep  
temperature above 70<sup>o</sup>F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F  
at saturated atmosphere

Normal Environment

120<sup>o</sup>F

OPERABILITY REQUIREMENTS

MSLB in Turbine bldg.

30 minutes - 211<sup>o</sup>F and 100% RH

Normal Environment

104<sup>o</sup>F

OPERABILITY DEMONSTRATED

MSLB in Turbine bldg.

30 minutes - 211<sup>o</sup>F & 100% RH

Normal Environment

120<sup>o</sup>F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

MSLE in Turbine bldg.

Vendor's reply to TLX inquiry

Normal Environment

Industrial Standards

ANSI B31.7  
ANSI B16.10  
ANSI B16.5QUALIFICATION DOCUMENTMSLE in Turbine bldg.  
TLX-3-29-79 - W.B. Schumacher  
to J.E. KrechtingNormal Environment

Specification #NAS 197A

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONMSLE

None

Normal Environment

None

BY APPOINTMENT DESCRIPTION & PART NO.

1. or Operated Valves - Fisher  
Governor Company - Continental  
Division - Field P.O. - Matkin 40514-  
A-2000, located in charcoal filter  
duct from chiller room.

DESCRIPTION OF ENVIRONMENT

No changing environment.

ENVIRONMENT TO WHICH EQUIPMENT IS QUALIFIED

MOV-8V-104-1 & 2  
MOV-8V-113-1 & 2  
MOV-8V-204-1 & 2  
MOV-8V-213-1 & 2

NOTE:

Upon further investigation it was  
found that the electrical components  
of the above valves are within the  
control room pressure boundary and  
therefore will see no changing environment  
due to an accident.

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

QUALIFICATION DOCUMENT

MANNER OF QUALIFICATION

EQUIPMENT DESCRIPTION & MARK NO.

P.O. MA-255/1255  
5 KV alum. power cable  
(General Cable)  
MGA-3 Triplex 1000 MCM  
MGA-4 3/c 500 MCM alum. armor  
MGA-6 3/c 1250 MCM alum. armor  
MGA-5 3/c 1250 MCM st. armor  
MGA-10 1/c 2000 MCM  
MGA-12 3/c 1000 MCM alum. armor  
MGA-13 3/c h/o AWG. alum armor  
MGA-14 Triplex h/o AWG.  
MGA-9 1/c 1000 MCM

Jacket: Neoprene  
Insulation: Ethylene Propylene Rubber  
Outside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
1 x 10<sup>6</sup> rads (based on 120 day  
LOCA). In addition the 40 year  
radiation dose of 4 x 10<sup>4</sup> rads  
must be considered for a total  
possible radiation dose of  
1.04 x 10<sup>6</sup> rads.

Normal Environment  
40 to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

2 x 10<sup>5</sup> rads

Normal Environment

40 to 120°F

OPERABILITY REQUIREMENTS

Loss of Coolant Accident (LOCA)

1.04 x 10<sup>6</sup> rads

Normal Environment

40 to 120°F

OPERABILITY DEMONSTRATED

Loss of Coolant Accident (LOCA)

2 x 10<sup>5</sup> rads

Normal Environment

Less than or equal to 10<sup>4</sup> rads

ACCEPTANCE REQUIREMENTS

Not Required

MANNER OF QUALIFICATIONLOCA

Test

Normal EnvironmentIndustrial Standard  
IPCEA S-19-81QUALIFICATION DOCUMENTLOCA

General Cable Letter dated 12-22-71

Normal Environment

Specification NAS-108

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

## A. Deficiencies:

Qualification Document is in letter form (i.e., no formal test report data with approved signature and date) and does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

## B. Solutions:

- 1) Accuracy of instrument even though not stated, would commonly be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Location of test facility, even though not noted could be obtained from Vendor Records.

The letter is a summary of the nuclear incident environment tests performed on similar constructed cables, which General Cable has stated are applicable.

Normal Environment

## A. Deficiencies:

Normal ambient temperature may exceed cables maximum continuous ambient temperature.

## B. Solution:

- a) Maximum temperature is of short duration.
- b) Cables that are used in CAT IE circuits are not carrying full derated current continuously. Their load is in the range of 50 to 75% of derated full load current with the exception of emergency diesel generator which doesn't operate continuously during plant life.



EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-256/1256  
500 V Alum. Power Cable  
(General Cable)

NGB-5	Triplex	500 MCM
NGB-7	Triplex	250 MCM
NGB-11	Triplex	2/0 AWG.
NGB-12	Triplex	#1 AWG.

Jacket: Neoprene  
Insulation: Ethylene Propylene Rubber

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F >60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig >60 min  
 $7.2 \times 10^7$  rads(1)  
Spray: 0-4 hrs. Solution of boric  
acid (2000-2100 ppm boron) buffered  
to a pH of 8.5 to 11 with NaOH. >4 hrs  
similar solution with a pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLoss of Coolant Accident (LOCA)

Irradiated to  $.55 \times 10^8$  rads  
100 psig @ 340°F for 4 hrs.  
52 psig @ 310°F for 1 hr.  
20 psig @ 260°F for 43 hrs.  
2.5 psig @ 260°F for 5 days

Spray: Throughout test cycle solution  
consisting of a 2000 ppm solution of  
boron as boric acid buffered with NaOH  
to a pH of 9.0  
Irradiated an additional  $1.45 \times 10^8$  rads  
bringing the total exposure to  $2 \times 10^8$   
rads.

OPERABILITY REQUIREMENTSLoss of Coolant Accident (LOCA)

120 day @ 150°F

OPERABILITY DEMONSTRATED (2)

LOCA  
163 hr @ 260°F

Post LOCA thermal aging is  
equivalent to 490 days @ 150°F

ACCURACY REQUIREMENTS

LOCA  
Not required

MANNER OF QUALIFICATION

LOCA

Test - Sequential

QUALIFICATION DOCUMENT

LOCA

General Cable Letter dated 12-22-71

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA

A. Deficiencies:

Qualification Document is in letter form (i.e., no formal test report with approved signature and date) does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instrument even though not stated, would commonly be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Location of test facility, even though not noted could be obtained from Vendor Records.

The letter is a summary of the nuclear incident environment tests performed on cables of a similar construction, which General Cable has stated are applicable.

EQUIPMENT DESCRIPTION & MARK, NO.

P.O. NA-128/1128  
600 V. Cu. Power Cable  
Okonite

NGA-20	1/c 250 MCM
NGA-21	1/c 2/0 AWG
NGB-15	Triplex #4 AWG
NGB-16	Triplex #6 AWG
NGB-17	3/c #8 AWG
NGB-18	3/c #10 AWG
NGB-19	3/c #12 AWG

Jacket: Neoprene  
Insulation: Ethylene Propylene Rubber

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hr Solution of boric acid  
(200-2100 ppm boron) buffered to a  
pH of 8.5 to 11 with NaOH > 4 hr  
Similar solution with a pH of  
7 to 9.

Main Steam Line Break (MSLB)

430°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLoss of Coolant Accident (LOCA)

Aged 168 hr @ 121°C  
Irradiated to 2 x 10<sup>8</sup> rads

PWR exposure:

80 psig @ 324°F For 4 hr  
16 psig @ 252°F For 7 days

Spray: 10,000 ppm boric acid buffered  
with NaOH to a pH of 10.5 throughout the  
PWR exposure period.

Boiling Water Reactor Exposure (BWR)

A series of transient cycles each con-  
sisting of a rise to a specified press  
and temp for a specified time and a  
gradual return to initial conditions.  
Following transient cycles 100 day  
exposure to live steam 0 psig, 212°F

BWR exposure includes a transient cycle  
at 104 psig at 345°F for 3 hr and 20 min.

MSLB

Same as "Description of Environment"

OPERABILITY REQUIREMENTSLOCA

120 days @ 150°F  
MSLB  
120 days @ 150°F

OPERABILITY DEMONSTRATED (2)LOCA

304°F - 3 hr 20 min  
346°F - 4 hr 27 min  
256°F - 1 day  
212°F - 100 days  
259°F - 10 hr  
324°F - 4 hr  
252°F - 7 days

Post LOCA thermal aging is greater than  
2.9 years @ 150°F

MSLB

See above

ACCURACY REQUIREMENTSLOCA & MSLB

Not required

MANNER OF QUALIFICATIONLOCA

Test - Sequential

MSLB

Test - Analysis

Maximum calculated surface temperature during limiting MSLB is 335°F which does not exceed qualification temperature of 345°F given in BWR exposure portion of LOCA qualification.

QUALIFICATION DOCUMENTLOCA

Okonite's Engineering Report  
No. 141 dated 2/29/72

Additional Supporting Documents

Outline of Franklin Institute  
Research Laboratory report F-C3694

IEEE Transaction Paper T 74 044 4

MSLB

FEAR Section 3C and response to  
Comment 7.17 (Note to be revised  
to include this item).

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

## A. Deficiencies:

Qualification document does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

## B. Solution:

- 1) Accuracy of instrument even though not stated would commonly be ±1%.
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Location of test facility even though not noted could be obtained from vendor's records. Additional supporting documents indicate that some tests were performed at Franklin Institute.

MSLB

Qualification based on independent test and analysis.  
Each of the qualification parameters (obtained from independent test and analysis) exceeds the corresponding MSLB requirements.

Amend FSAR as stated in "Qualification Document".

EQUIPMENT DESCRIPTION & MARK NO.

P.O. MA-359/1359  
High Temperature Cable  
Cerro Wire and Cable Company

\*NCA-15 Triplex 250 MCM  
NCA-17 Triplex #2/0 AWG  
NCA-33 6/c 2-#8 and 4-#12 AWG  
NCA-61 7/c #12 AWG  
NGB-34 4/c #16 AWG  
NGB-37 2/c #8 AWG

NCA 15, 17 & NGB 37  
Jacket: Asbestos Braid  
Insulation: Silicone Rubber

NCA 33, 61 & NGB 34  
Jacket: Silicone Rubber  
Insulation: Silicone Rubber

Inside Containment

\*NCA-15 is required for the inside  
recirc spray pumps. All other items  
are not required for post accident  
operation.

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hr Solution of boric acid  
(2000-2100 ppm boron) buffered to a  
pH of 8.5 to 11 with NaOH > 4 hr  
Similar solution with a pH of 7 to 9

MSLB

430°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig to  
0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIPMENT IS QUALIFIED

LOCA

Irradiated to 2 x 10<sup>8</sup> rads, 50 psig, and  
270°F for 12 hr

Spray: Last 2 hr of 12 hr period with a solution  
of boric acid containing approximately 1,750 ppm  
of boron as boric acid.

Reduced to 5 psig and 160°F over an unspecified  
time with spray continuing

160°F at 5 psig for the remainder of the 7 day  
period without spray

F-02750 indicates that in an earlier test, the  
spray was buffered with NaOH to pH of 9

MSLB

Same as "Description of Environment"

OPERABILITY REQUIREMENTS

LOCA

120 days @ 150°F

MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATED

LOCA

270°F for 12 hr  
160°F for 7 days

Post LOCA thermal aging is  
equivalent to 65 days @ 150°F.

MSLB

See above

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

LOCA

Test - Sequential

Main Steam Line Break (MSLB)

Temperature - Analysis

Maximum calculated surface temperature during limiting MSLE is 335°F which does not exceed qualification temperature of 460°F given in Rockbestos' (formerly Cerro) letter dated 4/25/77.

Pressure and Radiation - Test

Refer to LOCA Qualification

QUALIFICATION DOCUMENT

LOCA

Franklin Institute Research Laboratory (FIRL), Report F-C2857

Cerro's Supplement to FIRL, Report F-C2857

FIRL, Report F-C2750

Cerro's Supplement to FIRL, Report F-C2750

MSLB

FSAR Section 3C and response to Comment 7.17

Rockbestos' letter dated 4/25/77  
LOCA qualification documents

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONS

LOCA

A. Deficiencies:

Qualification documents do not address:

- 1) Accuracy of test data and variables
- 2) Test monitoring sensors
- 3) 276°F, 0 to 30 min vs 280°F
- 4) 1,750 ppm boron vs 2,000 ppm
- 5) Long-term post-accident operabilities not demonstrated

B. Solutions:

- 1) Accuracy of instrument, even though not stated, would commonly be ±1%.
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) The above 276°F through first 30 min is within tolerance of the LOCA temp transient profile - FSAR Fig. 6.2-82 (Amendment No. 65)
- 4) The cable jacket is of an asbestos braid which has been shown to be resistant to all diluted alkaline solutions. Therefore, we believe that since the LOCA spray is in the range of a diluted alkaline solution, it should have no significant effect on the cable.
- 5) The cable (NIA-15) insulation is rated for 125°C conductor temperature at rated ampacity, it can be shown by standard industry practices that the cable is capable of operating in a 150°F ambient continuously.

MSLB

Each of the qualification parameters (obtained from independent test and analysis) exceeds the corresponding MSLE requirements.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-312/13/2  
600 V Control Cable  
Cerro Wire and Cable Company

NGA-19	2/c #2 AWG
NGA-34	1/c #14 AWG
NGA-35	2/c #14 AWG
NGA-36	3/c #14 AWG
NGA-37	5/c #14 AWG
NGA-38	7/c #14 AWG
NGA-39	9/c #14 AWG
NGA-40	12/c #14 AWG
NGA-44	1/c #12 AWG
NGA-45	2/c #12 AWG
NGA-47	4/c #12 AWG
NGA-49	7/c #12 AWG
NGA-57	4/c #10 AWG
NGA-77	4/c #10 AWG
NCB-43	2/c #8 AWG
NCB-44	2/c #6 AWG
NCB-45	4/c #6 AWG

Jacket: Neoprene  
Insulation: Cross-linked Polyethylene

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F 0 to 30 min  
Reduce from 280°F 30 to 60 min  
to 150°F  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)  
Spray:  
0-4 hr Solution of boric acid  
(2,000-2100 ppm boron) buffered  
to a pH of 8.5 to 11 with NaOH  
> 4 hr similar solution with a  
pH of 7 to 9.

MSLB

430 F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from  
45 to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads 40 yr. dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Irradiated to 2 x 10<sup>8</sup> rads  
50 psig and 276°F for 12 hr  
Spray: Last 2 hr of 12 hr period with a  
solution of boric acid containing  
approximately 1,720 ppm of boron as boric  
acid.

Reduce to 5 psig and 164°F over an un-  
specified time with spray continued.

160°F at 5 psig for the remainder of the  
7 day period with no spray.

OPERABILITY REQUIREMENTSLOCA & MSLE

120 days @ 150°F

OPERABILITY DEMONSTRATED(?)LOCA

270°F for 12 hr  
160°F for 6 days

Post LOCA thermal aging is equivalent  
71 day @ 150°F

MSLE

242°F for 395 hr

Post MSLE thermal aging is equivalent to  
2 yrs. @ 150°F.

ACCURACY REQUIREMENTS

Not required

MSLE

Thermally aged for 1300 hr @ 150°C  
Irradiated at a rate 0.30 x 10<sup>8</sup> rads per  
hr for total dose of 2.01 x 10<sup>8</sup> rad.

Spray: Solution of 6200 ppm Boron and  
hydrazine solution maintained at a pH  
value of between 8.5 and 10.0 for 399 hr

376°F @ 58 psig	0 to 13 min
376°F @ 62 psig	13 to 15 min
366°F @ 62 psig	15 to 20 min
337°F @ 60 psig	20 to 25 min
Reduce from 337°F @ 60 psig to 242°F	25 min to 3.6 hr

MANNER OF QUALIFICATIONLOCA

Test - Sequential

MSLB

Test - Sequential

QUALIFICATION DOCUMENTLOCAFranklin Institute Research  
Laboratory Report F-C2857Cerro's Supplement to F.I.R.L.  
Report F-C2857MSLBRockbestos Company  
Report 13-10407-E)S8-13-2  
Test was performed on cable  
of a similar construction as  
that supplied in P.O. NA-312/1312FSAR Section 3C and response to  
Comment 7.17 (Note to be revised  
to include this item).QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) Accuracy of test data and variables
- 2) Test monitoring sensors
- 3) 1,720 ppm boron vs 2,000-2100 ppm
- 4) 276°F 0 to 30 min vs 280°F

B. Solutions:

- 1) Accuracy of instrument even though not stated would commonly be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) The cable jacket is of a neoprene material which was shown to be resistant to all diluted alkaline solutions. Therefore we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the cable.
- 4) The above 276°F through first 30 min is within tolerance of the LOCA temp. transient profile - FSAR Fig. 6.2-82 (Amendment#65)

MSLBA. Deficiencies:

- 1) Accuracy of test data and variables
- 2) Test Monitoring Sensors
- 3) Qualification temp. is below propose accident temp. 430°F for 2 min vs 376°F for 13 min

B. Solutions:

- 1) Accuracy of instrument even though not stated would be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Surface temp. will reach a maximum of 355°F after 2 min @ 430°F therefore we meet the temp. requirements.



EQUIPMENT DESCRIPTION & MAKE NO.

P.O. MA-265/1265  
300 V Instrument Cable  
(Boston Insulated Wire and Cable)

MA-07	19/c	No.	10	AMD
MA-08	12/c	No.	16	AMD
MA-09	2/c	No.	16	AMT
MA-70	13/c	No.	10	AMD
*MGB-35	2/c	No.	16	AMD
*MGB-39	3/c	No.	16	AMD
*MGB-40	2/c	No.	10	AMD
MGB-55	45/c	No.	16	AMD

Jacket: Neoprene

Insulation: Cross-linked Polyethylene

Inside and Outside Containment

\*Denote cables that are used inside containment on class 1E circuits.

DESCRIPTION OF ENVIRONMENT

LOCA

2300°F  
Reduce from 2300°F  
to 1500°F  
1500°F  
45 psig  
Reduce from 45  
to 0 psig  
0 psig  
7.2 x 10<sup>7</sup> rads (1)  
Spray: 0-4 hrs solution of boric acid  
(200-2100 ppm boron) buffered to a pH  
of 8.5 to 11 with NaOH's 4 hrs similar  
solution with a pH of 7 to 9

0 to 30 min

30 to 60 min

> 60 min

0 to 30 min

30 to 60 min

> 60 min

MSLB

1300°F  
2300°F  
1500°F  
45 psig  
Reduce from 45  
to 0 psig  
0 psig  
3 x 10<sup>7</sup> rads

0 to 2 min

2 to 60 min

> 60 min

0 to 30 min

30 to 60 min

> 60 min

3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Irradiated to 1 x 10<sup>8</sup> rads  
2300°F at 45 psig 60 min  
2050°F at 0 psig 24 hrs  
Spray: Throughout 25 hr period with a  
solution of 0.20 molar boron as boric acid  
with the pH adjusted to 8-8.5 with a 0.019  
molar solution of NaOH

MSLB

Same as "Description of Environment"

OPERABILITY REQUIREMENTS

LOCA

120 days @ 1500°F

MSLB

120 days @ 1500°F

OPERABILITY DEMONSTRATED (2)

LOCA

2500°F for 60 min  
2050°F for 24 hrs

Post LOCA thermal aging is not equivalent  
to operating requirements

MSLB

See above

ACCURACY REQUIREMENTS

See above

MANNER OF QUALIFICATIONLOCA

Test - Sequential

QUALIFICATION DOCUMENTLOCA

B.I.W. Letters dated  
1-17-72  
12-14-71

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

1. Accuracy of variables and test data
2. Test monitoring sensors
3. Test facility
4. 8-8.5 psi vs 8.5-11 psi
5. Time, temperature envelope not sufficient

B. Solutions:

1. Accuracy of instrument even though not stated would commonly be  $\pm 1\%$
2. Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
3. Location of test facility, even though not noted, can be obtained from Vendor records.
4. The cable jacket is of a neoprene material which was shown to be resistant to all diluted alkaline solutions. Therefore, we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the cable.
5. This instrument cable has the same jacket & insulation as the 600v Control Cable. P.). NA 312/1312 page 8A which surpassed operability requirements. We will get further test data.

MSLB

Temperature - Analysis  
Maximum calculated surface temperature during limiting MSLB is  $343^{\circ}\text{F}$  which does not exceed qualification temperature of  $460^{\circ}\text{F}$  given in B.I.W. letter dated 10-12-70.  
Pressure and Radiation - Test refer to LOCA qualification

MSLB

PSAR Section 3C and response to comment 7.17

B.I.W. letter dated 10-12-70  
LOCA Qualification documents

EQUIPMENT DESCRIPTION & MARK NO.

F.O. NA-252  
Thermocouple Extension Wire  
(Cerro Wire and Cable)

WGB-68 1 pair No. 16 Copper-  
Constantan

WGB-69 1 pair No. 16 Iron-  
Constantan

Jacket: Neoprene  
Insulation: Silicone Rubber

Inside and Outside Containment

## NOTE:

Under further investigation it was found that these cables are not used in the systems that are required to mitigate a Design Basis Accident.

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280<sup>o</sup>F 0 to 30 min  
Reduce from 280<sup>o</sup>F  
to 190<sup>o</sup>F 30 to 60 min  
45 psig > 60 min  
Reduce from 45 0 to 30 min  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hrs Solution of boric acid  
(2000-2100 ppm boron) buffered to a pH  
of 8.5 to 11 with NaOH > 4 hrs similar  
solution with a pH of 7 to 9

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

## LOCA

Irradiated to 2 x 10<sup>8</sup> rads  
50 psig at 276<sup>o</sup>F 12 hrs

Spray: Last 2 hrs of 12 hr period  
solution of borated water containing  
approximately 1720 ppm of boron as boric  
acid.  
Reduce to 5 psig and 164<sup>o</sup>F over an  
unspecified time with spray continued.  
160<sup>o</sup>F at 5 psig for the remainder of  
7 day period without spray. F-C2750  
indicates that in an earlier test the  
spray was buffered with NaOH to a pH of 9.

OPERABILITY REQUIREMENTS

Not required

OPERABILITY DEMONSTRATED

Not required

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Test- Sequential

QUALIFICATION DOCUMENTLOCAFranklin Institute Research  
Laboratory Report F-C2857

Cerro's Supplement to F.I.R.L.

Franklin Institute Research  
Laboratory Report F-C2750Cerro's Supplement to F.I.R.L.  
Report F-C2750QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

1. Accuracy of variables and test data
2. Test monitoring sensors
3. 276<sup>o</sup>F for 0 to 30 min is below environment of 290<sup>o</sup>F for 30 min
4. Test solution is 1750 ppm boron vs 2000-2100 ppm boron.

B. Solutions:

1. Accuracy of instrument even though not stated would commonly be ±1%.
2. Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
3. 276<sup>o</sup>F for first 30 min is within tolerance of the LOCA temperature transient profile - FSAR Fig. 6.2-82 (Amendment No. 65)
4. F-C2750 indicates that in an earlier test the spray was buffered with NaOH to a pH of 9. Furthermore, cable jacket is of a neoprene material which has been shown to be resistant to all diluted alkaline solutions. Therefore we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the cable.

EQUIPMENT DESCRIPTION & MAKE NO.

F.O. MA-315/1375  
5 % Alum. Power Cable  
(Okonite)

MA-4  
MA-14  
MA-5  
MA-13

3/c 500 MCM  
Triplex 4/0 AWG  
Triplex 1000 MCM  
3/c #4/0 AWG

Jacket: Neoprene  
Insulation: Cross-Linked Polyethylene  
Outside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

$7.2 \times 10^7$  rads (1)

Normal Environment

$40^\circ - 120^\circ\text{F}$   
Area has temperature monitors  
& class is redundant ventilation  
system.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

Loss of Coolant Accident (LOCA)

$2 \times 10^8$  rads

Normal Environment  
Ambient temperature less than  $104^\circ\text{F}$

OPERABILITY REQUIREMENT

Loss of Coolant Accident(LOCA)

$7.2 \times 10^7$  rads

Normal Environment

$104^\circ\text{F}$

OPERABILITY DEMONSTRATED

Loss of Coolant Accident (LOCA)

$2 \times 10^8$  rads

Normal Environment

$104^\circ\text{F}$

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Test

Normal EnvironmentIndustrial Standards, IPCEA  
S-19-81QUALIFICATION DOCUMENTLOCA

Okonite's Engineering Report

Additional Supporting DocumentsOutline of Franklin Institute  
Research Laboratory Report  
F-C3094

IEEE Transaction Paper T74 044 4

Normal Environment

Specification NAS-108

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Qualification document does not address:

- 1) Accuracy of variables and test data.
- 2) Test monitoring sensors, retention of records (i.e. traceability of instrumentation)
- 3) Test facility

B. Solutions:

- 1) Accuracy of test data and variables even though not addressed would commonly have been made with instruments having accuracies of 1%.
- 2) Test monitoring sensors, even though not addressed can be assumed to be of typical types.
- 3) Test facility could be determined from vendor records.

Normal EnvironmentA. Deficiencies:

Normal ambient temperature may exceed cable maximum continuous ambient temperature.

B. Solution:

- a) Maximum temperature is of short duration.
- b) Cable that are used in Cat 1B circuit are not carrying full rated current continuously. Their load is in the range of 50 to 75% of derated full load current with the exception of emergency diesel generator which is intermittent duty.

EQUIPMENT DESCRIPTION & MAKE NO.

P.O. MA-354/1354  
600 V Aluminum Power Cable  
Okonite  
NGB-5 Triplex 500 MCM  
NGB-7 Triplex 250 MCM  
NGB-11 Triplex #2/0 AWG.  
NGB-12 Triplex # 1 AWG.  
Jacket: Neoprene  
Insulation: Ethylene Propylene Rubber  
Inside and Outside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
280°F 0 to 30 min  
Reduce from 280°F to 150°F 30 to 60 min  
150°F > 60 min  
4.5 psig 0 to 30 min  
Reduce from 4.5 to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)  
Spray: 0-4 Solution of boric acid (2,000-2,100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH, > 4 hr Similar solution with a pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
Aged 168 hr at 121°C  
Irradiated to 2 x 10<sup>8</sup> rads

PR Exposure:

324°F at 80 psig 0 to 4 hr  
252°F at 16 psig for 7 days  
Spray: 0-4 hr Solution of boric acid with NaOH to a pH of 10.5 throughout the PR exposure period.

Boiling Water Reactor Exposure:

A series of transient cycles each consisting of a rise to a specified pressure and temperature for a specified time and a gradual return to initial condition. Following transient cycles 100 day exposure to live steam 0 psig @ 212°F.

OPERABILITY REQUIREMENTS

LOCA  
120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

LOCA  
304°F - 3 hr. 20 min  
340°F - 4 hr. 27 min  
256°F - 1 day  
212°F - 100 days  
259°F - 10 hr  
324°F - 4 hrs  
292°F - 7 days

Post LOCA thermal aging is greater than 2.9 years @ 150°F

ACCEPTANCE REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Test - Sequential

QUALIFICATION DOCUMENTLOCA

Okonite's Engineering Report  
No. 141 dated February 29, 1972

Additional supporting Documents

Outline of Franklin Institute  
Research Laboratory Report P-C3694

IEEE Transaction Paper T 74 044 4

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies

Qualification Document does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instrument even though not stated would commonly be 1%
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Test facility, even though not identified, could be determined from vendor's records. (Additional supporting document indicates that some tests were performed at Franklin Institute.)



EQUIPMENT DESCRIPTION & MARK NO.

F.O. NA-392/1332  
 300  $\gamma$  Instrument Cable  
 (Cerro Wire and Cable)  
 NMA-67 19/c No. 16 AWG  
 NMA-68 12/c No. 16 AWG  
 NMA-70 10/c No. 16 AWG  
 NMP-35 2/c No. 16 AWG  
 NMP-39 3/c No. 16 AWG

Jacket: Neoprene  
 Insulation: Flame Retardant Cross-  
 Linked Polyethylene

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENTLOCA

280°F 0 to 30 min  
 Reduce from 280°F to 150°F 30 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45 to 0 psig 30 to 60 min  
 0 psig > 60 min  
 7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hr solution of boric acid (2000-2500 ppm boron) buffered to pH of 8.5 to 11 with NaOH > 4 hr similar solution with a pH of 7 to 9

MSLB

430°F 0 to 30 min  
 280°F 2 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45 to 0 psig 30 to 60 min  
 0 psig > 60 min

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Aged 1300 hr @ 150°C  
 Irradiated to 2 x 10<sup>6</sup> rads

280°F @ 70 psig	0 to 10 sec
Rise to 346°F @ 113 psig	10 sec to 5 min
Reduce to 140°F	5 min to 3 hr
280°F @ 70 psig	5 hr to 5 hr & 10 sec
Rise to 346°F	5 hr + 10 sec to 5 hr + 5 min
346°F @ 113 psig	5 hr & 5 min to 8 hr
339°F @ 93 psig	8 hr to 11 hr
315°F @ 69 psig	11 hr to 15 hr
256°F @ 26 psig	15 hr to 4 days
212°F @ 0 psig	4 days to 30 days

Spray:  
 1st 24 hr of 30 day period - solution of the following

composition:

0.25 molar H<sub>2</sub>SO<sub>4</sub>

0.004 molar Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub>

NaOH to make pH between 9-11

Following above 30 day LOCA period, an additional period of 100 days at 200°F.

MSLB

Same as "Description of Environment"

OPERABILITY REQUIREMENTSLOCA

150°F for 120 days

MSLB

140°F for 120 days

OPERABILITY DEMONSTRATED (2)LOCA

212°F for 30 days

Post LOCA thermal aging is equivalent to 320 days @ 150°F.

MSLB

See above

ACCOMPLISHMENT REQUIREMENTSMSLB

Not required

MANNER OF QUALIFICATIONLOCA

Test - Sequential

MSLB

Temperature Analysis  
Maximum calculated surface  
temperature during limiting  
MSLB is 343° which does not  
exceed qualification tem-  
perature of 460° given in  
Rockbestos (formerly Cerro)  
letter dated 4-25-77  
Pressure and Radiation - Test  
Refer to LOCA Qualification

QUALIFICATION DOCUMENTLOCA

Rockbestos (formerly Cerro)  
Letter dated 2-21-79 and its  
attached report

MSLB

FSAR Section 3C and response  
to comment 7.17  
Rockbestos letter dated  
4-25-77  
LOCA qualification document

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Qualification document does not address:

1. Accuracy of variables and test data
2. Test monitoring sensors retention of records (traceability of instrumentation)
3. Test facility

NOTE: Dosimeters are addressed

B. Solution

1. Accuracy of instrument even though not stated would commonly be ±1%.
2. Test monitoring sensors, even though not identified, are assumed to comply with industrial Standards for their type of application
3. Test facility could be determined from Vendor's records

MSLB

Qualification based on independent test and analysis.  
Each of the qualification parameters (obtained from independent test and analysis) exceeds the corresponding MSLB requirements

EQUIPMENT DESCRIPTION & PART NO.

P O NA 402/1408  
Thermocouple Extension Wire  
Section Insulated Wire & Cable

WSP-08 1 pair #16 Copper-  
Constantan

Jacket: Neoprene  
Insulation: Cross-linked Polyethylene

Inside Containment

NOTE:

Under further investigation it was  
found that this cable is not used  
in systems that are required to  
mitigate a Design Basis Accident.

DESCRIPTION OF ENVIRONMENT

LOCA  
2800g  
Reduce from 2800g  
to 1500g  
1500g  
Reduce from 4g  
to 0 psig  
0 psig  
7.2 x 10<sup>7</sup> rads(1)  
0 to 30 min  
30 to 60 min  
>60 min  
30 to 60 min  
>60 min

Spray: 0-4 hrs solution of boric acid  
(2000-2100 ppm boron) buffered to  
a pH of 8.5 to 11 with NaOH > 4 hr  
Similar solution with a pH of 7  
to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Irradiated to 1 x 10<sup>8</sup> rads  
2800g at 4g psig 60 min  
209g at 0 psig 24 hrs  
Solution of 0.20 molar boron as boric  
acid with the pH adjusted to 8-8.5 with  
a 0.01g molar solution of NaOH for 25  
hr period.

OPERABILITY REQUIREMENTS

LOCA  
None

OPERABILITY CONSTRAINTS

LOCA  
Not required

ACCUMULY REQUIREMENTS

LOCA  
Not required

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA

A. Deficiencies:

Qualification document does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors retention of records (i.e., traceability of instrumentation)
- 3) Test facility
- 4) 0.2 molar boron solution vs 2000-2100 ppm boron.

B. Solutions:

- 1) Accuracy of test data and variables, even though not addressed, would commonly have been made with instruments having accuracy of 1%.
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Test facility could be determined from vendor records.
- 4) The cable jacket is of a neoprene material which was shown to be resistant to all diluted alkaline solutions. Therefore we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the cable.

QUALIFICATION DOCUMENT

LOCA

E.I.W. letters dated:  
2-7-75  
1-17-72  
12-14-71

MANNER OF QUALIFICATION

LOCA

Test - Sequential

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-422/1422  
Triaxial Cable  
(Boston Insulated Wire & Cable)

NGA-72 Triax

Jacket: Hypalon  
Insulation: Cross-linked Polyethylene

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280<sup>o</sup>F                    0 to 30 min  
Reduce from 280<sup>o</sup>F  
to 150<sup>o</sup>F                30 to 60 min  
150<sup>o</sup>F                    >60 min  
45 psig                   0 to 30 min  
Reduce from 45 to  
0 psig                    30 to 60 min  
0 psig                    >60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hr. Solution of boric acid (2,000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH. > 4 hr Similar solution with a pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Irradiated to 2 x 10<sup>8</sup> rads  
300<sup>o</sup>F @ 60 psig            0 to 15 min  
Reduce to 252<sup>o</sup>F  
@ 15 psig                    15 to 45 min  
252<sup>o</sup>F @ 15 psig            45 min to 13 day

Spray: Throughout 13 day period. A solution of 2,000 ppm boric acid buffered to a pH of 8 to 8.5 with NaOH.

Following above, an additional 17 days exposure to 200<sup>o</sup>F @ 0 psig.

OPERABILITY REQUIREMENTS

Loss of Coolant Accident (LOCA)  
120 days @ 150<sup>o</sup>F

OPERABILITY DEMONSTRATED(2)

Loss of Coolant Accident (LOCA)  
13 days @ 252<sup>o</sup>F  
17 days @ 200<sup>o</sup>F

Post LOCA thermal aging is equivalent to 2.1 years @ 150<sup>o</sup>F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Sequential

QUALIFICATION DOCUMENTLOCA

E.I.W.'s Engineering Comments  
 No. 26665-EP Rev. 4  
 (specifically Test No. 75C008)

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

## A. Deficiencies

Qualification document does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility
- 4) 275°F at 30 min mark vs 280°F
- 5) 35 psig at 30 min mark vs 45 psig
- 6) pH of 8 to 8.5 vs pH of 8.5 to 11

## B. Solutions

- 1) Accuracy of instrument even though not stated would commonly be 1%.  
 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Test facility, even though not identified, could be determined Vendor's records.
- 4) 275°F at 30 min mark is within tolerance of the LOCA temperature transient profile FSAR Fig. 6.2-82 (Amendment No. 65).
- 5) 35 psig at 30 min mark is within tolerance of the LOCA pressure transient profile FSAR Fig. 6.2-63 (Amendment No. 65).
- 6) The cable jacket is of a hypalon material which was shown to be resistant to all diluted alkaline solutions. Therefore, we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the cable.

EQUIPMENT DESCRIPTION & MAKE NO.

P.O. No-404/1404  
600 V. Cu. Power Cable-Heat Treating  
(Okonite)

MCP-01 2/c #10 AWG

Jacket: Elyalon

Insulation: Cross-linked Polyethylene

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
250°F 0 to 30 min  
Reduce from 250°F 30 to 60 min  
to 150°F > 60 min  
150°F 0 to 30 min  
45 psig Reduce from 45  
to 0 psig > 60 min  
0 psig 30 to 60 min  
7.2 x 10<sup>7</sup> rads(1)  
Spray: 0-4 hr solution of boric  
acid (2,000-2100 ppm boron)  
buffered to a pH of 8.5 to 11 with  
KOH. > 4 hr Similar solution with a  
pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Aged 14 days at 250°F  
Irradiated to .5 x 10<sup>8</sup> rads and aged at  
240°F for 7 days  
For 31 day period  
250°F/70 psig 0 to 10 sec  
Rise to 340°F/  
113 psig 10 sec to 5 min  
340°F/113 psig 5 min to 3 hr  
Reduce to 140°F 3 hr to 5 hr  
280°F/70 psig 5 hr to 5 hr  
and 10 sec  
Rise to 340°F/  
113 psig 5 hr and 10 sec to  
340°F/113 psig 5 hr and 5 min  
to 8 hr  
335°F/95 psig 8 hr to 11 hr  
315°F/69 psig 11 hr to 15 hr  
265°F/28 psig 15 hr to 4 day  
212°F/0 psig 4 day to 31 day

Spray: Continuously for 31 day period solution of  
2,000 ppm boron as boric acid buffered with NaOH  
to a pH to 9-11. Irradiated to 1.5 x 10<sup>8</sup> rads  
during the 31 day period. Total 2 x 10<sup>8</sup> rads.

OPERABILITY REQUIREMENTS

Loss of Coolant Accident(LOCA)  
120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

Loss of Coolant Accident (LOCA)  
27 days @ 212°F  
Post LOCA thermal aging is equivalent  
to 291 days @ 150°F

MANNER OF QUALIFICATION

LOCA

Sequential

QUALIFICATION DOCUMENT

LOCA

Franklin Institute Research Laboratory  
Report F-C96-94

Additional Supporting Data

IEEE Transaction, Paper T 74 044 04

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA

A. Deficiency:

Qualification document does not address:

1) Accuracy of test data and variables

B. Solution:

1) Accuracy of test data and variables,  
even though not addressed, would commonly  
have been made with instruments having  
accuracies of  $\pm 1\%$



EQUIPMENT DESCRIPTION & MARK NO.

P.O. No-299/1209

Motor Operated Valves - Elliot Company:

- 1-MOV-HV-115-1,2
- 1-MOV-HV-116-1,2
- 2-MOV-HV-115-1,2
- 2-MOV-HV-116-1,2

Model #MAB-25

Chiller Room, Service Building

DESCRIPTION OF ENVIRONMENT

MSLB in Turbine Building

1. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes - 30 min
2. High ambient moisture content saturated steam, 100% RH for duration of steam discharge 30 min

Normal Environment

70° to 104°F  
Motors and pumps will keep temperature above 70°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB in Turbine Building

None

Normal Environment

104°F

OPERABILITY REQUIREMENTS

MSLB in Turbine Building

30 min - 211°F and 100% RH

Normal Environment

104°F

OPERABILITY DEMONSTRATED

MSLB in Turbine Building

None

Normal Environment

None

ACTUAL REQUIREMENTS

Not required

MANNER OF QUALIFICATIONMain Steam Line Break (MSLB) in Turbine Building

None

Normal Environment

None

QUALIFICATION DOCUMENTMSLB in Turbine Building

None

Normal Environment

Specification NAS-316

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSMSLB in Turbine BuildingA. Deficiencies:

- 1) High ambient temperature 211°F
- 2) Saturated atmosphere

B. Solution:

Substitute EPT liner to withstand 310°F

There are three possible solutions as discussed below:

- a. Include the chiller room inside the control room pressure boundary and eliminate its communication with the turbine building. This involves determining if the compressed air system is adequate to maintain pressure with the chiller room included. Additional ducting must be added to provide cooling to the chiller room. Structural modifications to block openings to turbine building and modify door to be a pressure barrier.
- b. Replace unqualified equipment with qualified equipment.
- c. Use equipment in unaffected unit to maintain control room environment.

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-421/1421  
 Chiller Room Sump Pumps -  
 Johnston Pump Company:  
 1-DB-P-10A  
 2-DB-P-10A

Model # Type 8G2V

Chiller rm, Service bldg.

DESCRIPTION OF ENVIRONMENT

MSELB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F for duration of steam discharge in vicinity of chiller room air intakes 30 minutes.
2. High ambient moisture content - saturated steam, 100% RH for duration of steam discharge 30 minutes.

Normal Environment

70<sup>o</sup> to 104<sup>o</sup>F  
 Motors and pumps will keep temperature above 70<sup>o</sup>F.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSELB in Turbine bldg.

1. High ambient temperature 211<sup>o</sup>F at saturated atmosphere

Normal Environment

104<sup>o</sup>F

OPERABILITY REQUIREMENTS

MSELB in Turbine Building

30 minutes - 211<sup>o</sup>F & 100% RH

Normal Environment

104<sup>o</sup>F

OPERABILITY DEMONSTRATED

MSELB in Turbine Building

None

Normal Environment

104<sup>o</sup>F

ACCURACY REQUIREMENTS

None

MANNER OF QUALIFICATION

MSLB in Turbine bldg.

Vendor reply to TLX inquiry

Normal EnvironmentIndustrial Standards

IEEE 112A

ANSI B3. 15

ANSI B3. 16

ASME PTC 8.2

NEMA MG1

QUALIFICATION DOCUMENT

MSLB in Turbine bldg.

TLX 3-28-79 - John Anderson  
to J.E. KrechtingNormal Environment

Specification NAS-427

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSMSLB in Turbine bldg.A. Deficiencies

1. High ambient temperature 211°F
2. Saturated atmosphere

B. Solutions:

Substitute EPT liner to withstand 310°F

There are three possible solutions  
as discussed below:

- a. Include the chiller room inside the control room pressure boundary and eliminate its communication with the turbine building. This involves determining if the compressed air system is adequate to maintain pressure with the chiller room included. Additional ducting must be added to provide cooling to the chiller room. Structural modifications to block openings to turbine building and modify openings to turbine building and modify door to be a pressure barrier.
- b. Replace unqualified equipment with qualified equipment.
- c. Use equipment in unaffected unit to maintain control room environment.

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-296/1296  
 Centrifugal Fans - Buffalo  
 Forge Co.  
 1-HV-F-4QA, B  
 2-HV-F-4QA, B

Model 680B101057  
 Auxiliary bldg.

DESCRIPTION OF ENVIRONMENTLOCA

1. Radiation zone IV 40 yr dose +  
 LOCA dose = 800 + 100 = 1040 rads

Normal Environment

50°F to 120°F  
 area has temperature monitors

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Radiation dose of  $7 \times 10^4$  rads

Normal Environment  
 50° to 120°F

OPERABILITY REQUIREMENTSLOCA

$1.04 \times 10^3$  rads

Normal Environment

50°F to 120°F

OPERABILITY DEMONSTRATEDLOCA

$7 \times 10^4$  rads

Normal Environment

50° to 120°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

LOCA

Vendor's reply to TLX inquiry

Normal Environment

Industrial Standard

REMA M1

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA

None

Normal Environment

None

QUALIFICATION DOCUMENT

LOCA

TLX-3-29-79 W.P. Shumacher  
J.E. Krechting

Normal Environment

Specification #RAS-308

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA 201/1201  
 1-HV-F-71A, B  
 2-HV-F-71A, B  
 Axial Flow Fans- Joy Mfg. Co.

Model#600263-5533  
 Safeguards bldg.

DESCRIPTION OF ENVIRONMENTLOCA

1. Radiation 40 yr dose -  $1 \times 10^6$  rads

Normal Environment

70°F to 120°F  
 area has temperature monitors

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

None

Normal Environment

120°F

OPERABILITY REQUIREMENTSLOCA

$1 \times 10^6$  rads

Normal Environment

70°F to 120°F

OPERABILITY DEMONSTRATIONLOCA

None

Normal Environment

70 F to 120°F

ACCURACY REQUIREMENTS

Not Required

MANNER OF QUALIFICATIONLOCA

None

Normal EnvironmentIndustrial Standard

NEMA MG1

QUALIFICATION DOCUMENTLOCA

None

Normal EnvironmentSpecification #NAS-218QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCADeficiencies

Equipment not qualified for exposure to:

1. Radiation -  $1 \times 10^6$  rads

Solutions:

Replace drivers with qualified motors

Replace motors have been purchased  
capable of withstanding the radiation dose  
of  $1 \times 10^6$  rads.

Normal Environment

None



EQUIPMENT DESCRIPTION & MAKE NO.

P.O. No 313/1313  
 Reactor Containment Electrical  
 Penetration - CONMAX  
 Polysulfone Terminal Blocks  
 Connection Inc.  
 Model N553 polysulfone

Inside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F @ 0 to 30 min  
 Reduce from 280°F  
 to 150°F 30 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45  
 to 0 psig 30 to 60 min  
 4.2 x 10<sup>7</sup> rads (1)

Spray = 0 to 4 hours solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH. Beyond 4 hours similar solution with a P to 9.

Main Steam Line Break (MSLB)

430°F 0 to 2 min  
 280°F 2 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45  
 to 0 psig 30 to 60 min  
 0 psig > 60 min  
 3 x 10<sup>7</sup> rads 40 yr dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Radiation: 2.5 x 10<sup>7</sup> rads minimum

253°F @ 25 psig	0 to 30 sec
232°F @ 45 psig	30 to 60 sec
295°F @ 45 psig	60 to 90 sec
298°F @ 37.5 psig	90 to 120 sec
282°F @ 48 psig	2.5 to 4 min
289°F @ 49 psig	4 to 5 min
300°F @ 56 psig	5 to 10 min
293°F @ 47 psig	10 to 15 min
297°F @ 47 psig	15 to 30 min

Range

Thermal aging 300°F for 74 hr

Spray:

Solution boron 1,900 ppm  
 Buffered to 7.7 pH at a  
 + 190°F, 10 gpm for 30 min.  
 140°F @ psig for 240 hr

OPERABILITY REQUIREMENTS

LOCA  
 120 days 150°F

MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)LOCA & MSLB

L.V.P./C/I

2550F - 190 hr

Post LOCA thermal aging is equivalent to 429 days @ 150°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

Test

QUALIFICATION DOCUMENT

Conax Corp. Test  
Report IPS-107

Conax letter "Qualification of  
Electric Penetrations"  
No. IPS-411, P/N 7280-10001-01,  
IPS-369, IPS-325 dated 1/5/80

Letters from Union Carbide,  
Belgium, N. J., dated 12/19/67,  
New Jersey, dated 1/22/68

Test

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

Qualification document does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors, retention of records (i.e. traceability of instrumentation)
- 3) Test facility
- 4) Test solution - 1,900 ppm boron vs 2,000-2100

Solutions

- 1) Accuracy of test data and variables even though not addressed would commonly have been made with instruments having accuracies of  $\pm 1\%$ .
- 2) Test monitoring sensors, even though not addressed can be assumed to be of typical types
- 3) Test facility could be determined from vendor records.
- 4) The terminal block is of a polysulfone material which has been shown to be resistant to all diluted alkaline solutions. Therefore, we believe that since the LOCA spray is in the range of a diluted alkaline solution, it should have no significant effect on the terminal blocks.

EQUIPMENT DESCRIPTION & MARK NO.

Specification NAS-90-22  
P.O. No. NA-333/1333

Level transmitters  
Gema #XM-29400  
LT-RS151A, B  
LT-RS251A, B

Gema Sensor Division  
Delaval Turbine

Inside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray - 0 to 4 hours solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH. Beyond 4 hours similar solution with a 7 to 9.

Main Steam Line Break (MSLB)

430°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads 40 yr dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
282±1°F 0 to 60 min  
280-150°F > 60 to 180 min  
150°F 180 min to 14 days  
45 psig 0 to 60 min  
45 0 psig > 60 to 150 min  
13.5 psig 150 min to 14 days

Radiation Exposure 2 x 10<sup>8</sup> rads

Spray - 15,000 ppm boric acid buffered to a pH of 10.5 with NaOH solution for 4 hours.  
Spray density = 0.15 gpm per ft<sup>2</sup>.

MSLB

As above

OPERABILITY REQUIREMENTSLOCA & MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATEDLOCA & MSLB

After test, transmitter functioned properly. Manufacturer's normal environment is rated to 300°F.

ACCURACY REQUIREMENTSLOCA & MSLB

± 5% of range

ACCURACY DEMONSTRATEDLOCA & MSLB

1.2% after test

MANNER OF QUALIFICATIONLOCA & MSLE

Test - Sequential  
Radiation and Environmental  
Exposure. Spray Exposure  
performed on a separate  
instrument.

QUALIFICATION DOCUMENTLOCA & MSLE

Franklin Institute  
Research Laboratories  
(FIRL) Report F-C3834  
Isomedix Inc. Test  
Report dated Nov. 1975.

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

None

MSLEA. Deficiencies:

Test Temperature of 282°F is below  
accident temperature of 430°F

B. Solution:

As measured by thermocouple on  
circuit board, internal components  
reached qualification temperature  
282°F only after 27 minute exposure  
to 450°F. Actual req'd exposure at  
450°F is 2 minutes, therefore,  
qualification is satisfactory.

EQUIPMENT DESCRIPTION & MARK NO.

NAMCO Model EA - 180  
Limit Switches  
Located on the following  
Control Valves

TV-BD 100B, D, F	Steam gen blowdown
TV-CC 101B	R.C.P. Therm barrier
TV-CC 102B, D, F	R.C.P. Return header
TV-CC 105A, B, C	Cont. Recirc Air Coils
TV-DA 100B	React cont sump pp disch
TV-DG 100B	Pri Drn. xfer pp disch
TV-RM 100C	Limit sw on tv ra 100C
TV-VG 100B	Pri drn xfer tk vent
TV-SS 100A	Pressure liquid space
TV-SS 101A	Pressure vapor space
TV-SS 102A	Primary coolant cold leg
TV-SS 104A	Press. relief tank gas sp
TV-SS 106A	Primary coolant hot leg
TV-SS 112A	St gen surface sample
TV-BD 200B, D, F	Steam gen blowdown
TV-CC 201B	R.C.P. Therm barrier
TV-CC 202B, D, F	R.C.P. Return header
TV-CC 205A, B, C	Cont. Recirc Air Coils
TV-DA 200B	React cont sump pp disch
TV-DG 200B	Pri drn. xfer pp disch
TV-RM 200C	Limit sw on tv ra 200C
TV-VG 200B	Pri drn xfer tk vent
TV-SS 200A	Pressure liquid space
TV-SS 201A	Pressure vapor space
TV-SS 202A	Primary coolant cold leg
TV-SS 204A	Press relief tank gas sp
TV-SS 206A	Primary Coolant hot Leg
TV-SS 212A	St gen surface sample

Inside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads(1)  
Spray: 0-4 hrs solution of boric acid  
(2000-2100 ppm boron) buffered a pH  
of 8.5 to 11 with NaOH > 4 hr similar  
solution with a pH of 7 to 9

Main Steam Line Break (MSLB)  
430°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
Heat aging @ 200°F for 200 hrs, mechanical  
aging 100,000 cycles under electrical load

340°F 0 to 3 hr  
Reduce from 340°F  
to 120°F 3 to 5 hr

SEQUENCE REPEATED  
250°F to 3.5 days  
200°F 3.5 to 30 days  
70 psi 0 to 8 hrs  
10 psi 8 hrs to 30 days

Radiation Exposure 2.04 x 10<sup>8</sup> rads

Spray: Boric acid and water buffered to  
a pH of 10-11 with NaOH solution for 4  
days, water spray for 25 days, spray  
density = .015 gpm/ft<sup>2</sup>

MSLB

Maximum surface temperature is 285°F per  
ESG calculation 11712-ES-197-0 dated  
3-16-78 and is well below qualification  
temperature  
Radiation Exposure see LOCA Test.

OPERABILITY REQUIREMENTSLOCA & MSLB

Valve to close within 60 seconds of  
isolation signal; switches shall not  
fail so as to reopen valves.

OPERABILITY DEMONSTRATED  
LOCA & MSLB

Limit switches shown to operate  
after sequential testing.

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Sequential Test

MSLB

Calculation

QUALIFICATION DOCUMENTLOCA

Report Entitled:

"Qualification of NACCO controls  
limit switch Mode EA-180 to IEEE  
Standards 344 ('75) 323 ('74)  
and 382 ('72)"  
dated 3-3-78 and revised 4-7-78

MSLB

ESG Calculation 11712-ES-197-0  
dated 3-16-78

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSA. Deficiencies:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instrument even though not stated would commonly be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application
- 3) Test facility, even though not identified, could be determined from vendor's records.

EQUIPMENT DESCRIPTION & SER. NO.

P.O. NA-176/1176  
Motor Control Centers  
(Alcockner Noellier)  
MCC-2H1-2M  
MCC-2H1-2S  
MCC-2H1-2N  
MCC-2H1-2S  
MCC-1H1-2M  
MCC-1H1-2S  
MCC-1H1-2N  
MCC-1H1-2S  
MCC-1H1-2S  
Auxiliary Building

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
1 x 10<sup>6</sup> rads (based on 120 day  
LOCA). In addition, the 40 year  
rads must be considered for a total  
possible radiation dose of 1.04 x  
10<sup>6</sup> rads.

Normal Environment

70° - 120°F

Area has temperature monitors &  
Class IE redundant ventilation  
system.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Minimum total integrated dose of  
1.4 x 10<sup>6</sup> rads of gamma source radiation.

Normal Environment

Equipment rating 32 - 104°F

OPERABILITY REQUIREMENTS

Loss of Coolant Accident (LOCA)  
1.04 x 10<sup>6</sup> rads

Normal Environment

70° to 120°F

OPERABILITY DEMONSTRATED

Loss of Coolant Accident (LOCA)  
1.4 x 10<sup>6</sup> rads

Normal Environment

32-104°F

ACTIONARY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

Test

Normal EnvironmentIndustrial Standards  
NEMA ICS(1974)  
Sect. 1-108.QUALIFICATION DOCUMENTLOCAKlockner-Moeller Letter dated  
3/16/79Normal Environment

Specification NAS-213

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Qualification document is in letter form (i.e. no formal test report with approved signature and date) and does not address:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instruments even though not stated would commonly be  $\pm 1\%$ .
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) The letter is a summary of the radiation exposure test successfully completed on sample electrical components used in the listed MCC's. Certified data is available from Klockner-Moeller Corp. Fairfield, NJ.

Normal EnvironmentA. Deficiencies:

Normal ambient temperature may exceed MCC maximum operational temperature.

B. Solution:

Area is equipped with an ambient temperature monitor that will signal at  $101^{\circ}\text{F}$  and alarm at  $104^{\circ}\text{F}$ .



<u>EQUIPMENT DESCRIPTION &amp; MARK NO.</u>	<u>DESCRIPTION OF ENVIRONMENT</u>	<u>OPERABILITY REQUIREMENTS</u>
Motor Operated Valves Limatorque Corp P.O. No. 194/1194 Flanged a Wafer Type Butterfly Valves	Loss of Coolant Accident (LOCA)	LOCA
MOV-SW-108A, B MOV-SW-208A, B MOV-SW-113A, B (Component Cooling Heat Exchanger Iso.) Model SMB-0015	5.4 x 10 <sup>6</sup> rads (based on 120 day LOCA) including the 40 yr dose.	5.4 x 10 <sup>6</sup> rads
MOV-SW-213A, B (Fuel Pool Cooler Isolation) Model SMB-000-2 Auxiliary Hldg.	Normal Environment	Normal Environment
MOV-SW-103A, B, C, D MOV-SW-203A, B, C, D MOV-SW-104A, B, C, D MOV-SW-204A, B, C, D (Recirc. Spray Heat Exch. ISO)	50° to 120°F	120°F
Q.S.P.H	<u>ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED</u>	<u>OPERABILITY DEMONSTRATED</u>
	LOCA	LOCA
	40 yr integrated - 2 x 10 <sup>8</sup> rads	2 x 10 <sup>8</sup> rads
	Normal Environment	Normal Environment
	120°F continuous	120°F continuous
		<u>ACCURACY REQUIREMENTS</u>
		Not required

MANNER OF QUALIFICATIONLOCA

2.0 x 10<sup>8</sup> rads gamma radiation  
at Isomedix, Inc. Parsippany, NJ.

Normal Environment

Industrial Standard  
USAS

QUALIFICATION DOCUMENTLOCA

Limatorque  
Report No. B0003

Normal Environment

Limatorque VLVC0  
Nuclear Qualification  
for Safety  
Related Services  
NQDS 11/1/79

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

None

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

P.O. No. 242/1242, S.S. Valves 2 1/2"  
and larger, Limatorque Corp.  
MOV-QS-101A, B, C, D  
MOV-QS-201A, B, C, D  
(Containment Iso.)

MOV-RS-155A, B  
MOV-RS-255A, B  
(Containment Iso. Suction)  
Model SMB-0-7-1/2"

MOV-RS-156A, B  
MOV-RS-256A, B  
(Containment Iso. Suction)

Model SME-0-40  
Safeguards Building

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  
LOCA

$1 \times 10^6$  rads (based on 120 days LOCA).  
In addition, the 40 year radiation  
dose of  $4 \times 10^4$  rads must be  
considered for a total possible  
radiation dose of  $1.04 \times 10^6$  rads.

Normal Environment

70° to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

40 yr integrated -  $2 \times 10^3$  rads

Normal Environment

120°F continuous

OPERABILITY REQUIREMENTS

LOCA

$1.04 \times 10^6$  rads

Normal Environment

120°F

OPERABILITY DEMONSTRATED

LOCA

$2 \times 10^3$  rads

Normal Environment

120°F continuous

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

$2.0 \times 10^8$  rads gamma radiation  
at Isomedix, Inc. Parsippany, N.J.

Normal Environment

Industrial Standard USAS

QUALIFICATION DOCUMENTLOCA

Limatorque  
Report No. B0003

Normal Environment

Limatorque VLWCO  
Nuclear Qualification  
For Safety  
Related Services  
NQDS 11/1/79

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

None

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.Pump Motors

F.G. No. 127/1127, Recirculation Spray  
Pumps, General Electric

1-RS-P-2A, B  
2-RS-P-2A, B

Model 5K6328XC264A  
Safeguards Building

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

$1 \times 10^5$  rads (based on 120 days  
LOCA). In addition, the 40 year  
radiation dose of  $4 \times 10^4$  rads  
must be considered for a total  
possible radiation dose of  $1.04$   
 $\times 10^6$  rads.

Normal Environment

$70^{\circ}$  to  $120^{\circ}$ F  
Class IE redundant ventilation system

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

$1 \times 10^5$  rads

Normal Environment

$120^{\circ}$ F

OPERABILITY REQUIREMENTSLOCA

$1.04 \times 10^6$  rads

Normal Environment

$120^{\circ}$ F

OPERABILITY DEMONSTRATEDLOCA

$1 \times 10^5$  rads

Normal Environment

$120^{\circ}$ F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Unknown

Normal Environment

Industrial Standards

NEMA MG1 &amp; IEEE 112A

QUALIFICATION DOCUMENTLOCALetter from Vendor C. Bell (GE)  
March 10, 1979

Specification NAS#44

Normal Environment

Specification NAS-44

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Qualification document is in letter form (i.e. no formal test report with approved signature and date) and does not address:

1. Accuracy of variables and test data
2. Test monitoring sensors
3. Test facility

B. Solutions:

1. Accuracy of instrument even though not stated would commonly be 1%.
2. Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
3. Test facility, even though not identified, could be determined from Vendor's records.

Normal Environment

None

EQUIPMENT DESCRIPTION & PART NO.

P.O. No. 313/313  
Reactor Containment Electrical  
Penetrations -  
Conax Corp.  
Item 1 of 2

Penetration Assemblies

- Type IA - Instrumentation
- IB - Control
- IC, IIA, IIB, IIC, IID and
- IIE - Low Voltage Power
- III - Electrical
- IV - Thermocouples

Inside & Outside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

- 230°F 0 to 30 min
- Reduce from 230°F to 150°F 30 to 60 min
- 150°F 7 to 30 min
- 45 psig 0 to 30 min
- Reduce from 45 to 0 psig 30 to 60 min
- 4.2 x 10<sup>7</sup> rads (1)
- Spray: 0-4 hrs solution of boric acid (2,000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH beyond 4 hrs similar solution with a pH of 7 to 9.

OPERABILITY REQUIREMENTS

LOCA  
120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

LOCA  
E.V. 2./C/I  
2529-190 hrs  
Post LOCA thermal aging is equivalent to 429 days @ 150°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Pressure and Temperature

- Pressure 45 psig @ 230°F 0 to 30 min
- Decrease from 45 psig to 0 psig 0 to 30 min
- and 230°F to 245°F 30 to 60 min
- 150°F + 20°F @ 0 psig 1 hr to 10 days
- or
- 150°F - 40°F @ 0 psig
- radiation

1 x 10<sup>8</sup> rads gamma radiation minimum

ACCURACY REQUIREMENTS

Not required

Chemical Spray:  
From 0-30 min. No chemical spray was introduced from 30 min to 10 days assembly was subjected to spray solution: boron content was .23 molar as H<sub>3</sub>BO<sub>3</sub> NaOH = 5.0 to 8.0

MANNER OF QUALIFICATIONLOCA

Penetration assemblies were tested by using a prototype with characteristics pertinent to each individual type. This was first exposed to radiation then pressure and temperature and finally chemical spray.

QUALIFICATION DOCUMENTLOCA

Conax report "Maximum Emergency Environmental Test Report for Electrical Penetration Assemblies" No. IPS-73.4 dated 5/13/75

Radiation Test alarmax service test conax report IPS-137.

Conax letter "Qualification of Electric Penetrations"  
No. 1 PS-411, P/N 7280-10001-01,  
IPS-369, IPS-325 dated 1/5/80

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) pH of chemical spray was 5 to 8 for duration, not 8.5 to 11.0 for first ¼ hr or 7.0 to 9.0 for remainder
- 2) Temperature range was 140° to 170° from 1 hr to end not 150°
- 3) No calibration information or instrument error range was given.

B. Solutions:

- 1) The electrical penetration assemblies are fabricated from the following non-metallic materials; polyimides and polysulfone. These materials have been shown to be resistant to all diluted alkaline solutions. Therefore we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the penetration assemblies.
- 2) Very short duration of temp. below 150° when compared to total test duration makes this item acceptable.
- 3) Typical instrument accuracy can be expected to be ±1%, tolerance on the pressure and temperature curves used will allow for this accuracy.



EQUIPMENT DESCRIPTION & MAKE NO.

P.O. No-313/1313  
 Reactor Containment Electrical  
 Penetrations  
 Coax Corp.  
 Item 1 of 2  
 Penetration Assemblies  
 Type IA - Instrumentation  
 Type IB - Control  
 Type IC, IIA, IIB, IIC, IID and  
 IIE - Low Voltage Power

Inside and Outside Containment

DESCRIPTION OF ENVIRONMENT

Main Steam Line Break (MSLB)  
 430°y 0 to 2 min  
 290°y 2 to 60 min  
 150°y > 60 min  
 45 psia 0 to 30 min  
 Reduce from 45  
 to 0 psia 30 to 60 min  
 0 psia > 60 min  
 3.4 x 10<sup>4</sup> 40 yr dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB  
 290°y 0 to 30 min  
 Range 290°y 30 to 60 min  
 to 220°y  
 Range 245°y 60 to 1300 yr  
 to 140°y  
 Range 07 to 0 to 30 min  
 50 psia 30 min  
 0 psia 30 min  
 2.3 x 10<sup>7</sup> rads gamma radiation minimum

NOTE 1 - Temperature qualification by analysis per qualification Document #2.

RELIABILITY REQUIREMENTS

MSLB  
 120 days @ 150°y

RELIABILITY DEMONSTRATED (2)

MSLB  
 L.V.P./c/I  
 @ 255°y @ 190 hrs  
 Post LOCA thermal aging is equivalent  
 to 429 days @ 150°y

CEP EQUIPMENTS

MANNER OF QUALIFICATIONMSLE

Penetration assemblies were tested by using a prototype with characteristics pertinent to each individual type. This was first exposed to radiation then pressure and temperature.

QUALIFICATION DOCUMENTMSLE

1. CONAX Report "Maximum Emergency Environmental Test Report for Electrical Penetration Assemblies." No. IPS-73.4 dated May 13, 1975.
2. FSAR Appendix 3 C "Safety Related Equipment Temperature Transients During the Limited Main Steam Line Break" and NRC Comment 7.17 of the same subject.

Conax letter "Qualification of Electric Penetrations"  
No. IPS-411, P/N 7280-10001-01,  
IPS-369, IPS-325 dated 1/580

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSMSLEA. Deficiencies:

- 1) Pressure excursion was maintained for 30 min duration not 60 min.
- 2) During the test in Qualification Document #1, no accuracy was stated for the instruments used.

B. Solutions:

- 1) Pressure should have no significant effect on the splicing material.
- 2) Typical instrument accuracy can be expected to be  $\pm 1\%$ , tolerances on the pressure and temperature curves used will allow for this accuracy.

EQUIPMENT DESCRIPTION & MARK NO.

Item 2 of 2  
 P.O. No. NA-313/1313  
 Splices (Field and Factory)

Comax Corp (Supplier)  
 Kapton Insulation  
 Inside & Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F                    0 to 30 min  
 Reduce from 280°F  
 to 150°F                30 to 60 min  
 150°F                    > 60 min  
 45 psig                   0 to 30 min  
 Reduce from 45 to  
 0 psig                    30 to 60 min  
 0 psig                    > 60 min  
 4.2 x 10<sup>7</sup> rads (1)  
 Spray:  
 0 to 4 hrs solution of boric acid  
 (2,000-2100 ppm boron) buffered  
 to a pH of 8.5 to 11.0 with NaOH  
 beyond 4 hrs similar solution with  
 a pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Spray - From 0+ -240 hr spray continuously  
 with a solution of the following contents:  
 Boron content = .23 molar (1,900 PPM)  
 NaOH content = 10<sup>-4</sup> to 4 x 10<sup>-2</sup> M/DIAL  
 pH = 7.7 to 7.8

280°F @ 45+ psig                    0 to 30 min  
 Reduce from 45 to  
 0 psig                    30 to 60 min  
 Reduce from 280°F  
 to 144°F  
 Raised from 140°F                    30 to 60 min  
 150°F                    1 to 240 hrs

10 x 10<sup>7</sup> rads gamma radiation, minimum

OPERABILITY REQUIREMENTSLoss of Coolant Accident (LOCA)

120 days @ 150°F

OPERABILITY DEMONSTRATED(2)Loss of Coolant Accident (LOCA)

10 days @ 140°F

Post LOCA operations do not meet  
 operability requirements.

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Splices were made using various representative cable types and sizes which had been attached to a prototype penetration assembly. The prototype was first subjected to radiation exposure, then temperature, pressure and chemical spray concurrently.

QUALIFICATION DOCUMENTLOCA

Conax Report "Test Procedure and Report on Electrical Terminations Subjected to Design Basis Accident Environment" No. IPS-107 dated

Radiation: Alseraz Service Test  
Conax Report IPS-137

Conax letter "Qualification of Electric Penetrations"  
No. IPS-411, F/N 7280-10001-01,  
IPS-369, IPS-325 dated 1/5/80

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) Chemical spray solution had pH of 7.7 to 7.8 not 8.5 to 11.0 for first 1/2 hr.
- 2) Temperature below 150° to 140° on various occasions during test
- 3) The instruments and/or monitors used were not identified, also accuracy or error range was not stated.
- 4) Time, temperature envelope not adequate

B. Solutions:

- 1) The Penetration splicing material is a polyolefin material which has been shown to be resistant to all diluted alkaline solutions. Therefore we believe that since the LOCA spray is in the range of a diluted alkaline solution it should have no significant effect on the splice material.
- 2) Overall temp was within test tolerances.
- 3) Typical instrument accuracy can be expected to be ±1% tolerance on the pressure and temp. curves will allow for this accuracy.
- 4) The splices are qualified for 120 days @ 150°F per Conax letter "Qualification of Electrical Penetrations," No. IPS-411, F/N 7280-10001-01, IPS-369, IPS-325, dated 1/5/80.

EQUIPMENT DESCRIPTION & MAKE NO.  
 P.O. No-313/1113  
 Reactor Containment Electrical  
 Penetrations - CONAX  
 Item 2 of 2  
 Splices (field and factory)  
 Conax Corp. (Supplier)  
 Kapton Insulation  
 Inside & Outside Containment

DESCRIPTION OF ENVIRONMENT  
 Main Steam Line Break (MSLB)  
 430°F 0 to 2 min  
 260°F 2 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45  
 to 0 psig 30 to 60 min  
 0 psig > 60 min  
 3.4 x 10<sup>4</sup> rads 40 yr dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB  
 Raise from 109°F  
 to 253°F 0 to 30 sec  
 Raise from 253°F  
 to 290°F 1 to 2 min  
 282°F 2 to 30 min  
 Range 144°F  
 to 294°F 30 to 60 min  
 Range 140°F  
 to 150°F > 60 min to 240 hr  
 0 to 24 psig 0 to 30 sec  
 45+ psig 1 to 30 min  
 0 psig 30 min to 240 hr  
 2.5 x 10<sup>7</sup> rads gamma radiation minimum

OPERABILITY REQUIREMENTS

120 days @ 150 °F

OPERABILITY DEMONSTRATED (2)

MSLB  
 L.V.P./c/1  
 285°F - 190 hrs  
 Post IAKK thermal aging is  
 equivalent to 429 days @ 150°F

ACCEPTANCE REQUIREMENTS

MSLB

Not required

MANNER OF QUALIFICATIONMSLB

Splices were made on various representative cable types and sizes which had been attached to a prototype penetration assembly. The prototype was first subjected to radiation exposure, then temperature and pressure, concurrently.

QUALIFICATION DOCUMENTMSLB

1. CONAX Report "Test Procedure and Report on Electrical Terminations Subjected to Design Basis Accident Environment " No. IPS-107 dated October 5, 1973.
2. FSAR Appendix 3C "Safety Related Equipment Temperature Transients During the Limited Main Steam Line Break" and NRC Comment 7.17 of the same subject.

Conax letter "Qualification of Electric Penetrations: No. IPS-411, P/N 7280-10001-01, IPS-369, IPS-325 dated 1/5/80.

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSMSLB

## A. Deficiencies :

1. Pressure excursion was maintained for 30 min duration not 60 min
2. The instruments and/or sensors used were not identified in Qualification Document #1, also accuracy or error range was not stated.

## A. Solutions:

1. During the LOCA test the pressure was held for the required time period.
2. Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application. Typical instrument accuracy can be expected to be  $\pm 1\%$ . Tolerances on the pressure and temperature curves used will allow for this accuracy.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-355/1355

Inside Recirc. Spray Pump Motor  
 General Electric - 300 hp, 460 v,  
 1.15 S.P., Class H Insulation,  
 Model: 5K6319XJ1B

1-RS-P-1A, B  
 1-RS-P-1A, B

Inside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F	0 to 30 min
Reduce from 280°F	
150°F	30 to 60 min
150°F	> 60 min
45 psig	0 to 30 min
Reduce from 45	
50 0 psig	30 to 60 min
0 psig	> 60 min
7.2 x 10 <sup>7</sup> rad (1)	

Spray: 0 to 4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH. Beyond 4 hrs similar solution with a pH of 7 to 9.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLoss of Coolant Accident (LOCA)

Pressure and Temperature - 45 psig at 275-280°F from 0-30 min. Pressure was reduced to 0<sup>0</sup> psig at 100°F within next 30 min. During this 60 min. steam exposure motor was sprayed with chemical solution at 20 gpm. Motor was at full load throughout. Four cycles were run as described above, stopping motor between each cycle to take readings. At the fifth cycle till end of 7 days, temp. reduced to 150°F at 0 psig and sprayed continuously with chemical solution.

Radiation - Motor was exposed to an equivalent dose of 2 x 10<sup>6</sup> rads at a dose rate of < 0.5 x 10<sup>6</sup> rads/hr.

Chemical Spray - Spray continuously 0-7 days with a water solution of boric acid, lithium hydroxide, and sodium hydroxide with the following concentrations:

Boron - 0.23 molar (as boric acid)  
 Lithium hydroxide - 1.0 x 10<sup>-4</sup> molar  
 Sodium hydroxide - 1.0 x 10<sup>-3</sup> molar

The above will result in a pH of 5.5 to 6.5

OPERABILITY REQUIREMENTS

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

130°F - 750 days

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Motor was tested sequentially by first subjecting it to the cumulative radiation dose and then the steam/-chemical spray with elevated temperature and pressure.

QUALIFICATION DOCUMENTLOCA

Topical Report on G.E. Vertical Induction Motors Inside Containment Recirculation Spray Pump Motors - Surry Power Station - Second Addendum to Cover Heat Aging, Radiation Exposure, Vibration, Steam/Chemical Spray Exposure Qualification Tests - Docket Number 50-280 and 50-281 by M.W. Sheets, Vertical Motor Products Section General Electric Company, San Jose, California June 12, 1973 (pages 36 to 64)

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies

1. Accuracy not stated in test report for pressure and flow.
2. No accuracy given for any data gathering instruments used.
3. Test report is not dated on signature page.
4. Chemical spray pH levels in test do not agree with design levels.
5. Temperature varied from 275-280°F.

B. Solutions:

1. The actual max pressure taken from the LOCA pressure transient profile (FSAR Fig. 2.4-1) is 36 psig. 45 psig is a conservative value and the test pressure accuracy is considered to be within +9 psig.
2. Accuracy of instruments, even though not stated, would commonly be ±1%.
3. Test report, even though not dated on signature page, is dated on cover sheet.
4. Lower pH levels (5.5 to 6.5) maintained during motor test have been reviewed with regard to motor materials and it has been determined that the higher design pH levels would not have any additional effect.
5. Temperature variation of 275°F to 280°F falls within the tolerance (265-280°F) of the LOCA temperature transient profile (FSAR Fig. 2.4-2).



EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-355/1355

Inside Recirc. Spray Pump Motor  
 General Electric - 300 hp, 460 v.  
 1.15 S.F., Class H insulation,  
 Model: 5K6319XJ1B  
 1-RS-P-1A,B  
 2-RS-P-1A,B

Inside Containment

DESCRIPTION OF ENVIRONMENTMain Steam Line Break (MSLB)

430°F	0 to 2 min
280°F	2 to 60 min
150°F	> 60 min
45 psig	0 to 30 min
Reduce from 45	
to 0 psig	30 to 60 min
0 psig	> 60 min
3 x 10 <sup>7</sup> rads	40 yr. dose

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDMain Steam Line Break (MSLB)

Temperature - Motor was qualified to the design environment by analysis.

Pressure - See LOCA qualification for this motor.

Radiation - Motor was exposed to an equivalent dose of 2 x 10<sup>8</sup> rads at a dose rate of 4 0.5 x 10<sup>6</sup> rad/hr.

OPERABILITY REQUIREMENTS

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

130°F - 750 days

ACCURACY REQUIREMENTS

Not Required

MANNER OF QUALIFICATIONMSLB

The motor was qualified by utilizing the LOCA qualification test results i.e., radiation exposure, temperature, pressure. A heat transfer calculation was performed (Ref. FSAR, Section 3C) to obtain the maximum surface temperature that will be experienced during a MSLB. This value (271°F) was then compared to the value (280°F) that the motor was tested for. Since the motor was qualified for the LOCA at a temperature of 280°F, the lower surface temperature of 271°F proved the acceptable operation of the motor during a MSLB.

QUALIFICATION DOCUMENTMSLB

1. Final Safety Analysis Report - Section 3C. (pages 1 to 21)
2. Topical Report on GE Vertical Induction Motors - Inside Containment Recirculation Spray Pump Motors - Surry Power Station - Second Addendum to Cover Heat Aging, Radiation Exposure, Vibration, and Steam/Chemical Spray Exposure Qualification Test - Docket Number 50-280 and 50-281 by M.W. Sheets, Vertical Motor Products Section, General Electric Company - San Jose, California June 12, 1973 (pages 36 to 64)

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSMSLB

## A. Deficiencies:

1. Accuracy not stated in test report for pressure.
2. Test report is not dated on signature page.
3. Pressure was maintained at 40 psig for 30 min and not 60 min.

## B. Solutions:

1. The actual max. design pressure is 40 psig. These motors were tested for 45 psig (ref. LOCA qualification for these motors). 40 psig is a conservative value and test pressure accuracy within ±5 psig from 45 psig tested would be reasonable to assume.
2. Test report even though not dated on the signature page is dated on the cover sheet.
3. In the G.E. LOCA test, the motor was tested for five cycles at 45 psig for a period of 30 min per cycle. Therefore, the 60 min MSLB requirement at 40 psig was exceeded.

EQUIPMENT DESCRIPTION & MARK NO.

Solenoid Operated Valves Automatic  
Switch Co., Model #HT8321A5

SOV-BD-100A,C,E	Steam Generator Blowdown ISO Isol Vlv
SOV-CC-100A,C,E	Containment Recirc Air Clr Outlet - Outside Cont
SOV-CC-100A	RCP Therm Barrier Return Hdr
SOV-CC-102A,C,E	RCP Coolers Return Hdr
SOV-CC-103A,B	RHR Heat Exchange Return
SOV-CC-104A-1,2	RCP Coolers Inlet - Outside Cont A
SOV-CC-104B-1,2	RCP Coolers Inlet - Outside Cont B
SOV-CC-104C-1,2	RCP Coolers Inlet - Outside Cont C
SOV-CV-150A,B,C,D	Containment Vac Pump Suction
SOV-DG-100A	Pri Drn Xfer Ip
SOV-EM-100A	Radiation Monitor
SOV-SI-100A,B	Nitrogen Supply Line
SOV-SI-101A,B	Nitrogen Supply Line
SOV-VG-100A	Pri Drn Xfer Tk Vent
SOV-BD-200A,C,E	Steam Generator Blowdown Isol Vlv
SOV-CC-200A,B,C	Containment Recirc Air Clr Outlet - Outside Cont
SOV-CD-201A	RCP Therm Barriers Return Hdr
SOV-CC-202A,C,E	RCP Coolers Return Hdr
SOV-CC-203A,B	RHR Heat Exchanger Return
SOV-CC-204A-1,2	RCP Coolers Inlet - Outside Containment
SOV-CC-204B-1,2	RCP Coolers Inlet - Outside Containment
SOV-CC-204C-1,2	RCP Coolers Inlet - Outside Containment
SOV-CV-250A,B,C,D	Containment Vac Pump Suction
SOV-DA-200A	RC Sump Pump Disch
SOV-DG-200A	Pri Drain Xfer Pump Disch
SOV-EM-200A	Radiation Monitor
SOV-SI-200A,B	Nitrogen Supply Line
SOV-SI-201A,B	Nitrogen Supply Line
SOV-VG-200A	Pri Drn Xfer Tk Vent

Auxiliary Building

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

$1 \times 10^6$  rads (based on LOCA). In addition, the 40 yr radiation dose of  $4 \times 10^4$  rads must be considered for a total possible radiation dose of  $1.04 \times 10^6$  rads.

Normal Environment

50° to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Valves not specifically tested to  $1.6 \times 10^6$  rad integrated dose. When exposed to  $5 \times 10^7$  rad, leakage developed which exhausted the pressure vessel. Solenoid valves will have achieved their safety-related function within 60 sec of an initiation signal. The long-term failure mode will not reintroduce air to a control valve, therefore, the valve will maintain its fail-safe position.

Normal Environment

32° to 176°F

OPERABILITY REQUIREMENTSLOCA

SOV will perform its function of closing the isolation valve within 60 sec of receiving signal.

Normal Environment

120°F

OPERABILITY DEMONSTRATEDLOCA

SOV performed required safety function after receiving radiation dose.

Normal Environment

176°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

LOCA  
Test

Normal Environment

Underwriter's Laboratory

QUALIFICATION EXPERIMENT

LOCA  
Franklin Institute Research  
Laboratories (FIRL) Test  
Report F-04539,  
Catalog #30,  
Westinghouse letter

NS-SS770-0

Normal Environment

ASCO. Catalog #30 page B

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA

A. Deficiencies:

Failed during radiation exposure.

B. Solutions:

When exposed to a radiation dose of  $5 \times 10^7$  rads, some plastic inards of the SOV did disintegrate causing the valve to leak. However, the valve was able to exhaust its accumulated pressure and perform its safety function. (W letter NS-SS770-0)

Normal Environment

None

EQUIPMENT DESCRIPTION & PART NO.

- P.O. No. 12-99/1086
- 450 V Switchgear
- 2-EE-S5-03 (2H1)
- 2-EE-S5-04 (2J1)
- 2-EE-S5-01 (2H1)
- 2-EE-S5-02 (2H1)
- 1-EE-S5-03 (1H1)
- 1-EE-S5-04 (1H1)
- 1-EE-S5-01 (1H1)
- 1-EE-S5-02 (1J1)

13E INTERNAL CABINETS  
Rad Control Room, Auxiliary Bldg.

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)  $1 \times 10^6$  rads (based on 120 days LOCA). In addition, the 40 year radiation dose of  $4 \times 10^6$  rads must be considered for a total possible radiation dose of  $1.04 \times 10^6$  rads.

Normal Environment

70 to 120°F  
Area has temperature monitors & class IE redundant ventilation systems.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

Loss of Coolant Accident

Later

Normal Environment

-2200 to 1040°F

OPERABILITY REQUIREMENTS

Loss of Coolant Accident (LOCA)

$1.04 \times 10^6$  rads

Normal Environment

700-1200°F

OPERABILITY DEMONSTRATED

Loss of Coolant Accident (LOCA)

Later

Normal Environment

-2200 to 1040°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLoss of Coolant Accident

Tested

Normal EnvironmentIndustrial Standard  
ANSI C37.20 Sec 3.1QUALIFICATION DOCUMENTLoss of Coolant Accident

Later

Normal Environment

Specification NAS-34

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

Later

Normal EnvironmentA. Deficiencies:

Normal ambient temperature may exceed switchgear's maximum operational temperature.

E. Solution:

Area is equipped with an ambient temperature monitor that will signal at 101°F and alarm at 104°F.

EQUIPMENT DESCRIPTION & MARK NO.

Marathon Series 200 and 1500  
Terminal Blocks (Phenolic)

Connectron Type NSG-1,  
NSG-3, and PSU's Terminal  
Blocks (Nylon)

Thermo-electric Terminal  
Block No. 3225 (Thermosetting  
Phenolic)

GE Terminal Blocks  
EB5 and EB25 (Phenolic)

Westinghouse Type T-AL  
Terminal Blocks (Nylon)

Outside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

$1 \times 10^6$  rads (based on 120 days LOCA)  
In addition, the 40 yr radiation dose  
of  $4 \times 10^4$  rads must be considered for  
a total possible radiation dose of  
 $1.04 \times 10^6$  rads.

Exceptions:

- a) Auxiliary Building Pipe Tunnel  
El 244'-6" maximum radiation  
dose  $7 \times 10^6$  rads (1)
- b) Safeguards Building maximum  
radiation dose  $5 \times 10^6$  rads (1)

Normal Environment

Most severe temperature will occur,  
for Cat 1E systems in Main Stream  
Valve House 40-120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Unfilled phenolic can withstand a gamma  
exposure dose of over  $10^6$  rads and show  
minimal effects due to radiation.

Nylon can withstand a gamma exposure  
dose of over  $10^6$  rads

Normal Environment

This temperature range is well within the  
normal continuous service temperature.

OPERABILITY REQUIREMENTSLOCA

$1.04 \times 10^6$  rads

Normal Environment

40°F-120°F

OPERABILITY DEMONSTRATEDLOCA

Phenolic  $1 \times 10^6$  rads  
Nylon  $1 \times 10^6$  rads

Normal Environment

120°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Terminal Block material was compared with identical material for the effects high level radiation.

Normal Environment

Industrial Standards  
Underwriter's Lab

QUALIFICATION DOCUMENTLOCA

REIC Report No. 21 Radiation  
Effect Information Center,  
Columbus, Ohio. Suchman Product  
Manual Insert 2.1 Rev. 8/23/76

Normal Environment

UNDERWRITERS LAB

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) Exact spec. of material is not available from most mfr.
- 2) Nylon terminal blocks, which are located in the auxiliary building, pipe tunnel & safeguards building, may not withstand the radiation level above  $1 \times 10^5$  rads.

B. Solutions:

- 1) The general makeup by phenolic or nylon will not vary enough to effect the test results.
- 2) Nylon terminal blocks will be replaced with phenolic or poly-sulfone in the pipe tunnel and safeguards building.



EQUIPMENT DESCRIPTION & MARK NO.  
 Ononite Termination Tape Field Purchased  
 T-05 Insulating Tape  
 T-15 Jacketing Tape  
 Inside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

280°F                    0 to 30 min  
 Reduce from 280°F to 150°F            30 to 60 min  
 150°F                    > 60 min  
 45 psig                    0 to 30 min  
 Reduce from 45 psig to 0 psig            30 to 60 min  
 0 psig                    > 60 min  
 7.2 x 10<sup>7</sup> rads (1)  
 0 psig                    > 60 min  
 Spray: 0-4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH > 4 hr similar solution with a pH of 7 to 9

Main Steam Line Break (MSLB)

430°F                    0 to 2 min  
 290°F                    2 to 60 min  
 150°F                    > 60 min  
 45 psig                    0 to 30 min  
 Reduce from 45 psig to 0 psig            30 to 60 min  
 0 psig                    > 60 min  
 3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Aged 1/8 hr at 1210°F  
 Irradiated to 2 x 10<sup>3</sup> rads

PWR Exposure:

80 psig @ 3280°F for 4 hours  
 16 psig @ 2920°F for 7 days  
 Spray 10,000 ppm boric acid buffered with NaOH to a pH of 10.5 throughout the PWR exposure period.

SMR Exposure:

A series of transient cycles each consisting of a rise to a specified pressure and temp. for a specified time and a gradual return to initial conditions. Following transient cycles 100 day exposure to live steam 0 psig, 2120°F

MSLB

Same as "Description of Environment"

OPERABILITY REQUIREMENTS

LOCA & MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

LOCA & MSLB

2120°F for 100 days  
 Post LOCA thermal aging is equivalent to 2.9 years @ 150°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Test - Sequential

QUALIFICATION DOCUMENTLOCA

Okonite's Engineering Report  
No. 141 dated February 29, 1972

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Qualification document does not address

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instrument even though not stated would commonly be  $\pm 1\%$
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Test facility, even though not identified, could be determined Vendor's records.

MSLB

Temperature - Analysis

Maximum calculated surface temperature during limiting MSLB is 270°F which does not exceed qualification temperature of 324°F given in Okonite Engineering Report No. 141.

Pressure and Radiation - Test

Refer to LOCA qualification

MSLB

S&W Calculation ES-189  
"Equipment Temperature Transient  
for Okonite Tape Splices"

MSLB

Same as above

EQUIPMENT DESCRIPTION & MARK NO.

Raychem heat shrinkable field  
splicing material WCSF type coated  
with Type-B adhesive

Inside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280<sup>o</sup>F                    0 to 30 min  
Reduce from 280<sup>o</sup>F  
to 150<sup>o</sup>F                30 to 60 min  
150<sup>o</sup>F                    > 60 min  
45 psig                 0 to 30 min  
Reduce from 45  
to 0 psig                30 to 60 min  
0 psig                    > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hrs solution of boric acid  
(2000-2100 ppm boron) buffered to a pH of  
8.5 to 11 with NaOH<sup>24</sup> or similar solution  
with a pH of 7 to 9

Main Steam Line Break (MSLB)

430<sup>o</sup>F                    0 to 2 min  
280<sup>o</sup>F                    2 to 50 min  
150<sup>o</sup>F                    > 60 min  
45 psig                 0 to 30 min  
Reduce from 45  
to 0 psig                30 to 60 min  
0 psig                    > 60 min

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA & MSLB

Irradiated by cobalt-60 gamma source at 0.27 Mrads/hr  
to total dose of 200 Mrads.

360<sup>o</sup>F @ 70 psig            5 hr  
320<sup>o</sup>F @ 70 psig            6 hr  
250<sup>o</sup>F @ 21 psig            24 hrs  
and 0.2% Boric acid spray buffered to a pH of 10  
221<sup>o</sup>F @ 2.5 psig            12 days  
212<sup>o</sup>F @ 2.0 psig            100 days

OPERABILITY REQUIREMENTSLOCA

120 days @ 150<sup>o</sup>F

MSLB

120 days @ 150<sup>o</sup>F

OPERABILITY DEMONSTRATED(2)LOCA

212<sup>o</sup>F for 100 days

Post LOCA thermal aging is greater  
than 2.9 years @ 150<sup>o</sup>F

MSLB

See above

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

LOCA & MSLE

Combined thermal and radiation aging period followed by a simultaneous exposure to steam, chemical spray and gamma radiation

QUALIFICATION DOCUMENT

LOCA & MSLE

Psychem Technical Report F-04033

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONS

None

EQUIPMENT DESCRIPTION & PART NO.

Solenoid Operated Valve Automatic  
Switch Co., Model #M33025111

SOV-30-1002, I&F	Steam Gen Slowdown Isol Vlv
SOV-02-1012	RCP Thermal Barrier Return Hdr
SOV-02-1022, I&F	RCP Coolers Return Hdr
SOV-02-1024, I&F	Cont Reactor Air Ctr Outlet & Inj Cont
SOV-02-1002	Cont Sump Fp Disch Isol Vlv
SOV-02-1008	Pri Dm Kler Fp Disch Isol Vlv
SOV-02-1004	Press Liquid Space Cont Isol Vlv
SOV-02-1014	Press Vapor Space Sump Cont Isol Vlv
SOV-SS-1004	Pri Coolant Cold Leg Sample Cont Isol Vlv
SOV-SS-1004	Press Heater Tix Gas Space Cont Isol Vlv
SOV-SS-1004	Pri Coolant Hot Leg Sample Cont Isol Vlv
SOV-SS-1124	Steam Gen Sample Cont Isol Vlv
SOV-02-1002	Pri Dm Kler Tix Vent
SOV-02-3002, I&F	Steam Gen Slowdown Isol Vlv
SOV-02-3012	RCP Thermal Barrier Return Hdr
SOV-02-3022, I&F	RCP Coolers Return Hdr
SOV-02-3024, I&F	Cont Reactor Air Ctr Outlet & Inj Cont
SOV-02-3008	Cont Sump Fp Disch Isol Vlv
SOV-02-3004	Pri Dm Kler Fp Disch Isol Vlv
SOV-SS-3004	Press Liquid Space Cont Isol Vlv
SOV-SS-3014	Press Vapor Space Sample Cont Isol Vlv
SOV-SS-3024	Pri Coolant Cold Leg Sample Cont Isol Vlv
SOV-SS-3024	Press Relief Tix Gas Space Cont Isol Vlv
SOV-SS-3024	Pri Coolant Hot Leg Sample Cont Isol Vlv
SOV-SS-3124	Steam Gen Sample Cont Isol Vlv
SOV-02-3002	Pri Dm Kler Tix Vent

Isolde Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

280°F 0 to 30 min  
 Reduce from 280°F to 150°F 30 to 60 min  
 150°F > 60 min  
 45 psig 0 to 30 min  
 Reduce from 45 to 0 psig 30 to 60 min  
 0 psig > 60 min  
 7.2 x 10<sup>7</sup> rads (1)

Spray:  
 0-4 hr - Solution of boric acid (3000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
 > 4 hr stabilizer solution with a pH of 7 to 9

Main Steam Line Break (MSLB)

45 psig 0 to 30 min  
 Reduce from 45 to 0 psig 30 to 60 min  
 0 psig > 60 min  
 3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

450°F 0 to 2 min  
 Reduce from 450°F to 340°F 2 to 8 min  
 Reduce from 340°F to 240°F 8 to 35 min  
 150°F 52 min to 14 days  
 129 psia 0 to 2 min  
 118 psia 2 to 32 min  
 Reduce from 118 to 25 psia 32 to 34 min  
 13.5 psia 32 min to 14 days

Radiation exposure 5 x 10<sup>7</sup> rads

MSLB

Exceeded by above LOCA test

OPERABILITY REQUIREMENTS

LOCA & MSLB

SOV will perform its function of closing isolation valve within 60 sec of receiving signal. Failure of SOV will not cause valve to reopen.

OPERABILITY DEMONSTRATED

LOCA & MSLB

Functioned properly for 14 days at 150°F after 50 Mrad radiation exposure.

ACCEPTABLE REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA & MSLE

Sequential Test

Radiation followed by Environmental Exposure

QUALIFICATION DOCUMENTLOCA & MSLE

Franklin Institute Research Laboratories (FIRL) Test Report F-04539

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSLOCA & MSLEA. Deficiencies:

- 1) Valves were not subjected to a chemical spray
- 2) Radiation exposure during test is below accident dose of  $4.2 \times 10^7$  rads plus 40 yr dose of  $3 \times 10^7$  rads.

B. Solutions:

- 1) Valves not subject to spray since valves will have performed their intended function prior to initiation of spray.
- 2) Replace valves inside the crane wall prior to 10.67 yr exposure. Take radiation reading for rate of dose during plant operation. These measurements will provide a more accurate exposure rate and, thereby, increase or decrease the period of replacement.

EQUIPMENT DESCRIPTION & MAKE NO.

Solenoid Operated Valves, Automatic  
Switch Co.

Model #M0344471

SOV-M0-111A,B, Aux. Feed Pump Turb Drive

Model #M0344471

SOV-M0-211A,B, Aux. Feed Pump Turb Drive

Main Steam Valve Building

DESCRIPTION OF ENVIRONMENT

Main Steam Line Break (MSLB)

See Deficiencies and Solutions

Normal Environment

40° to 120°°F

Area has temperature monitors.

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB

See Deficiencies and Solutions

Normal Environment

Type HT suitable for ambient  
temperature as high as 170°°F

OPERABILITY REQUIREMENTS

MSLB

SOV will perform its function of closing  
isolation valve within 60 sec of  
receiving signal.

Normal Environment

120°°F

OPERABILITY DEMONSTRATED

MSLB

- a) SOV will have performed its function  
prior to failure.
- b) Failure of SOV will not cause valve  
to reopen.

Normal Environment

170°°F

ACCURACY REQUIREMENTS

Not required

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

MSLB

A. Deficiencies:

SOV's will not withstand the MSLB temperature.

B. Solution:

SOV's will have completed their operation before temperature causes it to fail.

QUALIFICATION DOCUMENT

MSLB

None

Normal Environment

ASCO Catalog #30, Page 8

MANNER OF QUALIFICATION

MSLB

None

Normal Environment

Underwriters Laboratories



EQUIPMENT DESCRIPTION & MARK NO.

Solenoid Operated Valves Automatic  
Switch Co., Model #HT830281U

SOV-BA-100A	R.C. Sump Pp Discn
SOV-SS-100B	Pressure Liquid Space Isol Vlv
SOV-SS-102B	PRI Coolant Cold Leg Sample Isol Vlv
SOV-SS-104A,B	Press Relief TK Gas Space Sample Isol Vlv
SOV-SS-106B	PRI Coolant Hot Leg Sample Isol Vlv
SOV-SS-112B	Steam Generator Sample Isol Vlv
SOV-SS-200B	Pressure Liquid Space Isol Vlv
SOV-SS-202B	PRI Coolant Cold Leg Sample Isol Vlv
SOV-SS-204A,B	Press Relief TK Gas Space Sample Isol Vlv
SOV-SS-206B	PRI Coolant Hot Leg Sample Isol Vlv
SOV-SS-212B	Steam Generator Sample Isol Vlv

Auxiliary Building

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

$1 \times 10^6$  rads (based on 120 day LOCA).  
In addition, the 40 yr radiation dose  
of  $4 \times 10^4$  rads must be considered for  
a total possible radiation dose of  
 $1.04 \times 10^6$  rads.

Normal Environment

50° to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

Radiation exposure  $5 \times 10^7$  rads

Normal Environment

Type HT suitable for ambient temperature  
as high as 176°F

OPERABILITY REQUIREMENTSLOCA

SOV will perform its function of closing  
isolation valve within 60 sec of  
receiving signal.

Normal Environment

120°F

OPERABILITY DEMONSTRATEDLOCA

Functioned properly for 14 days at  
150°F after 50 Mrad radiation  
exposure and will not misoperate  
if SOV fails due to radiation.

Normal Environment

176°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Test

Normal EnvironmentIndustrial Standard  
Underwriter's LaboratoryQUALIFICATION DOCUMENTLOCAFranklin Institute Research  
Laboratories (FIRL) Test  
Report F-04539Normal Environment

ASCO, Catalog #30, page 8

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

None

Normal Environment

None

EQUIPMENT DESCRIPTION & MARK NO.

Solenoid Operated Valve  
Automatic Switch Co.

Model #PT83201A101

SOV-SS-103A,B RHR Outboard Isol Viv  
SOV-SS-203A,B RHR Outboard Isol Viv

Auxiliary Building

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

$1 \times 10^6$  rads (based on 120 day LOCA).  
In addition, the 40 yr radiation dose of  
 $4 \times 10^4$  rads must be considered for a  
total possible radiation dose of  
 $1.04 \times 10^6$  rads.

Normal Environment

50° to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

None

Normal Environment

Type PT is suitable for ambient temperature  
as high as 140°F.

OPERABILITY REQUIREMENTSLOCA

SOV will perform its function of closing  
isolation valve within 60 sec of  
receiving signal.

Normal Environment

120°F

OPERABILITY DEMONSTRATEDLOCA

None

Normal Environment

140°F

ACCURACY REQUIREMENT

Not required

MANNER OF QUALIFICATION

LOCA  
None

Normal Environment  
Industrial Standard  
Underwriter's Laboratory

QUALIFICATION DOCUMENT  
LOCA

None

Normal Environment  
ASCO Catalog #30, Page 8

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS  
LOCA

SOV will perform its function of closing isolation valve within 10 sec. of receiving signal. Failure of SOV will not reopen valve.

Normal Environment  
None

<u>EQUIPMENT DESCRIPTION &amp; MAKE NO.</u>	<u>DESCRIPTION OF ENVIRONMENT</u>	<u>OPERABILITY REQUIREMENTS</u>
Raychem high voltage terminations HVT	LOCA 1 x 10 <sup>7</sup> rads (based on 120 day LOCA). In addition, the 40 year radiation dose of 4 x 10 <sup>8</sup> rads must be considered for a total possible radiation dose of 1.04 x 10 <sup>9</sup> rads.	LOCA 1.04 x 10 <sup>7</sup> rads
Raychem high voltage motor connectors HVMC	Normal Environment 40 - 120° F <u>ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED</u> LOCA Terminations & Connectors Irradiation of the materials in a cobalt - 60 gamma source at 0.50 Mrads per hour to a total dose of 2 x 10 <sup>8</sup> rads.	Normal Environment 40-120 F <u>OPERABILITY DEMONSTRATED</u> LOCA 2 x 10 <sup>8</sup> rads Normal Environment -60-125° F
Raychem Inc. Outside Containment	Normal Environment Terminations & Connectors Continuous operation -60 to 125°	<u>ACCURACY REQUIREMENTS</u> Not required

MANER OF QUALIFICATIONLOCA

Test: Thermal aging followed by  
irradiation for HVT and HVMC

Normal Environment

Industrial Standards  
ASTM D476  
IEEE 48

QUALIFICATION DOCUMENTLOCA

Raychem Report #71100 Revision 1

Letter from Raychem dated 4/24/79  
and EPSERT PRO Raychem Report  
RT1500/1

Normal Environment

Raychem HVT catalog U-012 dated June 1976

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

E. Solutions:

- 1) Accuracy of instrument even though  
not stated would commonly be 1%
- 2) Test monitoring sensors, even though  
not identified, are assumed to comply  
with Industrial Standards for their  
type of application
- 3) Test facility, even though not  
identified, could be determined  
from Vendor's records.

Normal Environment

None

EQUIPMENT DESCRIPTION AND MARK NO.

Solenoid Operated Valves  
Automatic Switch Co.  
Model THT8320A102

SOV-LM100A Cont. Press Taps  
SOV-LM100B Cont. Press Taps  
SOV-LM100C Cont. Press Taps  
SOV-LM100D Cont. Press Taps  
SOV-LM100E Cont. Press Taps  
SOV-LM100F Cont. Press Taps  
SOV-LM100G Cont. Press Taps  
SOV-LM100H Cont. Press Taps

SOV-LM200A Cont. Press Taps  
SOV-LM200B Cont. Press Taps  
SOV-LM200C Cont. Press Taps  
SOV-LM200D Cont. Press Taps  
SOV-LM200E Cont. Press Taps  
SOV-LM200F Cont. Press Taps  
SOV-LM200G Cont. Press Taps  
SOV-LM200H Cont. Press Taps

Auxiliary Bldg.

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

$1 \times 10^5$  rads (base on 120 day LOCA).  
In addition, the 40 yr. radiation dose  
of  $4 \times 10^4$  rads. must be considered  
for a total possible radiation dose of  
 $1.04 \times 10^6$  rads.

Normal Environment

50° to 120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

None

Normal Environment

Type THT suitable for ambient  
temperature as high as 170°F

OPERABILITY REQUIREMENTS

LOCA

SOV will perform its function of  
closing isolation valve within  
60 sec. of receiving signal.

Normal Environment

120°F

OPERABILITY DEMONSTRATED

LOCA

None

Normal Environment

170°F

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATION

LOCA

None

Normal EnvironmentIndustrial Standard  
Underwriter's LaboratoryQUALIFICATION DOCUMENT

LOCA

None

Normal Environment

ASCO catalog #30, page 8

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCASOV will perform its function of  
closing isolation valve within 60 sec  
of receiving signal. Failure of SOV  
will not reopen valve.Normal Environment

None



EQUIPMENT DESCRIPTION & MARK NO.

P.O. No-83/1063

Radiation Monitoring Pump Motor  
Variation Electric  
Class A Insulation

Model #3954175134-W

1-SM-P-5,6,7,8  
2-SM-P-5,6,7,8

Main Steam Valve House

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

5.4 x 10<sup>6</sup> (1)

Normal Environment

120°F

OPERABILITY REQUIREMENTS

LOCA

5.4 x 10<sup>6</sup>

Normal Environment

120°F

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

None

OPERABILITY DEMONSTRATED

LOCA

None

Normal Environment

104°F

Normal Environment

104°F

ACTIVITY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

None

Normal EnvironmentIndustrial Standard  
NEMA-MILQUALIFICATION DOCUMENTLOCA

None

Normal Environment

Specification NAS-104

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

No nuclear qualification

B. Solutions:

- 1) Replace motor
- 2) Shield motor

Normal EnvironmentA. Deficiencies:

High ambient temperature

B. Solutions:

- 1) Replace motor
- 2) Provide area with ambient temperature monitor that will signal at 101°F and alarm at 104°F

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA 10/1010  
Nuclear Steam Supply System  
Westinghouse Electric Comp.

## Steam Generator Flow Transmitters

FT-1474, 2474  
FT-1475, 2475  
FT-1484, 2484  
FT-1485, 2485  
FT-1494, 2494  
FT-1495, 2495

Rosemount Model 1152DP6A

Inside Containment

DESCRIPTION OF ENVIRONMENT

LOCA  
280°F  
Reduce from 280°F 0 to 30 min  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
4.2 x 10<sup>7</sup> rads

Spray: 0-4 hrs solution of boric  
acid (2000-2100 ppm boron)  
buffered to a pH of 8.5 to 11 with  
NaOH; 4 hrs similar solution with  
a pH of 7 to 9.

MSLB  
430°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
350°F 0 to 10 min  
310°F 10 min to 1 hr  
303°F 1 hr - 8 hr  
230°F 8 hr - 50 hr  
66 psig 0 - 10 min  
70 psig 10 min - 7 hr  
55.4 psig 1 hr - 8 hr  
6 psig 8 hr - 50 hr  
5 x 10<sup>6</sup> rads

Spray: None

MSLB

See above

OPERABILITY REQUIREMENTS

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

124 days @ 150°F

ACCURACY REQUIREMENTS

± .1%

ACCURACY DEMONSTRATED

± .25%

MANNER OF QUALIFICATIONLOCA & MSLE

Test

QUALIFICATION DOCUMENTLOCARosemount Test  
Report #117415MSLERosemount Test  
Report #117415FSAR Section 3C  
and response to comment 7.17QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

- A. Deficiencies:
- 1) Accuracy of variables and test data
  - 2) Test monitoring sensors
  - 3) Radiation level

## B. Solutions:

- 1) Accuracy of instrument even though not stated would commonly be  $\pm 1\%$ .
- 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
- 3) Transmitters are good for 40 yr. radiation dose plus 200 hrs. into a LOCA. Optimum solution is still being investigated.

MSLE

- A. Deficiencies:
- 1) See items 1 & 2 for LOCA.
  - 2) Temperature envelope

## B. Solutions:

- 1) See items 1 & 2 for LOCA
- 2) Qualification test of  $350^{\circ}\text{F}$  for ten minutes,  $316^{\circ}\text{F}$  for one hour whereas the environment is  $430^{\circ}\text{F}$  for two minutes, then dropping to  $250^{\circ}\text{F}$  after two minutes. The temperature environment does not exceed qualified limits due to thermal inertia and internal temperature. See calculation # 28-169.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. WA-10/1010  
 Nuclear Steam Supply System  
 Westinghouse Electric Corp.  
 Pressurizer Level Transmitter  
 LT-1459  
 LT-1460  
 LT-1461  
 LT-2459  
 LT-2460  
 LT-2461

Barton 386/752\*

Inside Containment

\*386/752 is prototype of 764.  
 Lot 1 testing is applicable to prototype.

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F	0-30 min
Reduce from 280°F to 150°F	30-60 min
150°F	>60 min
45 psig	0-30 min
Reduce from 45 to 0 psig	30-60 min
0 psig	>60 min

$7.2 \times 10^7$  rads (1)

Spray: 0.4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
 >4 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

430°F	0 to 2 min
280°F	2 to 60 min
150°F	>60 min
45 psig	0 to 30 min
Reduce from 45 to 0 psig	30 to 60 min
0 psig	>60 min

$3 \times 10^7$  rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

0 to 280°F	0-3 sec
280°F @ 75 psig	3-1200 sec
280°F-220°F	20 min to 24 hr
220°F	1 to 15 days

Radiation:  $5 \times 10^7$  rads

Spray: 1.14 wt % boric acid and 0.17 wt % NaOH dissolved in water for 24 hr

MSLB

380°F @ 75 psig  
 100% RH

Radiation:  $1.13 \times 10^5$  rads

OPERABILITY REQUIREMENTSLOCA

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)LOCA

212 days @ 150°F

ACCURACY REQUIREMENTS

±10% for ≤ 5 min

ACCURACY REQUIREMENTS

0 to 5 min <5%  
 Max. error 5 min to 4 months 17%

MANNER OF QUALIFICATIONLOCA

Test - Sequential

QUALIFICATION DOCUMENTLOCA

Westinghouse Electric Corp.

NS-TMA-1950

Anderson to Stolz

NS-TMA-2120

Anderson to Stolz

Test

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Radiation level to which equipment was qualified is below that of 40 yr plus LOCA dose.

B. Solutions:

LOCA equipment was qualified for a level of  $5 \times 10^7$  rads. This means that equipment will be able to withstand the LOCA dose of  $4.2 \times 10^7$  rads with a  $8 \times 10^6$  rads level for normal life. Therefore, since the 40 yr life is  $3 \times 10^7$  rads and this is a fairly constant rate, the equipment is qualified for greater than 10 yr. We will either obtain further qualification data or replace equipment before the 10th yr.

MSLBA. Deficiencies:

Qualified to 300°F MSLB, peak temperature is 430°F.

B. Solutions:

Temperature qualification is acceptable since temp reduced to 260°F after 2 min, due to thermal inertia, internal temperature rise stays within qualified limits. See Temperature Calculation #ES- 169

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA 10/1010  
Nuclear Steam Supply System  
Westinghouse Electric Corp.

Steam Generator Level  
(Narrow Range) transmitter

LT-1474, 2474  
LT-1475, 2475  
LT-1476, 2476  
LT-1484, 2484  
LT-1485, 2485  
LT-1486, 2486  
LT-1494, 2494  
LT-1495, 2495  
LT-1496, 2496

Rosemount #115pp4A

Inside Containment

DESCRIPTION OF ENVIRONMENT

LOCA  
280°F 0 to 30 min  
Reduce from 280°F  
to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 hrs solution of boric  
acid (2000-3100 ppm boron) buffered  
to a pH of 8.5 to 11 with NaOH > 4 hrs  
similar solution with a pH of 7 to 9.

MSLB  
4300°F 0 to 2 min  
280°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45  
to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
350°F 0 to 10 min  
316°F 10 min to 1 hr  
303°F 1 hr to 8 hrs  
230°F 8 hr to 50 hrs  
60 psig 0 to 10 min  
70 psig 10 min to 7 hrs  
55.4 psig 1 hr to 8 hrs  
0 psig 8 hr to 50 hr  
5 x 10<sup>6</sup> rads

Spray: None

MSLE

See above

OPERABILITY REQUIREMENTS

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

124 days @ 150°F

ACCURACY REQUIREMENTS

± .5%

ACCURACY DEMONSTRATED

± .25%

MANNER OF QUALIFICATION

LOCA &amp; MSLE

Test

QUALIFICATION DOCUMENTLOCARosemount Report  
# 117415MSLERosemount Report  
# 117415FSAR section 3C  
and response to comment 7.17QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA

- A. Deficiencies:
- 1) Accuracy of variables and test data
  - 2) Test monitoring sensors
  - 3) Radiation level
- B. Solutions:
- 1) Accuracy of instrument even though not stated would commonly be  $\pm 1\%$ .
  - 2) Test monitoring sensors, even though not identified, are assumed to comply with Industrial Standards for their type of application.
  - 3a) Transmitters were operational at  $5 \times 10^6$  rads, need further testing to assure compliance to the  $7.2 \times 10^7$  rads. The results of the existing testing indicate that radiation does not adversely effect the transmitter.
  - 3b) Replace with qualified transmitters.

MSLE

- A. Deficiencies:
- 1) See items 1 & 2 for LOCA.
  - 2) Temperature envelope
- B. Solutions:
- 1) See items 1 & 2 for LOCA
  - 2) Qualification test of  $350^{\circ}\text{F}$  for ten minutes,  $316^{\circ}\text{F}$  for one hour whereas the environment is  $430^{\circ}\text{F}$  for two minutes, then dropping to  $280^{\circ}\text{F}$  after two minutes. The temperature environment does not exceed qualified limits due to thermal inertia and internal temperature. Calculation #ES-1-9



EQUIPMENT DESCRIPTION & MARK NO.

P.O. No-10/1010

- Nuclear Steam Supply System
- Westinghouse Electric Corp.
- Limit Switches for Valves

- HCV-1200A,B,C - Regen H- Outlet
- HCV-2200A,B,C - Regen H- Outlet
- TV-1200 - Containment Isolation
- TV-2200 - Containment Isolation

NAWCO J6-120

Inside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant (LOCA)

- 280°F 0-30 min
- Reduce from 280°F to 190°F 30-60 min
- 190°F 460 min
- 4.5 psig 0-30 min
- Reduce from 4.5 to 0 psig 30-60 min
- 0 psig >60 min

7.2 x 10<sup>7</sup> rads (1)

Spray:

0-4 hr solution of boric acid (3000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
 >4 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

- 430°F 0 to 2 min
- 280°F 2 to 60 min
- 190°F >60 min
- 4.5 psig 0 to 30 min
- Reduce from 4.5 to 0 psig 30 to 60 min
- 0 psig >60 min

3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Heat aging @ 200°F for 300 hr, mechanical aging  
 100,000 cycles under electrical load

- 340°F 0 to 3 hr
- Reduce from 340°F to 120°F 3 to 5 hr

SEQUENCE REFERRED

- 250°F to 3-5 days
- 200°F 3.5 to 30 days
- 70 psi 0 to 8 hr
- 10 psi 8 hr to 30 days

Radiation Exposure 2.04 x 10<sup>6</sup> rads

Spray: Boric acid and water buffered to a pH of  
 10-11 with NaOH solution for 4 days, water spray  
 for 36 days, spray density = .015 g/m<sup>2</sup>/hr

MSLB

Maximum surface temperature is 285°F per BSG calculation  
 1172-SG-197-Q, dated 3/16/76, and is well below qualifi-  
 cation temperature.

Radiation Exposure - See LOCA test

OPERABILITY REQUIREMENTS

LOCA & MSLB

Valve to close within 60 sec of isolation  
 signal. Switches shall not fail so as  
 to reopen valves.

OPERABILITY DEMONSTRATED

LOCA & MSLB

Limit switches shown to operate after  
 sequential testing.

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA

Sequential Test

QUALIFICATION DOCUMENTLOCA

Report entitled:

"Qualification of NAMOO controls limit switch Mode RA-180 to IEEE Standards 344 ('75), 323 ('74), and 382 ('72)," dated 3/3/78 and revised 4/7/78

QUALIFICATION DEFICIENCIES AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

- 1) Accuracy of variables and test data
- 2) Test monitoring sensors
- 3) Test facility

B. Solutions:

- 1) Accuracy of instrument, even though not stated, would commonly be ±1%.
- 2) Test monitoring sensors, even though not identified, are assumed to comply with industrial standards for their type of application.
- 3) Test facility, even though not identified, could be determined from vendor's records.

EQUIPMENT DESCRIPTION & MAKE NO.

F.O. NA 10/1010

Nuclear Steam Supply System

Westinghouse Electric Corp.

Valve Position Switch

HCV-1201 DC Leddon

HCV-2201 DC Leddon

NAMCO D-2400X

Inside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

200°F

Reduce from 200°F to 150°F

150°F

4.5 psig

Reduce from 4.5 to 0 psig

7.2 x 10<sup>7</sup> rads (1)

Spray:

0-4 hr solution of boric acid (2000-21000 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
 24 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

430°F

280°F

190°F

4.5 psig

Reduce from 4.5 to 0 psig

0 psig

3 x 10<sup>7</sup> rads

0-30 min

30-60 min

>60 min

0-30 min

>60 min

0 to 2 min

2 to 60 min

>60 min

0 to 30 min

30 to 60 min

>60 min

OPERABILITY REQUIREMENTS

LOCA & MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATED

LOCA & MSLB

Not qualified

ACCEPTANCE REQUIREMENTS

Not required

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

Not qualified

MSLB

Not qualified

MANNER OF QUALIFICATIONLOCA & MSLB

None

QUALIFICATION DOCUMENTSLOCA & MSLB

None

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA & MSLBA. Deficiencies

- 1) NAMCO D-2400X not qualified for accident environment.

B. Solutions:

Limit switches provided for indication only and do not perform a safety function. Thus no requirements to be qualified for accident environment.

EQUIPMENT DESCRIPTION & WARE NO.

P.O. No. NA 10/1010  
Nuclear Steam Supply System  
Westinghouse Electric Corp.  
RCP Sealwater  
Return  
MOT-1350  
MOT-2350  
Limitorque

Inside Containment

DESCRIPTION OF ENVIRONMENT

LOCA  
2300°F  
Reduce from 2300°F  
to 1500°F  
45 psig  
Reduce from 45  
to 0 psig  
0 psig  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0-4 nrs solution of boric  
acid (2000-2100 ppm boron) buffered  
to a pH of 8.5 to 11 with NaOH's &  
nrs similar solution with a pH of  
7 to 9.

W/SLE  
430°F  
2500°F  
1500°F  
45 psig  
0 psig  
3 x 10<sup>7</sup> (rads)

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
Peak temp. 3400°F

59 psig  
2 x 10<sup>8</sup>

2500 ppm boric acid buffered with .2%  
NaOH.

W/SLE

as above

OPERABILITY REQUIREMENTS

120 days @ 150°F

OPERABILITY DEMONSTRATED (2)

200 days @ 150°F

ACCURACY REQUIREMENTS

Not required.

MANNER OF QUALIFICATION

LOCA &amp; MSLE

Test

QUALIFICATION DOCUMENT

NCAP-7744

NS-CE-692

QUALIFICATION DEFICIENCIES & RECOMMENDED SOLUTIONSLOCA

None

MSLEA. Deficiencies:

Temperature envelope

B. Solutions

In accordance with 79-01B "Guidelines for Evaluating Environment Qualification" page7, paragraph 4.2.1, "Equipment qualified for a LOCA environment is qualified for a MSLE environment.....".

EQUIPMENT DESCRIPTION & MAKE NO.

P.O. No-10/1010

Nuclear Steam Supply System

Westinghouse Electric Corp.

Resurizer Pressure Transmitters

- PT-1455
- PT-1456
- PT-1457
- PT-2455
- PT-2456
- PT-2457

Barton 763 (Lot 1)  
Inside Containment

DESCRIPTION OF ENVIRONMENT  
Loss of Coolant Accident (LOCA)

LOCA

2800°F 0-30 min  
 Reduce from 2800°F to 1900°F 30-60 min  
 1900°F >60 min  
 45 psig 0-30 min  
 Reduce from 45 to 0 psig 30-60 min  
 0 psig >60 min

7.2 x 10<sup>7</sup> rads (1)

Spray: 0.4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH >4 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

4300°F 0 to 2 min  
 2800°F 2 to 60 min  
 1900°F >60 min  
 45 psig 0 to 30 min  
 Reduce from 45 to 0 psig 30 to 60 min  
 0 psig >60 min

3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA

0 to 2800°F 0-3 sec  
 2800°F @ 75 psig 3-1200 sec  
 2800°F to 2200°F 20 min - 24 hr  
 2200°F 1 to 15 days

Radiation: 5 x 10<sup>7</sup> rads - Gamma  
 Spray: 1.14 wt % boric acid and 0.17 wt % NaOH dissolved water for 24 hr

MSLB

3800°F @ 75 psig  
 100% RH

Radiation: 1.13 x 10<sup>5</sup> rads - Gamma

OPERABILITY REQUIREMENTS  
LOCA & MSLB  
120 days @ 1900°F

OPERABILITY DEMONSTRATED (2)

LOCA & MSLB

212 days @ 1900°F

ACCURACY REQUIREMENTS

±10% for 5 min  
 5 min to 4 months  
 ±0.5%

ACCURACY DEMONSTRATED

5% for 5 min max.  
 Error 5 min to 4 months  
 1%

MANNER OF QUALIFICATION

Test - Sequential

QUALIFICATION DOCUMENT

Westinghouse Electric Corp.

NS-TMA-1950

Anderson to Stolz

NS-TMA-2120

Anderson to Stolz

(Test)

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Radiation level to which equipment was qualified is below that of 40 yr plus LOCA dose.

B. Solutions:

LOCA equipment was qualified for a level of  $5 \times 10^7$  rads. This means that equipment will be able to withstand the LOCA dose of  $4.2 \times 10^7$  rads with a  $8 \times 10^6$  rads level for normal life. Therefore, since the 40 yr life is  $3 \times 10^7$  rads and this is a fairly constant rate, the equipment is qualified for greater than 10 yr. We will either obtain further qualification data or replace equipment before the 10th yr.

MSLBA. Deficiencies:

Qualified to 380°F MSLB, peak temperature is 430°F.

B. Solutions:

Temperature qualification is acceptable since temp reduced to 280°F after 2 min, due to thermal inertia, internal temperature rise stays within qualified limits. See Temperature Calculation #ES- 159



EQUIPMENT DESIGNATION & MARK NO.  
P O MA-10/1010  
Nuclear Steam Supply System  
Westinghouse Electric Corp.  
RCS Wide Range Pressure Transmitters  
PT-1402  
PT-2402

Version 393 (Prototype of 7-3)

Inside Containment

DESCRIPTION OF ENVIRONMENT  
Loss of Coolant Accident (LOCA)

LOCA  
290°F 0 to 30 min  
Reduce from 290°F to 150°F 30 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45 to 0 psig 30 to 60 min  
0 psig > 60 min  
7.2 x 10<sup>7</sup> rads (1)

Spray: 0.4 hr solution of sulfuric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH; 4 hr similiar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)  
430°F 0 to 2 min  
290°F 2 to 60 min  
150°F > 60 min  
45 psig 0 to 30 min  
Reduce from 45 to 0 psig 30 to 60 min  
0 psig > 60 min  
3 x 10<sup>7</sup> rads

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA  
0 to 290°F 0 to 3 sec  
290°F @ 75 psig 3 to 1200 sec  
290°F to 220°F 20 min to 24 hrs  
220°F 1 to 15 days

Radiation: 5 x 10<sup>7</sup> rads - Gamma  
Spray: 1 lb wt % sulfuric acid and 0.17 wt % NaOH dissolved water for 24 hr.

MSLB  
390°F @ 75 psig  
100% RH

Radiation: 1.13 x 10<sup>5</sup> rads - Gamma

OPERABILITY REQUIREMENTS  
LOCA & MSLB  
120 days @ 150°F

OPERABILITY DEMONSTRATED (2)  
LOCA & MSLB  
212 days @ 150°F

ACCURACY REQUIREMENTS  
±10% for 5 min  
5 min to 4 months  
±2%

ACCURACY DEMONSTRATED  
5% for 5 min max.  
Error 5 min to 4 months  
17%

MANNER OF QUALIFICATION

Test - Sequential

QUALIFICATION DOCUMENT

Westinghouse Electric Corp.

NS-TWA-1950

Anderson to Stolz

NS-TWA-2120

Anderson to Stolz

(Test)

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCAA. Deficiencies:

Radiation level to which equipment was qualified is below that of 40 yr plus LOCA dose.

B. Solutions:

LOCA equipment was qualified for a level of  $5 \times 10^7$  rads. This means that equipment will be able to withstand the LOCA dose of  $4.2 \times 10^7$  rads with a  $8 \times 10^6$  rads level for normal life. Therefore, since the 40 yr life is  $3 \times 10^7$  rads and this is a fairly constant rate, the equipment is qualified for greater than 10 yr. We will either obtain further qualification data or replace equipment before the 10th yr.

MSLBA. Deficiencies:

Qualified to 330°F MSLB, peak temperature is 430°F.

B. Solutions:

Temperature qualification is acceptable since temp. reduced to 280°F after 2 min. due to thermal inertia, internal temperature rise stay within qualified limits. See Temperature Calculation #ES-1-9.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NA-10/1010

Nuclear Steam Supply

Westinghouse Electric Corp.

Solenoid Operator Regen Hx Outlet

HCV-1200A

HCV-1200B

HCV-1200C

HCV-2200A

HCV-2200B

HCV-2200C

ASCO #HT8300B4RU

Inside Containment

DESCRIPTION OF ENVIRONMENTLoss of Coolant Accident (LOCA)

280°F	0-30 min
Reduce from 280°F to 150°F	30-60 min
150°F	>60 min
45 psig	0-30 min
Reduce from 45 to 0 psig	30-60 min
0 psig	>60 min

7.2 x 10<sup>7</sup> rads (1)Spray:

0-4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
 >4 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

430°F	0 to 2 min
280°F	2 to 60 min
150°F	>60 min
45 psig	0 to 30 min
Reduce from 45 to 0 psig	30 to 60 min
0 psig	>60 min

3 x 10<sup>7</sup> radsENVIRONMENT TO WHICH EQUIP. IS QUALIFIEDLOCA

460°F	0 to 2 min
Reduce from 460°F to 340°F	2 to 8 min
Reduce from 340°F to 240°F	8 to 35 min
150°F	52 min to 14 days
129 psia	0 to 2 min
118 psia	2 to 32 min
Reduce from 118 to 25 psia	32 to 34 min
13.5 psia	52 min to 14 days

Radiation Exposure 5 x 10<sup>7</sup> radsMSLB

Encompassed by above LOCA test

OPERABILITY REQUIREMENTSLOCA & MSLB

120 days @ 150°F

OPERABILITY DEMONSTRATEDLOCA & MSLB

Functioned properly for 14 days at 150°F after 50 Mrad radiation exposure.

ACCURACY REQUIREMENTS

Not required

MANNER OF QUALIFICATIONLOCA & MSLB

Sequential Test

QUALIFICATION DOCUMENTSLOCA & MSLBFranklin Institute Research  
Laboratories (FIRL), Test  
Report F-C4539QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONSLOCA & MSLBA. Deficiencies:

- 1) Valves were not subjected to a chemical spray
- 2) Radiation exposure during test is below accident dose of  $4.2 \times 10^7$  rads plus 40 yr dose of  $3 \times 10^7$  rads.
- 3) Time, temperature envelope is not adequate.

B. Solutions:

- 1) Valves not subject to spray since valves will have performed their intended function prior to initiation of spray.
- 2) Replace valves inside the crane wall prior to 10.67 yr exposure. Take radiation reading for rate of dose during plant operation. These measurements will provide a more accurate exposure rate.
- 3) SOV will perform its function within 60 sec of receiving signal and will not misoperate if SOV fails due to temperature.

EQUIPMENT DESCRIPTION & MARK NO.

P.O. NW-10/1010

Nuclear Steam Supply System  
Westinghouse Electric Corp.  
Solenoid Operated Valves

LCV-1460A, B - Letdown Line Loop 1 & 2  
LCV-2460A, B - Letdown Line Loop 1 & 2  
TV-1542 - Containment Isolation  
TV-2542 - Containment Isolation  
RVC-1201 - Excessive Letdown Hx Outlet  
RVC-1201 - Excessive Letdown Hx Outlet

ASCO RT-31154

Inside Containment

DESCRIPTION OF ENVIRONMENT

Loss of Coolant Accident (LOCA)

280°F  
Reduce from 280°F to 190°F  
190°F  
4.5 psig  
Reduce from 4.5 to 0 psig  
7.2 x 10<sup>7</sup> rads (1)

0-30 min  
30-60 min  
>60 min  
0-30 min  
>60 min

Spray: 0.4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11 with NaOH  
>4 hr similar solution with a pH of 7 to 9.

Main Steam Line Break (MSLB)

430°F  
280°F  
190°F  
4.5 psig  
Reduce from 4.5 to 0 psig  
0 psig  
3 x 10<sup>7</sup> rads

0 to 2 min  
2 to 60 min  
>60 min  
0 to 30 min  
30 to 60 min  
> 60 min

OPERABILITY REQUIREMENTS

120 days @ 190°F

OPERABILITY DEMONSTRATED

None

ACTIVITY REQUIREMENTS

Not required

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

LOCA & MSLB

None

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

LOCA & SSE

A. Deficiencies:  
No qualification

B. Solutions:

Westinghouse Electric Corp.

Refer to NS-CR-755, dated August 15, 1975  
"Fail Mode Analysis for Safety-related  
Solerooid Valves in an Accident Environment"  
submitted to NRC.

QUALIFICATION DOCUMENT

LOCA & SSE

None

MANNER OF QUALIFICATION

LOCA & SSE

None

EQUIPMENT DESCRIPTION & MAKE NO.

P.O. No-10/1010

Nuclear Steam Supply System

Heatinghouse Electric Corp

Bus Temp

Wide Range RTD

- TE- 1410 2410
  - TE- 1413 2413
  - TE- 1420 2420
  - TE- 1423 2423
  - TE- 1430 2430
  - TE- 1433 2433
- Rosemount 17,435

Inside Containment

DESCRIPTION OF ENVIRONMENT

Main Steam Line Break (MSLB)

430°F

2500°F

1500°F

45 psia

Reduce from 45 to 0 psia

0 psia

3 x 10<sup>7</sup> rads

0 to 2 min

2 to 60 min

>60 min

0 to 30 min

30 to 60 min

>60 min

ENVIRONMENT TO WHICH EXITE \* IS QUALIFIED

MSLB

>3000°F @ 66 psia

Radiation 1 x 10<sup>8</sup> rads

OPERABILITY REQUIREMENTS

Two weeks post MSLB

OPERABILITY DEMONSTRATED

Two weeks post MSLB

ACCEPTANCE REQUIREMENTS

±0.2%

ACCEPTANCE DEMONSTRATED

±0.2%

MANNER OF QUALIFICATION

MSLB

Comparison to  
Rosemount 170KF

QUALIFICATION DOCUMENT

MSLB

WCAP-9157

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

MSLB

A. Deficiencies

- 1) Qualified to > 320°F peak  
Temperature is 430°F

B. Solutions:

- 1) In accordance with 79-01B  
"Guidelines for Evaluating  
Environmental Qualification",  
page 7, paragraph 4.2.1  
"Equipment qualified for a LOCA  
environment is qualified for a  
MSLB environment . . ."



EQUIPMENT DESCRIPTION & MAKE NO.

P.O. WA-10/1010

Nuclear Steam Supply System

Westinghouse Electric Corp.

RCS Temp

- TE- 1412 S, D
- TE- 1422 S, D
- TE- 1432 S, D
- TE- 2412 S, D
- TE- 2422 S, D
- TE- 2432 S, D

Rosemount 1713F

Inside Containment

DESCRIPTION OF ENVIRONMENT

Main Steam Line Break (MSLB)

- 430°F
- 2500°F
- 1500°F
- 1/2 psig
- Reduce from 1/2 to 0 psig
- 0 psig
- 3 x 10<sup>7</sup> rads

- 0 to 2 min
- 2 to 60 min
- >60 min
- 0 to 30 min
- 30 to 60 min
- >60 min

OPERABILITY REQUIREMENTS

30 sec Post MSLB

OPERABILITY DEMONSTRATED

30 sec Post MSLB

ENVIRONMENT TO WHICH EQUIP. IS QUALIFIED

MSLB

> 3000°F @ 66 psig

Radiation: 1 x 10<sup>8</sup> rads

ACCURACY REQUIREMENTS

±0.2%

ACCURACY DEMONSTRATED

± 0.2%

MANNER OF QUALIFICATION

Test - Sequential

QUALIFICATION DOCUMENT

MSLE

WCAP-9157

QUALIFICATION DEFICIENCIES  
AND RECOMMENDED SOLUTIONS

MSLE

A. Deficiencies:

Qualified to 300°F, peak temperature  
is 430°F

B. Solutions:

In accordance with 79-018 "Guidelines for  
Evaluating Environmental Qualification",  
page 7, paragraph 4.2.1, "Equipment  
qualified for a LOCA environment is  
qualified for a MELB environment....."