



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Kick

JUL 13 1982

MEMORANDUM FOR: Darrell G. Eisenhut, Director  
Division of Licensing, NRR

FROM: Edward L. Jordan, Director  
Division of Engineering and Quality Assurance, IE

SUBJECT: ONCE THROUGH STEAM GENERATOR (OTSG) EDDY CURRENT  
INSERVICE INSPECTION

The enclosed memorandum from R. R. Keimig is being forwarded to your office for appropriate action in accordance with EDO memorandum of April 13, 1982 and because the technique used in examining the transition zone in the TMI-1 heat exchangers is interesting and may have other applications.

Revision of technical specifications (TS) is not recommended for three reasons: (1) the problem is more of an operating concern than a safety concern in that failures of tubes in the transition zone will be leakage that would tend to cause plants to shut down in accordance with TS limitations rather than gross primary to secondary leakage, (2) the introduction of sulfides into the primary system is unique to TMI, and (3) Information Notice 82-14 has already been issued on the subject.

Edward L. Jordan, Director  
Division of Engineering and  
Quality Assurance  
Office of Inspection and Enforcement

Enclosure: Memo, R. R. Keimig to  
E. L. Jordan, dated May 20, 1982

cc w/enclosure:  
R. L. Baer, IE  
L. J. Cunningham, IE  
M. S. Wegner, IE

cc w/o enclosure:  
R. W. Starostecki, RI  
R. R. Keimig, RI  
F. I. Young, Res. Insp.

CONTACT: M. S. Wegner, IE  
49-24511

8506140086 850125  
PDR FOIA  
DETJEN84-897 PDR

RC(H)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUL 13 1982


MEMORANDUM FOR: Darrell G. Eisenhut, Director  
Division of Licensing, NRR

FROM: Edward L. Jordan, Director  
Division of Engineering and Quality Assurance, IE

SUBJECT: ONCE THROUGH STEAM GENERATOR (OTSG) EDDY CURRENT  
INSERVICE INSPECTION

The enclosed memorandum from R. R. Keimig is being forwarded to your office for appropriate action in accordance with EDO memorandum of April 13, 1982 and because the technique used in examining the transition zone in the TMI-1 heat exchangers is interesting and may have other applications.

Revision of technical specifications (TS) is not recommended for three reasons: (1) the problem is more of an operating concern than a safety concern in that failures of tubes in the transition zone will be leakage that would tend to cause plants to shut down in accordance with TS limitations rather than gross primary to secondary leakage, (2) the introduction of sulfides into the primary system is unique to TMI, and (3) Information Notice 82-14 has already been issued on the subject.

  
Edward L. Jordan, Director  
Division of Engineering and  
Quality Assurance  
Office of Inspection and Enforcement

Enclosure: Memo, R. R. Keimig to  
E. L. Jordan, dated May 20, 1982

cc w/enclosure:  
R. L. Baer, IE  
L. J. Cunningham, IE  
M. S. Wegner, IE

cc w/o enclosure:  
R. W. Starostecki, RI  
R. R. Keimig, RI  
F. I. Young, Res. Insp.

CONTACT: M. S. Wegner, IE  
49-24511