

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342 3840

Harold A. Glovier
Resident Manager



June 6, 1985
JAFFP-85-0492

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King Of Prussia, PA 19406

Attention: Thomas T. Martin, Director
Division of Radiation Safety and Safeguards

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT
DOCKET NO. 50-333, INSPECTION NO. 85-06

Reference: (1) NRC Letter from Mr. Thomas T. Martin
to Mr. Harold A. Glovier Dated May 10, 1985
Re: Inspection No. 50-333/85-06

(2) NYPA Letter from Mr. Harold A. Glovier
to Thomas T. Martin JAFFP-85-0474 Dated
May 30, 1985 Re: Inspection No. 50-333/85-06

The following information supplements and clarifies the Authority's response [Reference (2)] to the subject inspection [Reference (1)]:

Item B. Add immediate corrective action:

RESPONSE: The immediate corrective action was to provide guidance to the radiation protection technicians on intermittent monitoring requirements. This was accomplished via memo JRES-85-116 dated April 29, 1985.

Item B. Revise permanent corrective action, reword second paragraph:

RESPONSE: The permanent corrective action will be to provide procedural guidance to radiation protection technicians concerning requirements for intermittent monitoring. Intermittent monitoring will normally depend on the progress of work rather than specific time intervals, particularly where the progress of work could result in a change in radiological conditions. Where warranted, specific monitoring frequencies will be specified. This will be accomplished by August 31, 1985.

A handwritten signature in dark ink, appearing to read 'HAG'.

HAROLD A. GLOVIER

HAG
HAG:EAM:jaa

850614009B 850606
PDR ADOCK 05000333
G PDR

Copy: J. P. Bayne, J. C. Brons, R. A. Burns, J. J. Kelly, G. M. Wilverding,
J. A. Gray, Jr., A. Klausmann (WPO); R. J. Converse, R. L. Patch, E. Mulcahey,
C. J. Gannon, NRC Resident Inspector, NRCI-85-06 File, DCC (JAF)

1/0 IE 01