

L. J. Grier, Director  
Office of Inspection & Enforcement, Region 1  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

No. 3-80-5/3L-0

Dear Mr. Grier:

This L.E.R. refers to setpoint drift of a differential pressure switch.

The governing Technical Specification is Table 3.2.B.

POOR ORIGINAL

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A P B 5 3 (2) 0 0 - 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) \_\_\_\_\_ (5)

LICENSEE CODE 14 LICENSE NUMBER 19 LICENSE TYPE 25 ST CAT 58

01 REPORT SOURCE L (6) 0 5 0 - 0 2 7 8 (7) 0 2 0 7 8 0 (8) 0 3 0 4 8 0 (9)

60 61 DOCKET NUMBER 62 63 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During performance of a surveillance test the setpoint of DPIS 3-13-84,

03 the RCIC Turbine steam supply high flow sensor, was found to be 10

04 inches of water greater than the Tech Spec limit of 4.50 inches of water.

05 Redundant instrumentation was operable.

06 \_\_\_\_\_

07 \_\_\_\_\_

08 \_\_\_\_\_

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SURCODE VALVE SUBCODE

09 C E (11) E (12) E (13) INSTRU (14) S (15) Z (16)

27 28 29

17 REPRINT NUMBER (17) 8 0 (18) - (19) 0 0 5 (20) [ ] (21) 0 3 (22) [ ] (23) [ ] (24) 0 (25)

31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

E (26) Z (27) Z (28) Z (29) 0 0 0 0 (30) N (31) Y (32) N (33) B O S O (34)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (35)

11 The cause was setpoint drift on Barton Model 288 differential pressure

12 switch. The instrument was immediately recalibrated, tested satisfactor-

13 ily, and returned to service.

14 \_\_\_\_\_

15 \_\_\_\_\_

FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

15 E (28) 0 8 0 (29) NA (30) E (31) Surveillance Testing (32)

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

16 Z (33) Z (34) NA (35) NA (36)

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (37)

17 0 0 0 (37) Z (38) NA (39)

PERSONNEL INJURED NUMBER DESCRIPTION (40)

18 0 0 0 (40) NA (41)

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (42)

19 Z (42) NA (43)

PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY

20 N (44) NA (45)

NAME OF PREPARED BY: *[Signature]* PHONE (215) 841-5020