

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

June 10, 1985

O. W. DIXON, JR.  
VICE PRESIDENT  
NUCLEAR OPERATIONS

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Virgil Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
Deletion of Technical Specification  
Table 3.8.1


Dear Mr. Denton:

In a letter to Mr. H. R. Denton from Mr. O. W. Dixon, Jr., dated April 29, 1985, South Carolina Electric and Gas Company (SCE&G) requested a revision to the Virgil C. Summer Nuclear Station Technical Specifications to delete Table 3.8.1, "Containment Penetration Conductor Overcurrent Protective Device Test Setpoint Criteria." This letter and the attached marked-up copy of page 3/4 8-16 of the Virgil C. Summer Nuclear Station Technical Specifications are provided for further clarification of the proposed revision.

The information in Table 3.8.1 will be maintained as part of the plant design, and testing will be performed to insure that devices required for penetration protection function as designed. The surveillance requirements for these protective devices are described on the attached marked-up copy of page 3/4 8-16 of the Technical Specifications. Please replace the corresponding page in the April 29, 1985 submittal with this attached page.

Should you have any questions, please advise.

Very truly yours,



O. W. Dixon, Jr.

JAW/OWD/csw  
Attachment

cc: V. C. Summer  
T. C. Nichols, Jr./O. W. Dixon, Jr.  
E. H. Crews, Jr.  
E. C. Roberts  
W. A. Williams, Jr.  
D. A. Nauman  
J. Nelson Grace  
Group Managers  
O. S. Bradham  
C. A. Price

C. L. Ligon (NSRC)  
K. E. Nodland  
R. A. Stough  
G. O. Percival  
C. W. Hehl  
J. B. Knotts, Jr.  
H. G. Shealy  
NPCF  
File

8506140520 850610  
PDR ADOCK 05000395  
P PDR

Acc  
11