11/7/83 Letter to D. G. Eisenhut from J. F. Quirk re: GESSAR-II Fire and Flood External Event Analysis (81 pages)

8506150012 850215 PDR FOIA CURRAN84-A-66 PDR

## GENERAL ELECTRIC COMPANY PROPRIETARY INFORMATION

2.5 Quantification of Fire-Induced Accident Sequences

Table 2.5-1 presents the core damage contribution for each critical location. The total fire contribution to core damage frequency was found to be  $7.5 \times 10^{-8}/\text{yr}$  which is 1.6% of the total internal event core damage frequency (4.7x10<sup>-6</sup>).

## GENERAL ELECTRIC COMPANY PROPRIETARY INFORMATION

## 2.6 Release-Frequency Antigsis

contribution to plant risk was calcu-

lated by summing over all release categories. The calculated fire-induced contribution to plant risk was  $2.6 \times 10^{-7}$  which is 1.6 percent of the internal event plant risk.