



SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

Report Nos. 50-335/92-23 and 50-389/92-23

Licensee: Florida Power and Light Company
9250 West Flagler Street
Miami, FL 33102

Docket Nos. 50-335 and 50-389

License Nos. DPR-67 and NPF-16

Facility Name: St. Lucie 1 and 2

Inspection Conducted: November 30 - December 4, 1992

Inspector: William J. Tobin 12/14/92
William J. Tobin, Senior Safeguards Inspector Date Signed

Approved by: David R. McGuire 12/14/92
David R. McGuire, Chief Date Signed
Safeguards Section
Nuclear Material Safety and Safeguards Branch
Division of Radiation Safety and Safeguards

SUMMARY

Scope:

This routine, announced inspection was conducted in the area of the Physical Security Program for Power Reactors. Specifically, the areas inspected were Vital Area Barriers and Alarms, Lighting, Assessment, and Testing, Maintenance and Compensatory Measures.

Results:

In the areas inspected, violations or deviations were not identified. The licensee continues to have a very effective security program. Barriers, alarms, lights, cameras, as well as, repair and maintenance are outstanding. An issue was identified to track the licensee's revision of its Physical Security Plan regarding an additional exception to the required seven day tests of certain vital area alarms.

SAFEGUARDS INFORMATION

Document transmitted herewith contains sensitive unclassified information. When separated from enclosures, this document is decontrolled.

9212280060 921218
PDR ADOCK 05000335
Q PDR