



# SAFEGUARDS INFORMATION

UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II  
191 MARIEYTA STREET, N.W.  
ATLANTA, GEORGIA 30323

Report Nos. 50-250/92-33 and 50-251/92-33

Licensee: Florida Power and Light Company  
9250 West Flagler Street  
Miami, FL 33102

Docket Nos. 50-250 and 50-251

License Nos. DPR-31 and DPR-41

Facility Name: Turkey Point 3 and 4

Inspection Conducted: November 30 - December 4, 1992

Inspector: D. Thompson  
D. Thompson, Safeguards Inspector

11/23/92  
Date Signed

Approved by: D. McGuire  
D. McGuire, Chief  
Safeguards Section  
Nuclear Materials Safety and Safeguards Branch  
Division of Radiation Safety and Safeguards

11/23/92  
Date Signed

## SUMMARY

### Scope:

This routine, unannounced inspection was conducted in the areas of Physical Barriers, Intrusion Detection Alarms, Communication, Contingency Operations, Compensatory Measures, Access Control (Personnel and Vehicles), Alarm Stations, Lighting, Security Force Annual Audit, and Training and Qualification.

### Results:

In the areas inspected, violations or deviations were not identified. The licensee continues to provide strong support for the security programs, audits were a strength, as well as the continued maintenance support to re-construct equipment to pre-Hurricane Andrew conditions. Two licensee initiated drills were observed and in both drills the on duty security force was capable of responding to the contingency and neutralized the situation. The inspector noted, while conducting lighting surveys, that in some areas the protected area lighting was less than 0.2 footcandles but in compliance with the commitments of the Physical Security Plan.

9212290112 921223  
PDR ADOCK 05000250  
G PDR

## SAFEGUARDS INFORMATION

Document transmitted herewith  
contains sensitive unclassified  
information. When separated from  
enclosures, this document is decontrolled.