



**PSEG** Public Service  
Electric and Gas  
Company

80 Park Plaza, Newark, NJ 07101 / 201 430-8217 MAILING ADDRESS / P.O. Box 570, Newark, NJ 07101

Robert L. Mittl General Manager  
Nuclear Assurance and Regulation

June 12, 1985

Director of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Bethesda, MD 20814

Attention: Mr. Walter Butler, Chief  
Licensing Branch 2  
Division of Licensing

Gentlemen:

SER CONFIRMATORY ITEM 14  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354

Pursuant to our conversation with G. Thomas of the Reactor Systems Branch on May 31, 1985, regarding SER Confirmatory Item 14, the models used in performing the Hope Creek plant-specific ECCS analysis were SAFE, REFLOOD, and CHASTE.

Should you have any questions in this regard, please contact us.

Very truly yours,

C D. H. Wagner  
USNRC Licensing Project Manager

A. R. Blough  
USNRC Senior Resident Inspector

The Energy People

8506170111 850612  
PDR ADDCK 05000354  
E PDR

Boo1  
1/0