

PDR

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 15 1975

Docket No. 50-263

Karl Goller, Assistant Director for Operating Reactors, RL

MONTICELLO - PROPOSED TECH. SPEC. CHANGES TO INCORPORATE GETAB/GEXL
(TAR-1516)

Plant Name: Monticello


Docket No.: 50-263

Responsible Branch and Project Leader: ORB-2, B. Buckley

Technical Review Branch Involved: Reactor Systems

Review Status: Additional Information Required

The Monticello technical specification changes required to change from Hensch-Levy to GETAB/GEXL thermo-hydraulic limits have been reviewed by the Reactor Systems Branch. Additional information is required to evaluate the acceptability of the changes. The required additional information is identified in the enclosure.



Victor Stello, Jr., Assistant Director
for Reactor Safety
Division of Technical Review
Office of Nuclear Reactor Regulation

Enclosure:
Request for Additional
Information

cc: S. Hanauer
F. Schroeder
A. Giambusso
W. McDonald
D. Ziemann
B. Buckley
T. Novak
W. Hodges

9212290320 750515
PDR ADOCK 05000263
P PDR



REQUEST FOR ADDITIONAL INFORMATION
ON MONTICELLO TECH SPEC CHANGES (TAR-1516)

1. The APRM flux scram trip setting equation is the same as that given for 7 x 7 geometry using the Hench-Levy CHF correlation. The APRM trip setting equations should probably be changed to be consistent with the new GEXL/GETAB Analysis as was done for Quad Cities. Either provide the new form with justification for its constants or justify retaining the old form and constants with the new GEXL/GETAB Analysis.

Also, the APRM flux scram trip setting equation for the 8 x 8 fuel is different from that given for 7 x 7 fuel. Explain the difference.

2. Does the relative bundle to bundle power distribution used in the GETAB statistical analysis for Monticello remain fixed throughout the analysis? If not, how does it vary, and why? If yes, show that the peak radial power factor used is the maximum obtainable during the cycle.