

## APPENDIX A

### NOTICE OF VIOLATION

TU Electric  
Comanche Peak Steam Electric Station

Docket No. 50-445  
License No. NPF-87  
Construction Permit No. CPPR-127

During an NRC inspection conducted on November 9-13, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

10 CFR 20.201(b) requires that each licensee make or cause to be made such surveys as (1) may be necessary for the licensee to comply with the regulations in this part and (2) are reasonable under the circumstances to evaluate the extent of radiation hazards that may be present.

Contrary to the above, on November 7, 1992, workers performing in service inspection preparation work in the Unit 1 reactor containment building removed insulation from piping and used a wirebrush to remove corrosion from a valve without first having the radiation hazards associated with this work evaluated through the analysis of contamination surveys.

This is a Severity Level IV violation (Supplement IV).(445/9256-01)

Pursuant to the provisions of 10 CFR 2.201, TU Electric is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas  
this 18th day of December 1992