

NOTED

M.F.K.

March 3, 1981

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. R. B. Chewning
Regional Director
State Water Control Board
Valley Regional Office
116 North Main Street
P. O. Box 260
Bridgewater, Virginia 22812



North Anna Power Station - Noncompliance Notification

Dear Mr. Chewning:

This is to inform you of an exception to our NPDES permit that occurred at North Anna Power Station.

The daily average mass of total suspended solids discharged in the blowdown from the Unit 2 flash evaporator was determined to be 0.724 Kg for February, 1981. Station personnel suspect that this exception is due to a defective flow meter, as the concentration of total suspended solids was only 1.6 mg/l and the average flow was 0.11952 mgd. As corrective action, station personnel are going to repair the flow meter.

If you have any questions or desire additional information, please contact us.

Very truly yours,

Original Signed By

MORRIS L. BREHMER

Morris L. Brehmer, Ph.D.
Executive Manager
Environmental Services

cc: Mr. A. W. Hadder
Mr. B. R. Sylvia
Dr. J. T. Rhodes
Mr. W. W. Cameron)
Mr. W. A. Thornton)
Mr. M. F. Kadlubowski)
Mr. R. L. Birkhead)
Mr. R. J. Williams

C003
1/10

S

8108170 445