

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MNPIN 200-00000400 341111 4 5  
7 8 9 14 15 25 26 30 57 CAT 58  
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T  
01 L60500030670712838081183 9  
7 8 60 61 68 69 74 75 80  
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | During surveillance test, CV-31642, Containment Air Sample Inlet Isolation Valve,  
03 | failed to fully close on demand. Tech Spec 3.6.A.6 applies. No effect on public  
04 | health and safety since redundant valve was operable. Similar event was RO 82-12.  
05 |  
06 |  
07 |  
08 |

09 BB 11 E 12 B 13 VALVEX 14 A 15 D 16  
7 8 9 10 11 12 13 18 19 20  
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
17 83 017 03 L 0  
21 22 23 24 26 27 28 29 30 31 32  
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
A18X19 Z20 Z21 0000 N23 Y24 A25 C630 26  
33 34 35 36 37 40 41 42 43 44 47  
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | Apparent inaccuracy in training of the hard valve sea in a 1" Contromatics F.P. SW  
11 | valve. Valve seats were replaced with those of a more resilient material and the valve  
12 | tested satisfactorily. Replacement of valve seats in similar valves is contemplated.  
13 |  
14 |

15 E28 100 NA B31 Surveillance testing 32  
7 8 9 10 12 13 44 45 46 80  
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION  
16 Z33 Z34 NA NA NA 36  
7 8 9 10 11 44 45 80  
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE  
17 000 Z38 NA 39  
7 8 9 11 12 13 80  
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION  
18 000 NA 40 NA 41  
7 8 9 11 12 80  
 PERSONNEL INJURIES NUMBER DESCRIPTION  
19 Z42 NA 43  
7 8 9 10 12 80  
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION  
20 N44 NA 45  
7 8 9 10 80  
 PUBLICITY ISSUED DESCRIPTION  
 8506170578 830811  
 PDR ADOCK 05000306  
 S PDR  
 NRC USE ONLY  
 612-388-1121  
 NAME OF PREPARER A. A. Hunstad PHONE: 612-388-1121



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401  
Telephone (612) 330-5500

August 11, 1983

Regional Administrator  
Region III  
U S Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

PRAIRIE ISLAND NUCLEAR GENERATING PLANT 83-17  
Docket No. 50-306 License No. DPR-60

Inoperability of Unit 2 Containment Air  
Sample Radiation Monitor Isolation Valve

The License Event Report for this occurrence is attached.

This event is reported in compliance with Technical Specification 6.7.B.2.(b) since it placed the plant in a degraded mode as permitted by limiting conditions of operations.

*Simon Fehner for*  
David Musolf  
Manager - Nuclear Support Services

DMM/SAF/js

cc: NRC Document Control Desk (1)  
NRC Resident Inspector  
MPCA  
Attn: J W Ferman

Attachment

AUG 15 1983

1E22  
1/1  
83 RETROFIT