

Docket File



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 23, 1992

Docket No. 52-001

Mr. Patrick W. Marriott, Manager
Licensing & Consulting Services
GE Nuclear Energy
175 Curtner Avenue
San Jose, California 95125

Dear Mr. Marriott:

SUBJECT: STATUS OF GE NUCLEAR ENERGY (GE) ADVANCED BOILING WATER REACTOR
(ABWR) SHUTDOWN RISK DRAFT FINAL SAFETY EVALUATION REPORT (DFSER)

The Reactor Systems Branch (SRXB) is currently finalizing its safety evaluation report on the subject identified above. The reviewers have identified some potential open issues below, which require early dialogue with GE.

1. Reliability of power available for reactor water cleanup (RWCU) system to measure coolant temperatures. This open item regards the method used to measure water temperature at the residual heat removal (RHR) pump discharge and the RWCU system suction lines, in case of loss of all power.
2. Adequacy of the decay heat removal (DHR) system parameters monitored by the ABWR instrumentation system. This open item regards the potential applicability of the GL 88-17's recommendations for RHR system indications (e.g., pump noise, pump suction pressure, motor current, alarms, etc.).
3. GE operating procedure guidelines for conducting outage and planning.
4. Shutdown technical specifications for the ABWR.
5. Potential impact on inflatable seals due to temperature increase from loss of DHR cooling during reactor internal pumps replacement or maintenance.
6. Discussion of a director reactor pressure vessel boiling to the containment as an acceptable alternate decay heat removal method.
7. Impact on safety-related equipment from heavy loads and fuel handling in the containment during the refueling process.

280020

NRC FILE CENTER COPY

9212310122 921223
PDR ADOCK 05200001
P PDR

DF03/10

In addition, the reviewers have identified two confirmatory items:

1. Modification of a high temperature isolation feature to only isolate and bypass the filter demineralizers rather than the entire RWCU. This confirmatory item regards the potential degrading of the RWCU system if the coolant inlet temperature to the iron exchanger exceeds the resin's design temperature.
2. Modification of a manually-operated RWCU bottom drain suction valve to remote/manual air-operated valve function. This confirmatory item regards the diverse capability for operators to isolate line breaks from the control room.

Please provide this list to cognizant GE staff and contact me during the week of January 4, 1993, so that I can arrange a preliminary phone call and meeting, if necessary, to quickly resolve these concerns. I still expect evaluation inputs on shutdown risk from the Containment Systems and Severe Accident, Plant Systems, and Probabilistic Safety Assessment Branches in the near future. I will provide feedback to you next month if additional open items are identified.

Sincerely,

(Original signed by)

Chester Poslusny, Project Manager
Standardization Project Directorate
Associate Directorate for Advanced Reactors
and License Renewal
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File	PDST R/F	DCrutchfield	WTravers
PDR	WRussell, 12G18	RPierson	JNWilson
CPoslusny	TBoyce	PShea	GGrant, 17G21
RJones, 8E23	JMoore, 15B18	ACRS (10)	MRubin, 8E23

OFC:	LA:PDST:ADAR	PM:PDST:ADAR	SC:PDST:ADAR	D:PDST:ADAR
NAME:	PShea	CPoslusny:tz	JNWilson	RPierson
DATE:	12/23/92	12/23/92	12/23/92	12/23/92

GE Nuclear Energy

Docket No. 52-001

cc: Mr. Robert Mitchell
General Electric Company
175 Curtner Avenue
San Jose, California 95114

Mr. Joseph Quirk
GE Nuclear Energy
Mail Code 782
General Electric Company
175 Curtner Avenue
San Jose, California 95114

Mr. L. Gifford, Program Manager
Regulatory Programs
GE Nuclear Energy
12300 Twinbrook Parkway
Suite 315
Rockville, Maryland 20852

Director, Criteria & Standards Division
Office of Radiation Programs
U. S. Environmental Protection Agency
401 M Street, S.W.
Washington, D.C. 20460

Mr. Daniel F. Giessing
U. S. Department of Energy
NE-42
Washington, D.C. 20585

Mr. Steve Goldberg
Budget Examiner
725 17th Street, N.W.
Room 8002
Washington, D.C. 20503

Mr. Frank A. Ross
U.S. Department of Energy, NE-42
Office of LWR Safety and Technology
19901 Germantown Road
Germantown, Maryland 20874

Mr. Raymond Ng
1776 Eye Street, N.W.
Suite 300
Washington, D.C. 20006

Marcus A. Rowden, Esq.
Fried, Frank, Harris, Shriver & Jacobson
1001 Pennsylvania Avenue, N.W.
Suite 800
Washington, D.C. 20004

Jay M. Gutierrez, Esq.
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Suite 1000
Washington, D.C. 20036