

Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

December 30, 1992

HAROLD B. RAY
SENIOR VICE PRESIDENT

TELEPHONE
714-455-4400

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555


Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 127 and 111
Changes to Technical Specification 3.3.3.1, "RADIATION
MONITORING," San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application Nos. 127 and 111 to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively. These amendment applications consist of Proposed Change Number (PCN) 416. PCN-416 is a request to revise Units 2 and 3 Technical Specification (TS) 3.3.3.1, "RADIATION MONITORING." This amendment request increases the required number of plant vent stack wide range noble gas radiation monitors from 1 to 2 when either Unit 2 or 3 is in Mode 1, 2, or 3. When either Unit 2 or 3 is in Mode 4 and the other unit is in Mode 4, 5, or 6, either the plant vent stack monitor (2/3RT-7808) or both wide range gas monitors (2RT-7865-1 and 3RT-7865-1) will be required. Editorial clarifications are also made.

If you would like additional information on this Technical Specification change request, please let me know.

Sincerely,



cc: J. B. Martin, Regional Administrator, NRC Region V
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2&3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3
H. Kocol, California Department of Health Services

310033

9212310144 921230
PDR ADOCK 05000361
P PDR

Adol
1/1