

December 23, 1992

Docket No. 52-002

Mr. Charles B. Brinkman, Acting Director
Nuclear Systems Licensing
ABB-Combustion Engineering
1000 Prospect Hill Road
Windsor, Connecticut 06095-0500

Dear Mr. Brinkman:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON CESSAR-DC, SYSTEM 80+

Enclosed is a request for additional information based on a review of the System 80+ Shutdown Risk Evaluation Report. Please respond within 45 days following the receipt of this request.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,
(Original signed by)
Michael X. Franovich, Project Manager
Standardization Project Directorate
Associate Directorate for Advanced Reactors
and License Renewal
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket file	PDST R/F	TMurley/FMiraglia	WRussell
PDR	DCrutchfield	WTravers	JNWilson
RPierson	TVWambach	RBorchardt	MXFranovich
PShea	JMoore, 15B18	EJordan, MNBB3701	GGrant, EDO
ACRS (10)	ATHadani 8E2	RPerch, 8H7	GHolahan, 8E2
DDi-: 8E23			

OFC:	LA:PDST:ADAR	PM:PDST:ADAR	SC:PDST:ADAR	DD:DSSA:ADT*	D:PDST:ADAR
NAME:	PShea	MFranovich:sg	RBorchardt	ATHadani	RPierson
DATE:	12/23/92	12/23/92	12/23/92	12/18/92	12/ /92

*SEE PREVIOUS CONCURRENCE

OFFICIAL DOCUMENT COPY:

DOCUMENT NAME: SDRAI.MXF

9301040133 921223
PDR ADOCK 05200002
A PDR

INTS FILE CENTER COPY

DF03

ABB-Combustion Engineering, Inc.

Docket No. 52-002

cc: Mr. C. B. Brinkman, Acting Director
Nuclear Systems Licensing
Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095-0500

Mr. C. B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Stan Ritterbusch
Nuclear Systems Licensing
Combustion Engineering, Inc.
1000 Prospect Hill Road
Post Office Box 500
Windsor, Connecticut 06095-0500

Mr. Daniel F. Giessing
U. S. Department of Energy
NE-42
Washington, D.C. 20585

Mr. Steve Goldberg
Budget Examiner
725 17th Street, N.W.
Washington, D.C. 20503

Mr. Raymond Ng
1776 Eye Street, N.W.
Suite 300
Washington, D.C. 20006

CE SYSTEM 80+ SHUTDOWN RISK FINAL REPORT (CESDR)
REQUEST FOR ADDITIONAL INFORMATION
(REACTOR SYSTEMS BRANCH)

440.152

In Section 2.1, Procedures, ABB-CE has stated that vendor's operational guidance will be provided to instruct the plant owners in the use of the design features to detect, mitigate and assist recovery from abnormal events that can occur during shutdown. However, there is no information on how ABB-CE operational guidance will be based on the guidelines of NUMARC 91-06, or some alternate approach, or how safety functions identified in NUREG-1449 would be maintained during shutdown. Please provide a detailed discussion to address how NUMARC 91-06 guidelines, or some alternate approach, would be implemented in ABB-CE operational guidance and ABB-CE's recommendations on the implementation of the NUMARC guidelines to combined license (COL) applicants. In addition, ABB-CE operational guidelines should also address how key safety functions identified in NUREG-1449 will be maintained and provide recommendations to COL applicants to ensure that they will be maintained during shutdown.

Further, please discuss ABB-CE's recommended operating procedures guidance to COL applicants for conducting outage planning for shutdown operations. Outage planning and control should emphasize outage safety philosophy, outage scheduling, activities during high risk evolutions, defense-in-depth concept and safety margins, personnel training for outage activities, and appropriate review and approval.

440.153

Table 2.1-1 provides monitoring parameters for an unplanned draining of the reactor coolant system (RCS) using RCS level, inventory and temperature controls. In addition to the normal reactor water level indication system used during shutdown periods, is there any alternate and/or diverse method of measuring water level (e.g., ultrasonic), if the water level measuring system is not available?

440.154

Table 2.1-1, referenced report Section 2.4.3.2.2, discusses the System 80+ ac power availability as a strategy for outage maintenance during shutdown operations. There is no information on how effective outage planning and control will be achieved; and little information was given on how key safety functions (e.g., decay heat removal (DHR), reactivity, containment integrity, and electrical power) identified in NUREG-1449 will be maintained. Please provide a discussion to address how effective outage and planning can

Enclosure

be achieved (NUMARC 91-06 provides guidelines to the industry to effectively control outage activities), and how key safety functions will be maintained, including the need for a shutdown cooling system (SCS), and ac power during high decay heat loads and the later maintenance of the SCS when decay heat loads have been reduced.

440.155

CESDR, Appendix D, technical specifications (TS) for shutdown operations, defines mid-loop condition as when the RCS level is below the top of the hot legs at their junction to the vessel. The TS also define shutdown margin with a T_{ave} that is changed to $> 135^{\circ}\text{F}$ from 210°F , with the shutdown margin (SDM) being maintained at greater or equal to 6.5% delta K/K. Please provide the basis for the changes in temperature (with the same SDM), and clarify at what level below the top of the hot legs constitutes mid-loop level.

440.156

In Section 2.3.3.2, ABB-CE discusses the design features that will improve SCS performance during shutdown including an improved SCS suction piping layout which allows self venting. Provide layout detail of SCS suction nozzle interfaces with the hot leg and of the improved SCS suction piping. Discuss how the SCS suction piping interface would reduce the potential of vortex in the SCS pumps. In addition, a discussion is needed for the improved SCS piping design that allows self venting, and eliminates loop seals, thus increasing the reliability of the SCS systems. For loop seals, provide the piping configuration with respect to plant elevation that will minimize the loop seal problems. Discuss the procedural actions which will be used to minimize, mitigate, and recover from loss of the SCS pumps.

440.157

Section 2.8.3.1 discusses the instrumentation used to measure RCS level. ABB-CE employs dP-based level sensors for wide range and narrow range indication. In addition, ABB-CE also employs heated-junction-thermocouples (HJTCs). Together, ABB-CE indicates that these instruments are able to provide RCS level indication for the System 80+ from normal operating condition to shutdown for refueling. The HJTCs will not be available when the vessel head is removed and it is unclear to the staff that the wide and narrow range dP-based level sensors located at the SCS suction piping will provide accurate level measurement given possible dynamic effects due to fluctuating suction pressures when SCS pumps are in operation. Thus, the RCS level measurement method used during reduced inventory conditions may not be able to provide operators with a reliable level readings.

Provide an analysis to show that dP-based level sensors will provide accurate level readings and test results for the RCS level instrument during reduced inventory conditions. In

addition, when the reactor vessel head is off, ABB-CE has stated that temperature measurement is provided by using hot leg resistance temperature detectors (RTDs) and core exit thermocouples (CETs) (prior to fuel movement). Provide a discussion on (1) how far from the vessel that the RTDs are located on the hot leg and how accurate is the temperature measured, if SCS pumps are not running, and (2) where are CETs located in order to measure core temperature when the vessel head is off?

440-158

In Section 2.8.3.2.1, ABB-CE has stated that a second HJTC provides narrow-range level indication for mid-loop operations via measurement of reactor vessel water level in the hot leg region. The benefit of this design is that it permits very accurate measurement when the reactor vessel level is in the hot legs. Please clarify how this system can provide accurate measurement.

440.159

Section 2.8.3.2.2 discusses the RCS temperature measurement methods. ABB-CE has stated that if the SCS is lost, the CETs, the hot leg RTDs, and the HJTCs inputs are available to track the response to the loss of shutdown cooling or the approach to boiling. ABB-CE has also stated that core exit fluid temperature can be measured through the use of hot leg RTDs as long as the SCS is operable. It appears to the staff that the two statements contradict each other. Please explain.

440.160

In Section 2.8.3.2.5.5, the Nuplex 80+ component control features provide operators with the capability to actuate equipment and systems. It is not apparent to the staff that when the operator has selected a SCS cooling mode that the SCS system will automatically align valves to allow cooling. Provide a discussion to show whether or not a manual operator action is needed to align important valves for the selected mode and whether or not the design features will automatically perform important functions to reduce the possible man-machine interface errors.

440.161

In Section 2.8.3.2.5.3, the Nuplex 80+ discrete indicators are used to provide operators with information to support shutdown cooling such as inlet and outlet temperatures, and heat exchanger inlet and outlet temperatures. Please explain the difference between inlet temperature and heat exchanger inlet temperature. Are they supposed to be the same temperature which are used to indicate RCS temperatures during shutdown cooling conditions? It appears that the Nuplex 80+ design features allow heat exchanger inlet temperature readings to be indicated in the control room. However, CESSAR-DC Section 5.4.7.2.2, SCS component description indicates that the inlet heat exchanger temperatures are indicated at a remote location, and temperatures are

recorded in the control room. Please, explain the inconsistency as to where the inlet heat exchanger temperature indication is located. It is especially important that the operators have the RCS temperature readings accessible and visible within the visual range indicated in the control room.

440.162

In Section 2.3.3.3, ABB-CE has stated that given a heatup during mid-loop the pressurizer cubicle volume is sufficient for venting the RCS pressure during RCS boiling and preventing steam generator nozzle dam failure. In addition, a conservative RCS equilibrium pressure which is below the assumed steam generator nozzle dam design pressure had been calculated to occur 4 days after shutdown, indicating that the earliest time after shutdown from full power for operating at mid-loop is recommended as 4 days. Please, provide the analysis results showing that the pressurizer cubicle volume is sufficient for relieving RCS pressure and preventing nozzle dam failure. Also, provide the sensitivity study results to justify for the basis of the mid-loop operation at 4 days after the reactor had been shutdown from full power.

In addition, ABB-CE has also stated that procedural guidance regarding the earliest time after shutdown for entry into reduced inventory operation is provided in Section 2.2 of the CESDR submittal, and the time to boil assuming an initial RCS temperature of 150 F, is greater than 15 minutes. The staff is unable to confirm the incorporated information in the procedural guidance regarding the time for entry into a reduced inventory condition, and the time to boil in Section 2.2 of the submittal. Please verify the accuracy of the statement made and provide the analysis results showing the exact time to boil assuming RCS temperature at 150 F.

440.163

Table 2.4-1 indicates that an improved protection against pump excessive flow conditions is one of the many design features that increase resistance against loss of shutdown initiators. Please provide a broader discussion to address the features used to protect SCS pumps from excessive flow.

440.164

Section 2.4.3.1.3.1.1 discusses shutdown cooling recovery actions during Mode 5 for group I initiators including SCS pump suction failure and air ingestion. ABB-CE has stated that the containment spray system (CSS) pumps can be used to provide decay heat removal capability using the SCS heat exchanger. This response requires the manual operator actions to open a safety depressurization system (SDS) valve, open a normally locked-closed cross-connect valve, and the actuation of the CSS pump from the control room. This explanation is somewhat confusing to the staff. If the CSS were to be used to provide alternate decay heat

removal, it would appear that several actions need to take place: (1) operator has to isolate a normally opened CSS suction valve to the in-containment refueling water storage tank (IRWST), (2) realign the SCS system to the CSS by manually opening a normally locked-closed cross-connect valve SI-110 on the suction line to the CSS pump, and opening a normally locked-closed cross-connect valve SI-430 on the discharge line of the CSS system. In addition, opening the SDS valve to allow rapid depressurization to take place is also used with SI pumps for feed and bleed operation to achieve alternate decay heat removal capability.

Please, (1) clarify the use of the SDS valve in conjunction with the CSS pump and cross-connect valves for DHR, and (2) since manual operator actions are needed to realign valves to achieve alternate DHR, clarify what ABB-CE has done to minimize the possible operator errors (man-machine interface) in terms of requirements, control procedures, and perhaps automatic actions.

440.165

In Section 2.3.3.4 and Section 2.4, Table 2.4-3, ABB-CE has consistently stressed the available alternate makeup water sources using the boric acid storage tank (BAST) which has a total volume of 180,000 gallons, and the safety injection tanks (last line of defense) to supplement the normally preferred IRWST water source. Has ABB-CE considered the possibility of using the holdup tank as an additional alternate water source, which has a total volume of 435,000 gallons and contains the same 2.5 wt% boric acid as compared to the boric acid concentration of the BAST?

440.166

Section 2.9 indicates that a minimum IRWST level has been calculated to be "75+6." Please explain what "75+6" means. In addition, ABB-CE has stated that a conservative margin has been provided between the elevation of the suction piping openings and the minimum IRWST water level to minimize the possibility of air ingestion. Please provide a discussion to address at what elevations with respect to the minimum IRWST level that the safety injection system (SIS) suction piping are located, and your basis to support conservative margin.

440.167

Section 2.10 discusses the effects of loss of SCS with the PWR upper internals in position. ABB-CE has stated that an analysis was done to predict the extent of natural circulation flow through the upper guide structure. Please provide (1) a description of your analysis and simulation model used, (2) calculation examples, (3) justification for the assumptions made, and (4) compare your calculation method and model with the NUREG/CR-5820, "Consequences of the Loss of the Residual Heat Removal Systems in Pressurized Water

Reactors" results to justify the conservatism in your analysis. In addition, what assurance will be in place to inhibit operators to enter the refueling conditions before two days after shutdown?

440.168

In Section 2.12, ABB-CE has determined criteria for major, and minor drain paths and certain mitigative actions for loss of coolant. For example, ABB-CE has stated that for a major leak path, a preferred recovery action would be to isolate the drainage source before the RCS level reaches the break level and to add makeup to the RCS. In addition, for a minor drain path, a drain flow rate can be compensated by using available makeup, and "the identification of a minor drain path requires no further action." Some ABB-CE identified minor drain paths such as in-core instrumentation (ICI) seal table leak path, steam generator tube rupture drain path, and reactor cavity seal leak path, can result in loss of ability to maintain effective thermal heat transfer. Additionally, a loss of refueling water in case of reactor cavity seal leaks could potentially result in refueling water temperature increases due to insufficient decay heat capability; and a loss of RCS coolant in case of ICI table seal leaks or tube thimble seals failure could result in the core being uncovered. All of these minor leaks require more response than to just identify and provide makeup. ABB-CE should describe more fully the actions for minor drain path leaks.

440.169

In Section 2.12.3.1.2, ABB-CE has stated that the System 80+ ICI design does not employ temporary thimble tube seals. Please provide a description of the ICI system design and replacement process during shutdown conditions that will preclude the potential losses of RCS coolant inventory.

440.170

In Section 2.12.3.2, ABB-CE has stated that an assessment of identified leak paths was made relating to the potential flow rates, and the time it would take for the RCS water level to reach the bottom of the hot-legs. Please provide a discussion of important leak paths such as inadvertent drainage of RCS coolant through SCS systems to the IRWST, SCS relief valve discharge, etc. The discussion should quantify the anticipated volume loss of RCS coolant and the time it would take to reach the bottom of the hot-legs level, without makeup sources of water. Also, discuss how the system design would mitigate the leaks, what operator actions would be needed to mitigate the event, what operational constraints would prevent the potential leaks, and how the system design and/or operating procedures would minimize operator errors. Also, provide a discussion of System 80+ design features that have advantage over ABB-CE operating reactors.

440.171

In Section 2.6.3, Table 2.6-1, ABB-CE has identified the possible non-borated water flow paths for the rapid boron dilution events. ABB-CE has only identified one credible boron dilution event that is from the direct vessel injection (DVI) lines where the RCS leakage through the first SI check valve with a possible diluted water volume is determined to be 60 ft³. ABB-CE did not take credit for using the pressure indication in the lines and the possible diverting capability by opening valves SI-648, 638, 628, and 618 to minimize the potential dilution to the DVI injection lines. In addition, ABB-CE has also identified leakage through SIC hot legs injection check valves SI-522 and 532. However, in this scenario, APR-CE took credit for detecting pressure changes using pressure indication in the line and the ability to divert water to SIT drain and fill line. Please provide:

- (1) assumptions made for both scenarios and why credit was taken for using pressure indication and diverting water capability in one situation but not for the other,
- (2) consequences of the rapid boron dilution event from the diluted water leakage through hot legs injection check valves, if pressure indication in the lines and the diverting capability were not used, and
- (3) compare your 2-D mathematical model with the staff's steady state calculation using the NODEP-2 nodal code model (NUREG 1449, Section 6.8.3, Neutronics Analysis), and justify the conservatism in your calculation.

440.172

The staff has identified several instances of gas binding in the charging pumps suction that took place at operating plants. These events have occurred due to (1) a lower suction pressure at the operating pump in comparison to the volume control tank (VCT) pressure that allowed gas to come out of the solution coupled with the standby charging pump piping runs allowing the gas to effectively accumulate a sufficient volume to prevent the standby pump to successfully start due to air entrapment, (2) inadvertent emptying of the VCT. Provide a discussion of how the System 80+ design venting capability, construction (elevation between CVCS and pumps suction, and piping runs), and operating procedures would prevent these problems during shutdown as well as normal operating conditions. In addition, ABB-CE should address the impact of reactivity events as a result of being unable to borate the VCT due to gas binding in the boric acid transfer pumps and inadvertent emptying of the VCT.

440.173

Section 3.4.1 gives the event tree for loss of DHR in Mode 4 and discusses each branch point of the event tree. Branch point BOC (boil-off using CVCS) indicates that water can be injected into the vessel from the BAST by utilizing either charging pump or the boric acid makeup (BAMU) pumps as a backup and the BAST volume can provide up to 12 hours of boil-off. Please provide:

- (1) discussion on the BAMU pumps capability as a backup, if SCS (DHR) is not operable,
- (2) basis for the 12 hours of water available for boil-off.

440.174

The staff has identified that System 80+ does not have the capability for gravity drain from IRWST to the RCS. Provide a discussion of how CE System 80+ could provide water to the RCS to maintain core cooling in case of station blackout (SBO) and also discuss the reflux cooling capability for the System 80+ design. Discuss what actions could be taken to allow for gravity drains and ABB-CE's plans to incorporate such actions.

440.175

Section 5.3.1 indicates that the limiting break is in a bottom of the hot leg or a lower head instrument line resulting in a loss of DHR in Modes 5 and 6. Provide the basis for the break in a bottom of the hot leg or a lower instrument line as the most limiting condition in comparison to other possible pipe breaks.

440.176

Section 3.0 presents the probabilistic risk assessment (PRA) study for shutdown conditions, including mid-loop operation with the refueling cavity water level less than 23 feet above the vessel flange. It appears to the staff that loss-of-offsite power (LOOP) and SBO situations were not modeled in the event trees. The staff study indicates that LOOP and SBO situations can occur during shutdown conditions. As a result, the probability for core damage frequency during reduced inventory increases. It appears that System 80+ PRA models assumed that off-site power is always available for the entire shutdown conditions. Therefore, the availability of the emergency power is of minimal importance. Provide (1) justification for not modeling LOOP and SBO in your shutdown risk analysis, especially during mid-loop operations with water level less than 23 feet above the vessel flange, and (2) how would core damage frequency change during reduced inventory conditions, including mid-loop operation with water level in the refueling cavity less than 23 feet above the reactor vessel flange.

440.177

Table 4.0-1 and Table 4.0-2 provides requirements for the operating range of initial conditions and RCP operating conditions. How would these requirements be controlled (e.g., TS) for applicable modes?

440.178

Section 4.3.1, Total Loss of Reactor Coolant Flow, concludes that the SCS relief valves will ensure that the P-T limits for brittle fracture are not violated for transients postulated in Modes 4 or 5 with RCS temperatures below LTOP enable/disable temperatures, and Figure 4.0-1 provides initial conditions for P-T limits in modes 3 through 6 with the SCS relief valve setting at 565 psia. It appears to the staff that the operators can operate shutdown cooling at other conditions than the design initiating conditions of 350 °F and 400 psia for SCS systems. If the operators were to operate the SCS at temperatures and pressure higher than the system design initiating temperature and pressure conditions, provide (1) procedural guidance and design features to address the staff's Open Issue 5.4.3.2-2 in the System 80+ draft safety evaluation report (DSER), and (2) provide an analysis to address that the relief valve sizing design basis for overpressure protection for the SCS system is still bounded by design criteria discussed in CESSAR-DC, Section 5.2.2.

440.179

Section 4.1.2 states that to maximize the cool down rate and the time required to reach the steam generator water (SG) level trip setpoint, the events were assumed to be initiated at the minimum Mode 3 technical specification with SG water level of 25 percent wide range. Provide the basis for using SG water level of 25 percent wide range and justify the conservatism in your assumption. In addition, ADB-CE also states that the rate of cooldown for the excess feed-water flow events is less dependent upon the steam generator temperature than it is for the steamline break events. What is the difference between selecting the initial conditions to generate the lowest DNBR in coincident with the pre-trip for the steamline break event and this case.

440.180

Section 4.1.5 discusses the evaluation of steam system piping failures inside and outside containment. The evaluation indicated the minimum transient DNBR for the shutdown mode cases was greater than 2. Provide:

- (1) assumptions used for DNBR calculation, including peaking factors, pressure, flow rates, and provide the justification for the assumptions made in the analysis.
- (2) identify worst case for shutdown mode.

- 440.181 Section 4.2.8, Feedwater System Pipe Breaks, states that the energy mismatch between the primary and secondary system is very much less for events postulated to occur in shutdown modes other than for event of Section 15.2.8 of CESSAR-DC. Provide the technical basis for this assumption.
- 440.182 Section 4.6.3, Steam Generator Tube Rupture, indicates that the leakage rate could range from 0.0 to approximately 315 gallons, and at the maximum leakage rate, the operator would have more than 45 minutes to diagnose the event and take appropriate actions. Provide (1) calculation results to show that 315 gallons is a maximum leakage rate and is a limiting case, (2) basis for the 45 minutes available time for operator's actions.
- 440.183 Appendix C, Reduced Inventory Operational Guidance, Precaution 3.4, states that operations directly affecting the reactor vessel pressure boundary, i.e., ICI Seal Table Evolutions, shall be minimized during mid-loop. ABB-CE also states in CESDR, Sections 2.12.3.1.2 and 2.3.3.5 that procedural guidance prohibits In-core Instrumentation Seal Table Evolutions while the vessel head is on and mid-loop evolutions are in progress. These two statements appear to contradict each other. ABB-CE Reduced Inventory Operational Guidance would allow the seal table evolutions to take place during mid-loop operations, thus the potential loss of inventory exists. Clarify whether the operational guidance allows or prohibits seal table evolutions to be performed during mid-loop operations. If the evolutions are permitted, discuss what actions are needed to prevent the potential loss of coolant inventory.
- 440.184 Section 2.12.3.1.2 discusses the potential failure of the reactor cavity seal during Mode 6, refueling. The cavity seal can fail in some circumstances. For example, the cavity seal can be displaced during an earthquake of certain magnitudes, thus creating a total seal failure during refueling process (i.e., refueling cavity is flooded, fuel transfer gates are opened to connect with the spent fuel pool, and fuel transfer is in process, when the reactor cavity seal failure occurs). Please provide (1) time to drain to the reactor vessel flange if water is not added, (2) potential consequences to the spent fuel being transferred during the fuel transferring process, (3) radiological consequences, and (4) what actions are needed to mitigate and to maintain shutdown cooling.
- 440.185 Appendix C, Reduced Inventory Operational Guidance, Operational Guidance 4.4 provides RCS/SCS system parameters

monitored during reduced inventory. This operational guidance does not address SCS pump suction and discharge pressures as part of system parameters monitored during reduced inventory as mentioned in Section 2.8. Please, clarify.

440.186

Section 5.0, Abnormal Operating Conditions, discusses the use of the combustion turbine generator as an alternate and a diverse method to provide ac power during station blackout events to maintain shutdown cooling. However, there is no information that addresses the reliability assurance for the combustion turbine unit. Please, provide combustion turbine reliability assurance program information, availability information, and address how ABB-CE would ensure the operability (i.e., TS) of the combustion turbine unit during shutdown conditions.

440.187

ABB-CE indicated in the response to the staff RAI #440.135 that the combustion turbine will be utilized during shutdown to ensure adequate supply of ac power. This availability will be governed by a COL holder through administrative controls. Absent further information, the staff does not have assurance that said measures will be sufficient to require AAC availability of a future COL holder. The staff believes that for advanced PWR reactors that it may be appropriate to have two onsite sources of power available during reduced inventory conditions. These onsite sources of power would need to be controlled through specific shutdown TS requirements. Please define technical specifications to reflect the staff's concerns.

However, it should be noted that the staff is currently finalizing its proposed requirements for operating reactor shutdown operations, therefore, ABB-CE shutdown TS will not be reviewed at this time.

440.188

In Section 5.3, LOCA Analysis for Lower Modes of Operation, ABB-CE assumed different conditions in Mode 4. Please provide:

- (1) basis for different conditions in Mode 4, and
- (2) results from the sensitivity study to confirm that Mode 4, case 4 is the worst case.

440.189

Section 5.3 evaluates a postulated LOCA event (break in the bottom of the hot leg) in Mode 5 as a result of a loss of DHR. The postulated LOCA event analysis indicates that the water would reach the top of the active fuel in twelve minutes and the operators would have ten minutes to take actions to prevent core boiling. The Standard Review Plan (SRP), NUREG-0800 Section 6.3.8, item 19, states that operator delay time should be greater than 20 minutes. The ten

minutes provided by ABB-CE appears to be too short for preventing core boiling. Provide justification for the shorter operator delay time.

440.190

Section 5.3.1, Description of LOCA Scenario, indicates that a severe LOCA would occur at lower operating modes when the RCS temperature are reduced slightly below the temperature where no SI pumps are required to be on automatic. Provide the RCS temperature at which no SI pumps are required to be on automatic.

440.191

Section 5.3.4, LOCA Analysis for Mode 4, discusses LOCA analysis for hot rod heatup. Provide a detailed description of the assumptions made including axial power shape and RCP conditions.

440.192

In Section 5.3.3, ABB-CE has indicated that the Realistic Evaluation Model (REM) was used to study the possible impacts of a small break LOCA in Mode 4. Please, provide (1) detailed description of the assumptions made using the REM version of CEFLASH-4AS and PARCH codes.

440.193

In Section 5.3.4, LOCA Analysis for Mode 4, ABB-CE has used 10 minute time available for operator action to take credit for compliance with ECCS acceptance criteria. This assumed 10 minute time is inconsistent with SRP 6.3.8, Item 19 (see RAI question 440.190)

440.194

Section 2.6, Rapid Boron Dilution, discusses some potential boron dilution events. NUREG/CR-0105, Vol. 2, "Seventeenth Water Reactor Safety Information Meeting," identifies several potential PWR boron dilution events that ABB-CE has not discussed in Section 2.6 of the submittal. Please provide the below discussions which emphasis in the use of design features, detection, mitigation, and prevention capability and relate these to resolutions in Table 2.6-1:

- (1) addition of diluted accumulator water during shutdown due to slow leakage or blowdown thru single valve,
- (2) LOCA with diluted ECCS water from more than one accumulator or IRWST,
- (3) LOCA with sump water diluted,
- (4) uncontrolled boron dilution from CVCS during shutdown and the event of demineralized water from the purification system entered the core via the SCS system (the Belgians study),
- (5) rod ejection accident.

440.195

NUREG-1449 indicates that loss of coolant can result from the SCS pump suction relief valve opening. Please provide a discussion to address how your spring-loaded relief valve would not subject System 80+ to this vulnerability.

440.196

Please provide a list of ITAAC Tier 1 items which are essential to maintain safe operations during low power and shut-down conditions (e.g., piping configurations to support gravity drain and to eliminate loop seals, flow rates, water level, etc.)

REQUEST FOR ADDITIONAL INFORMATION
(INSTRUMENTATION AND CONTROL SYSTEM BRANCH)

1. Table 2.1-1 discusses the procedural guidance related to shutdown operations. With regard to unplanned draining of the reactor coolant, the staff notes that the heated junction thermocouple levels are not monitored.
2. In discussing the instruments to be used for monitoring RCS temperature during a loss of flow event, Table 2.1-1 lists resistance temperature detectors; which will be very inaccurate after flow is lost. It may not be appropriate to include these instruments in the parameter list for loss of flow events.
3. Table 2.4-2, Shutdown Cooling System (SCS) Instrumentation, lists the instrumentation considered by the applicant to be critical to identifying Group II initiators. Group II initiators include a failure on the discharge side of the SCS pump. An additional initiator of an impending loss of shutdown cooling is High SCS flow in the suction line caused by too much SCS pump flow. High SCS pump flow can initiate air entrainment via vortex formation during midloop operations.
4. On Page 2.8-1, the applicant states that providing an adequate fluid level in the hot leg above the level at which vortexing occurs will ensure that the SCS fluid will not entrain air. It should be pointed out that vortex formation is a function of level and flow, not just level. Vortex formation caused by excessive SCS flow on the suction side of the SCS pump is not uncommon.
5. In Table 2.8-1, the staff notes that the RCS water level reference leg tap for the Refueling Water Level Indication System is located in the top of the pressurizer. There should be one tap for each channel to preclude a SONGS-type event wherein the common reference leg tap was inadvertently blocked during a draindown operation.
6. In Table 2.8-1, RCS Temperature, the applicant appears to make a commitment that fuel shuffling activities will be scheduled in such a way as to ensure that availability of the CETs during midloop operations. This commitment should be a Tier 1 commitment, since it directly impacts the availability of temperature instrumentation.
7. In Table 2.8-1, SCS Flowrate and SCS Pump/CS Pump Discharge Pressure are alarmed on low flow and low pressure, respectively. There should also be alarms for high discharge flow and high discharge pressure, because excessive flow can result in pump cavitation and subsequent loss of SCS flow.

REQUEST FOR ADDITIONAL INFORMATION
(PROBABILISTIC SAFETY ASSESSMENT BRANCH)

1. Report the major findings and insights that were drawn from the shutdown PRA. Provide a list of shutdown PRA insights that contributed to changes in design, technical specifications, administrative controls, procedures, etc.
2. Core damage frequencies were estimated for Modes of operation 4 through 6. It is mentioned that Modes 1 through 3 are covered in the PRA performed for operation at power. However, although this may be true for forced outages, it is probably not true for planned outages. Please explain how the plant risk during Modes 2 and 3 was included in the risk estimate for power operation. Provide the assumed distribution of time among the different plant configurations (plant states) during shutdown. Also, for each plant configuration in Modes 2 and 3, provide an estimate of the frequency of initiators, any relaxation in the technical specifications, and systems or functions that are unavailable or require operator action.
3. In estimating the frequency of an initiating event while the plant is in a certain state, it was assumed that the frequency of each initiating event (as calculated by operational history of current PWR plants) can be distributed among all plant states according to the fraction of time the plant is in each configuration. However, some initiating events could occur only (or more frequently) during a particular plant state. For instance, LOCA frequency will vary with pressure and maintenance activities allowed during the various plant configurations. Similarly, loss of DHR may be more likely at the reduced inventory configuration and loss of power related frequencies may vary according to the allowed, and scheduled, maintenance activities. The affect of this assumption on the estimated core damage frequency (CDF) during shutdown must be investigated. The staff strongly recommends reviewing experience data, as well as the results of existing analyses, to resolve this issue.
4. The fractions of time that the plant is expected to be in a certain configuration (plant state) were used to estimate initiating event frequencies for the various plant states during shutdown. However, no complete information was provided on how the assumed 23-day refueling schedule was divided among plant states. In addition, the assumption of equal times in Modes 4 and 5 due to scheduled and forced outages may be optimistic. Please provide details and justification of assumptions made in determining the initiating event frequencies for the various plant states.
5. Provide a list of all dominant accident sequences that lead to core damage during plant shutdown and associated frequencies. For each sequence, list all initiating events, including failures and successes.
6. In the event tree for loss of DHR in Mode 4 (Figure 3.4-1), Technical Specifications (see Table 2.4-3, LCO 3.4.5) require: a) two RCS loops or two SCS trains or any combination of these to be operable; and b) one

RCS loop or SCS train to be in operation. This was not appropriately taken into account in the event tree. For example, in describing event OS1 it is mentioned that "if a SCS train fails, the operator will try to start the second SCS train which is required to be available by the Technical Specifications." However, this statement contradicts LCO 3.4.6 of Table 2.4-3. Similarly, in describing event SG heat removal (SGHR), it is stated that "by Tech Specs, a SG will be available if the second SCS train is out of service." This contradicts both the statement made in describing event OS1 and Table 2.4-3. Please clarify the applicable Technical Specifications and use them appropriately in the event tree model. In addition, clearly state all assumptions made in developing this event tree.

7. Please provide all information, assumptions, and sources used in determining the mechanical part of the "branch point" failure rates reported in Table 3.1-1 of the System 80+ Shutdown Risk Final Report. Information such as hourly failure rates, demand failure rates, test intervals, common cause failure rates, mission times, and assumed system configuration should be reported. Also, in determining the probabilities of the top events appearing in the event tree, it is important to keep in mind that these probabilities may be conditional on events that precede each branch point. Please discuss this issue when explaining how the "branch point" probabilities were derived.
8. One of the criteria for successful "Feed and Bleed" cooling is that it must be initiated at or before the time at which the primary safety valves lift (see page 3-16). What is the basis for this criterion? Present justification by referring to the results of related analyses. How much time does the operator have to initiate feed-and-bleed under the several accident sequence scenarios? Explain the affect that this "time window" has on the assessed probabilities and event tree model.
9. In discussing event BOC (Boil-off using CVCS), the following statement is made (page 3-17): "It was assumed that if BOC is successful, DHR is restored in the approximate 12 hours during boil-off." This statement implies that the DHR will be restored with certainty during boil-off. However, the probability of event BOC (as estimated) was assumed to be dominated by the failure probability to repair the DHR. Please remove this inconsistency. Also, the assumed 12-hour window to restore DHR needs further justification.
10. The probability of event BOC (boil-off using CVCS) has high uncertainty and appears in all dominant sequences. It is necessary to investigate the sensitivity of shutdown CDF to variations in the probability of this event. If it is found that the shutdown CDF is sensitive to such probability, then it will be necessary to further justify the assumed probability (0.1). It should be noted that the assumed probability of event BOC is dominated by the failure probability to restore DHR capability in approximately 12 hours. Given that these systems failed previously in the sequence and some repair needs to be performed on at least one of them, the assumed probability of 0.1 may be optimistic. In addition, the contribution of the unavailability of the CVCS (Tech Specs

require only one charging pump to be available) may be significant and should be calculated.

11. In the event tree for loss of DHR during Modes 5 and 6 (Figure 3.4-7), using feed-and-bleed with SCS (event SCSFB) is needed only if feed-and-bleed with SIS (event SIFB2) fails. Event SIFB2 includes failure of the Safety Injection System (SIS) as well as failure of the Safety Depressurization System (SDS). Event SCSFB includes failure of the Shutdown Cooling System injection as well as failure of the SDS. This implies that if SDS is not available for feed-and-bleed with SIS (event SIFB2) it will not also be available for feed-and-bleed with SCS (event SCSFB). Therefore, the event tree should be modified by adding a branch for the SDS function. The same is true for the event tree for LOCA Modes 5 and 6 with IRWST available (Figure 3.5-15).
12. The event tree of Figure 3.4-9 was used to model: a) the loss of DHR during Mode 5 operation when the coolant level is reduced and b) a LOCA during Mode 5 operation when the coolant level is reduced. Using the same event tree for these two initiators causes confusion (especially when no connection is made with the appropriate sections, where LOCAs, loss of DHR and reduced inventory are discussed). Please explain why the operator would "perceive" LOCAs as a loss of DHR. Does this mean that the leak will not be diagnosed prior to pump activation? How was the leak location taken into account? Is the leak recoverable? Are operator actions and associated time windows following a LOCA same as those for a loss of DHR due to other reasons? Please document all the assumptions and try to connect them with Section 2.12 (potential for draining the reactor coolant system), Section 2.3 (reduced inventory operation and GL 88-17 fixes), and Section 2.4 (loss of DHR capability).
13. How were the probabilities in the event tree of Figure 3.4-9 (loss of DHR or LOCA in Mode 5 with reduced inventory) calculated? They were assumed to be identical given either a loss of DHR or LOCA initiating event. Please justify. For example, given a LOCA, is the probability that the operator restores DHR still 0.16?
14. Event MUI ("Operator checks coolant level" in event tree of Figure 3.4-9) was assigned a probability of 4.1×10^{-3} . This includes, in addition to the human error, the probability of a mechanical failure of the SCS to make-up inventory (1.0×10^{-3}). How was this probability estimated? Does this estimate take into account the fact that a loss of DHR (or a LOCA that causes a loss of DHR) and failure of the operator to restore DHR have preceded this event? Please explain.
15. The probability of event OS1 (operator starts second DHR train) in Figure 3.4-9 is conditional on the failure of event OR (operator restores DHR) and the success of event MUI (operator uses SCS pumps to provide RCS makeup from the IRWST). How are these dependencies taken into account when assessing the probability for event OS1?
16. The success criteria for event SIFB2 in the event tree for "loss of DHR or LOCA in Mode 5 with reduced inventory" (see Figure 3.4-9) is not

clear. How many SIS trains are required for success? If two SIS trains are required (as the event tree heading suggests), then the assessed probability for this event (4.2×10^{-3}) is wrong and should be recalculated.

17. In discussing event SIFB2 (pages 3-24 and 3-25) for loss of DHR or LOCA in Mode 5 with reduced inventory, it is mentioned: "As noted in Section 3.4.1, in this mode, the pressurizer manway has been removed and opening the SDS valves is not necessary. . ." However, in Section 3.4.1, the probability of a failure of the SDS (8.0×10^{-4}) was included. Please remove this inconsistency. Also, please relate the event tree modeling of Figure 3.4-9 to the plant states and termination points for restoration of DHR (Figure 2.4-1 and Table 2.4-3). Document all assumptions made.
18. The event tree for loss of DHR in Mode 6 with the refueling cavity filled (Figure 3.4-11) does not model the effects of the potential presence in the vessel of the upper internals. Please relate this event tree model and assumptions to the criteria, analysis and resolution of the issue of the inhibition of natural circulation due to the presence of upper internals as discussed in Section 2.10 of the System 80+ shutdown risk report. Also, provide the same information for the event tree of Figure 3.4-17.
19. The event tree that models a LOCA in Mode 4 (Figure 3.4-12) is applicable when RCS temperatures are above 317 °F and pressures are above 500 psig. The low pressure and temperature part of Mode 4 is represented by the Mode 5 normal inventory event tree (Figure 3.4-15). This is not reflected in the estimates of the frequencies of the initiating events M4LOCA and M56IR. Please explain or correct this discrepancy.
20. The event trees either do not model or they lump together many of the several major plant configurations of interest to shutdown risk as identified by the termination points of Figure 2.4-1 and Table 2.4-3. For example, no distinction is made in the event tree (Figure 3.4-1) for termination points 2 and 3 (related to a loss of DHR during plant Mode 4 with RCS cold leg temperature greater than and less than 317 °F, respectively). Please explain how Figure 2.4-1 and Table 2.4-3 were used in constructing the event trees. Provide lists of all the important assumptions (implicit and explicit) that were made in constructing the event trees (for all the event tree headings by event tree).
21. The probability of event OI (operator isolates the leak locally) was assumed to be the same for leaks inside the containment as for leaks outside the containment. Justify this assumption. In addition, link the method for estimating the probability of event OI to specific leak paths, failure mechanisms, required operator actions, available procedures, monitoring parameters that alert operators upon the occurrence of a leak, and other information present in Sections 1 and 2 of the shutdown risk report.

22. The frequencies of event L60C and L61C (LOCAs in Mode 6 with refueling cavity flooded outside and inside containment, respectively) were estimated by assuming that half of the LOCAs experienced in current plants during this plant configuration occurred inside containment, and the other half occur outside containment. In view of the high sensitivity of the total shutdown core-damage frequency estimate to the frequency of event L60C (see event tree of Figure 3.4-17), please justify the assumed frequency for event L60C (5.5×10^{-3}).
23. Provide list(s) of features, human actions, technical specifications, administrative controls and procedures, by shutdown phase and plant configuration, that were found to be important in maintaining the shutdown risk levels as estimated in the PRA. Such lists could also provide part of the PRA input to reliability assurance program (RAP) and inspections, tests, analyses and acceptance criteria/design acceptance criteria (ITAAC/DAC).
24. Provide important analysis that identifies the dominant contributors to the assessed CDF during plant shutdown. Also, determine, study and characterize the dominant human errors in order to draw insights for the following:
- (i) shutdown phase/plant configuration combinations with highest human error contributions
 - (ii) any additional procedures, administrative controls and technical specifications that can be used to further reduce risk during shutdown.
 - (iii) any guidelines that can be used for outage planning that would even the risk profile and reduce overall risk during shutdown.
 - (iv) sensitivity of the shutdown CDF estimate to variations in human error probabilities.
25. Provide a clear definition of what is assumed to be a stable end-state in the event trees. Also, define mission times for the various systems and accident scenarios.
26. The PRA indicates that the refueling configuration is the most important contributor to risk during shutdown. This is not in agreement with the results of other PRAs. Please discuss the reasons for this.
27. The human error probability (HEP) estimates are not clearly documented. Please provide a concise description of the methodology used to assess human error probabilities. Also, provide clear references to tables or pages in NUREG-1278. Same HEPs were used in different event tree branch points (e.g., events OR, OS1, SIFB2, BOC) regardless of the initiators (e.g., event trees in Figures 3.4-1 and 3.4-9). This needs to be justified since HEP depends strongly on the time available for operator actions and the failures that preceded in the sequence.

28. It is not clear why the human error probabilities on page 3-29 (event SGC0M) are multiplied instead of added. It seems that an error in either one of the two required operator actions would fail the top event. Please explain or correct.
29. The number of PWR years shown in Table 3.3-1 seems high. This, if true, results in underestimation of frequencies. For example, 1412.3 reactor years from June 7, 1973, implies an average of 76 PWRs operating in that period. Please provide or refer to a list of events that were used in calculating initiating event frequencies. Categorize these events according to the plant status at the time of their occurrence. A first categorization should be among events that can occur only at power, only at shutdown and both at power and shutdown. Next, the events that can occur at shutdown should further be categorized among the various plant configurations that exist during shutdown.
30. In assessing the probability of event OI (Operator isolates leak, pages 3-27 and 3-28) it was assumed that 4 percent of the leaks caused by mechanical failures can not be isolated. However, the fraction of mechanical failures is not reported and the 4 percent assumption not justified. Please provide this information.
31. It is mentioned that the loss of offsite power events were not quantified because they are small contributors to risk. Please provide the analysis that supports your conclusion since it is quite possible that, during shutdown, on-site emergency electrical power can be degraded due to maintenance. This analysis should include maintenance downtimes at the various plant configurations.
32. Knowledge of containment integrity status when a loss of shutdown cooling has occurred is very important. The operator, in addition to taking actions for re-establishing core cooling, must be in a position to ensure containment integrity (in case core damage results). Does the System 80+ design provide any diagnostic, time tracking, procedural and/or other means to aid the operator to close containment penetrations (such as cable lines) in time? Are there any accident scenarios, associated with specific plant configurations, for which the time window for closing the penetrations is greater than the time to core boiling? Please provide related analysis.
33. Provide analyses for internal floods and fires during shutdown that are consistent with the related analyses performed for power operation (in progress at this time). This implies that similar methodologies should be used to assess the risk from internal fires and floods during shutdown as during power operation. Analyses performed for power operation, as well as their findings, can be referenced in the shutdown analyses whenever applicable.