



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-317

CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 176  
License No. DPR-53


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated September 1, 1992, as supplemented on November 11, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-53 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 176, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate 1-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 22, 1992



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20666

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 153  
License No. DPR-69


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated September 1, 1992, as supplemented on November 11, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2 of Facility Operating License No. DPR-69 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 153 hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/11  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 22, 1992

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 176 FACILITY OPERATING LICENSE NO. DPR-53

AMENDMENT NO. 153 FACILITY OPERATING LICENSE NO. DPR-69

DOCKET NOS. 50-317 AND 50-318

Revise Appendix A as follows:

Remove Pages

5-5

Insert Pages

5-5

## 5.0 DESIGN FEATURES

---

### VOLUME

5.4.2 The total water and steam volume of the Reactor Coolant System is 10,614  $\pm$  460 cubic feet at a nominal  $T_{avg}$  of 532°F.

### 5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

### 5.6 FUEL STORAGE

#### CRITICALITY - SPENT FUEL

5.6.1 The spent fuel storage racks are designed and shall be maintained with a minimum 10 3/32" x 10 3/32" center-to-center distance between fuel assemblies placed in the storage racks to ensure a  $k_{eff}$  of  $\leq 0.95$  with the storage pool filled with unborated water. The  $k_{eff}$  of  $\leq 0.95$  includes the conservative allowances for uncertainties described in Section 9.7.2 of the FSAR. The maximum fuel enrichment to be stored in the fuel pool will be 4.52 weight percent.

#### CRITICALITY - NEW FUEL

5.6.2 The new fuel storage racks are designed and shall be maintained with a nominal 18 inch center-to-center distance between new fuel assemblies such that  $k_{eff}$  will not exceed 0.95 when fuel having a maximum enrichment of 5.0 weight percent U-235 is in place and various densities of unborated water are assumed including aqueous foam moderation and full flood conditions. The  $k_{eff}$  of  $\leq 0.95$  includes the conservative allowance for uncertainties described in Section 9.7.2 of the FSAR.

#### DRAINAGE

5.6.3 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 63 feet.

## 5.0 DESIGN FEATURES

### 5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

### 5.6 FUEL STORAGE

#### CRITICALITY - SPENT FUEL

5.6.1 The spent fuel storage racks are designed and shall be maintained with a minimum 10 3/32" x 10 3/32" center-to-center distance between fuel assemblies placed in the storage racks to ensure a  $k_{eff}$  of  $\leq 0.95$  with the storage pool filled with unborated water. The  $k_{eff}$  of  $\leq 0.95$  includes the conservative allowances for uncertainties described in Section 9.7.2 of the FSAR. The maximum fuel enrichment to be stored in the fuel pool will be 4.52 weight percent.

#### CRITICALITY - NEW FUEL

5.6.2 The new fuel storage racks are designed and shall be maintained with a nominal 18 inch center-to-center distance between new fuel assemblies such that  $k_{eff}$  will not exceed 0.95 when fuel having a maximum enrichment of 5.0 weight percent U-235 is in place and various densities of unborated water are assumed including aqueous foam moderation and full flood conditions. The  $k_{eff}$  of  $\leq 0.95$  includes the conservative allowance for uncertainties described in Section 9.7.2 of the FSAR.

#### DRAINAGE

5.6.3 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 63 feet.

#### CAPACITY

5.6.4 The fuel storage pool is designed and shall be maintained with a combined storage capacity, for both Units 1 and 2, limited to no more than 1830 fuel assemblies.

### 5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.