



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 11 1984

MEMORANDUM FOR: George Knighton, Chief
Licensing Branch #3
Division of Licensing, NRR

FROM: David B. Matthews, Acting Chief
Emergency Preparedness Branch
Division of Emergency Preparedness
and Engineering Response
Office of Inspection and Enforcement

SUBJECT: REVIEW OF EMERGENCY PLAN FOR BEAVER VALLEY

We have reviewed Issue 7 of the Emergency Preparedness Plan for Beaver Valley Power Station and find that several items require resolution before we can conclude that the Beaver Valley Power Station Emergency Plan will provide an adequate planning basis for an acceptable state of onsite emergency preparedness.

We request that a letter similar to the enclosed draft with the attached review be sent to the applicant. Please provide this Branch with a copy of the final correspondence. The Emergency Preparedness Branch contact is Gerald E. Simonds (X-24870).

CPW-Niel
David B. Matthews, Acting Chief
Emergency Preparedness Branch
Division of Emergency Preparedness
and Engineering Response
Office of Inspection and Enforcement

Enclosure:

1. Draft Letter to Licensee - *release*
2. NRC Staff Review - *predecisional / not enclosed*

cc: E. L. Jordan, IE
S. A. Schwartz, IE
J. N. Grace, IE
C.-R. Van Niel, IE
F. Kantor, IE
G. E. Simonds, IE
L. M. Lazo, NRR

CONTACT: Gerald E. Simonds, IE
492-4870

8506190130 850306
PDR FOIA
GRABER84-926 PDR

S/V
~~_____~~

D R A F T

Docket No. 50-412

Gentlemen:

We have completed our review of of Issue 7 of the Emergency Plan for the Beaver Valley Power Station. Your plan was reviewed against the requirements of 10 CFR 50.47, Appendix E to 10 CFR Part 50, and the guidance criteria set forth in "Criteria for Preparation and Evaluation of Radiological Emergency Plans and Preparedness in Support of Nuclear Power Plants," NUREG-0654/FEMA-REP-1, Revision 1, November 1980. The guidance document addresses the standards set forth in these revised emergency planning regulations of 10 CFR 50.47 and has been endorsed as Regulatory Guide 1.101, Revision 2, "Emergency Planning and Preparedness for Nuclear Power Reactors."

Our review has indicated that additional information and commitment are required before we can conclude that your onsite emergency preparedness program is acceptable. Enclosed is our review which includes our comments for which resolution is necessary. Your plan should be revised to address these comments. Please submit the revised plan within 45 days of receipt of this letter.

As stated in paragraph 50.47(a)(2), the NRC will base its findings on a review of the Federal Emergency Management Agency (FEMA) findings and determinations as to whether the State and local plans are adequate and whether there is reasonable assurance that they can be implemented, and on the NRC assessment as to whether the applicant's onsite emergency plans are adequate with reasonable assurance that they can be implemented. In addition, an emergency response exercise with State and local governments designed to test the integrated capability of the emergency preparedness plans must be conducted before operation above 5% of rated power.

Sincerely,

Enclosure:
13.3 Emergency Preparedness
Evaluation