

JUN 12 1985

Docket No. 50-440

The Cleveland Electric Illuminating  
Company  
ATTN: Mr. Murray R. Edelman  
Vice President  
Nuclear Group  
Post Office Box 5000  
Cleveland, OH 44101

Gentlemen:

This refers to the routine safety inspection conducted by Messrs. D. E. Hills, G. F. O'Dwyer, S. G. DuPont and R. D. Lanksbury of this office on March 23, through May 10, 1985, of activities at Perry Nuclear Power Plant authorized by NRC Construction Permit No. CPPR-148 and to the discussion of our findings with Mr. M. D. Lyster and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in non-compliance with NRC requirements, as specified in the enclosed Appendix. A written response is required. In response to Item 1, please include responses to the concerns identified in Paragraph 2.a relating to system operation with temporary operating instructions which do not adequately resemble the corresponding system operating instructions, and systems being released for test without a list of significant events in the test package.

In accordance with the NRC's Rules of Practice for Domestic Licensing Proceedings, Title 10, Code of Federal Regulations, Part 2, Section 2.790, a copy of this letter and the enclosures will be placed in the NRC Public Document Room.

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

8506190295 850612  
PDR ADDCK 05000440  
G PDR

11 1020


Cleveland Electric Illuminating  
Company

2

JUN 12 1985

We will gladly discuss any questions you have concerning this inspection.

Sincerely,



R. L. Spessard, Director  
Division of Reactor Safety

Enclosures:

1. Appendix, Notice of Violation
2. Inspection Report No. 50-440/85017(DRS)

cc w/enclosures:

- J. J. Waldron, Manager, Perry Plant Technical Department
- M. D. Lyster, Manager, Perry Plant Operations Department
- L. O. Beck, General Supervising Engineer, Nuclear Licensing and Fuel Management Section
- DMB/Document Control Desk (RIDS)
- Resident Inspector, RIII
- Harold W. Kohn, Ohio EPA
- Terry J. Lodge, Esq.
- James W. Harris, State of Ohio
- Robert H. Quillin, Ohio Department of Health

RIII  
DEB 6/11/85  
Hills/cs  
06/10/85

RIII  
AP Ser  
O'Dwyer

RIII  
SER  
DuPont

RIII  
AP Ser  
Lanksbury

RIII  
JWA  
Ring  
6/12

RIII  
RFW  
Knop  
6/12

RIII  
JWA  
Harrison  
6/12

RIII  
JWA  
Spessard  
6/12