



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

December 29, 1992

Mr. Ken McCoy
Westinghouse Owners Group
Georgia Power Company
Birmingham, Alabama 35201

Mr. William F. Conway
Combustion Engineering Owners Group
Arizona Public Service
Phoenix, Arizona 85072-3999

Mr. P. M. Beard, Jr.
Babcock & Wilcox Owners Group
Florida Power Corporation
P. O. Box 219-NA-21
Crystal River, Florida 32629

Mr. W. T. Cottle
BWR Owners Group
Grand Gulf Nuclear Power Station
P. O. Box 756
Entergy Service Center
Port Gibson, Mississippi 39150

Gentlemen:

SUBJECT: CODE SAFETY VALVE DRIFT AND SETPOINT - STANDARD TECHNICAL
SPECIFICATIONS ACTION ITEM #98

The purpose of this letter is to confirm and describe the staff's position with regard to Code safety valve drift during operation and the resetting of valve setpoints following calibration. This issue was discussed during our executive meeting on September 17, 1992. At that time, I indicated that the standard technical specifications (STS) should incorporate the position developed for the BWR plants in response to General Electric's topical report NEDC-31753P.

On November 23, 1992, the CRGR discussed the staff's evaluation of that report, and approved a position on NEDC-31753P which is appropriate for generic implementation. Specifically, the CRGR approved a position which consists of the following relevant elements.

- A generic change of valve setpoint tolerance to $\pm 3\%$ is acceptable, provided that the plant-specific accident analysis justifies such a change.
- Licensees may propose license amendments to raise the allowable drift tolerance to $\pm 3\%$, in conjunction with a staggered testing interval (one-half of the valves at least once per 18 months and all valves within 40 months), provided that there is a requirement to conduct additional testing when a valve is found to exceed that tolerance (two additional valves for each valve found with a setpoint outside the 3% tolerance).
- All valves removed for maintenance or testing must be reset to $\pm 1\%$ prior to plant startup.

66-104

RETURN TO REGULATORY CENTRAL FILES


9301070221 921229
PDR ORG NRRB
PDR

DF03
L-4-1, Pt. 50
TEC-Spec
X RD-7-3

December 29, 1992

Upon issuance of the safety evaluation report for NEDC-31753P, which describes this position in greater detail, the staff will prepare proposed conforming changes to each of the STS for the Owners Groups' review and comment. Based on the foregoing position, we consider the subject Action Item #98 resolved.

Sincerely,



William T. Russell, Associate Director
for Inspection and Technical Assessment
Office of Nuclear Reactor Regulation

cc: W. Hall, NUMARC

December 29, 1992

Upon issuance of the safety evaluation report for NEDC-31753P, which describes this position in greater detail, the staff will prepare proposed conforming changes to each of the STS for the Owners Groups' review and comment. Based on the foregoing position, we consider the subject Action Item #98 resolved.

Sincerely,

Original Signed By

William T. Russell, Associate Director
for Inspection and Technical Assessment
Office of Nuclear Reactor Regulation

cc: W. Hall, NUMARC

DISTRIBUTION:

PDR	RJones
Central Files	TCollins
DORS R/F	MRazzaque
OTSB R/F	AEChaffee
WTRussell	GMarcus
JGPartlow	SHWeiss
BKGrimes	CLHoxie
CIGrimes	JRMiller
JERichardson	
JANorberg	
GHammer	

DOCUMENT NAME: G:SETPOINT.REV

*See previous concurrence

OTSB:DORS	ASC:OTSB:DORS	C:EMEB:DE	D:DE:NRR
JRMiller*	CLHoxie*	JANorberg*	JERichardson
12/4/92	12/4/92	12/7/92	12/7/92
C:OTSB:DORS	D:DORS:NRR	ADT:NRR	
CIGrimes	BKGrimes	WTRussell	
12/24/92	12/24/92	12/29/92	

Given the above, we consider Action List Item #98 resolved. When available, my staff will provide each of the TS owners group chairmen with a copy of the Staff's SER pertaining to our review of NEDC-31753P.

Sincerely,

William T. Russell, Associate Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission

DISTRIBUTION:

OTSB R/F	DORS R/F	Central Files	PDR
WTRussell	SHWeiss		
JGPartlow	GHMarcus		
BKGrimes	AECChaffee		
CIGrimes			
JERichardson			
JANorberg			
CLHoxie			
JRMiller			

DOCUMENT NAME: G:SETPOINT.JRM

OTSB:DORS:NRR	OTSB:DORS:NRR	C:EMEB, DE:NRR	D:DE:NRR	C:OTSB:DORS:NRR
JRMiller	CLHoxie CLH	JANorberg	JERichardson	CIGrimes
12/4/92	12/4/92	12/7/92	12/7/92	1/92
D:DORS:NRR	ADT:NRR			
BKGrimes	WTRussell			
1/92	1/92			