FILE COPY

Docket Nos. 50-325, 50-324 License Nos. DPR-71, DPR-62

Carolina Power and Light Company ATTN: Mr. R. A. Watson Senior Vice President Nuclear Generation P. O. Box 1551 Raleigh, NC 27602

Gentlemen:

SUBJECT: ENFORCEMENT CONFERENCE - BRUNSWICK

This confirms the telephone conversation between Mr. R. B. Richey of your staff and Mr. H. O. Christensen of this office on November 5, 1992, concerning an Enforcement Conference to be conducted at the Region II Office, Atlanta, Georgia on November 24, 1992, at 10:00 a.m. We requested this meeting to discuss the inadequately controlled Unit 1 reactor water level draining evolution which resulted in the inadvertent low level isolation of shutdown cooling on October 2, 1992. A proposed meeting agenda is enclosed.

Should you have any questions regarding these arrangements, we will be pleased to discuss them.

Sincerely, Original signed by: Jon R. Johnson/for

Ellis W. Merschoff, Director Division of Reactor Projects

Enclosure: Proposed Meeting Agenda

cc w/encl: R. E. Morgan Interim Manager Brunswick Nuclear Project P. O. Box 10429 Southport, NC 28461

(cc w/encl cont'd - See page 2)

9301070275 921113 PDR ADOCK 05000325 PDR IE01

(cc w/encl cont'd)
H. Ray Starling
Vice President - Legal Department
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

Kelly Holden Board of Commissioners P. O. Box 249 Eolivia, NC 28422

Chrys Baggett State Clearinghouse Budget and Management 116 West Jones Street Raleigh, NC 27603

Dayne H. Brown, Director Division of Radiation Protection N. C. Department of Environment, Health & Natural Resources P. O. Box 27687 Raleigh, NC 27611-7687

H. A. Cole Special Deputy Attorney General State of North Carolina P. O. Box 629 Raleigh, NC 27602

Robert P. Gruber Executive Director Public Staff - NCUC P. O. Box 29520 Raleigh, NC 27626-0520

Ms. Gayle B. Nichols Staff Counsel SC Public Service Commission P. O. Box 11649 Columbia, SC 29211

bcc w/encl: (See page 3)

bcc w/encl: Document Control Desk H. Christensen, RII R. Lo, NRR

NRC Resident Inspector U.S. Nuclear Regulatory Commission Star Route 1, Box 208 Southport, NC 28461

RILLARP RCarroll:tj 11//2/92

RII: DRP HChristenen 11/12/92

RII:DRP 70/ DVerrelli 11/12/92

RII:DRS RII: ELCS RII DRP Genkins AGibson JJohnson 11/12/92 11/ /92 11/13/92

ENCLOSURE

Proposed Meeting Agenda

November 23, 1992

Opening Remarks

S. D. Ebneter

II. Discussion Of The October 2, 1992, Unit 1 Reactor Water Level Oraining Event With Respect To: R. E. Morgan

- a. Inadequate Command, Control and Communications:
 - Inattentiveness and/or unawareness of draining evolution by control room operators.
 - Existence/tolerance of control room distractions (i.e., reading of nonoperational material, excessive administrative duties, etc..).
- b. Inadequate Management/Programmatic Controls:
 - Scheduling/providing clearance for the digital feedwater modification without adequately communicating, or compensating for, the disablement of the audible high/ low level annunciator.
 - Scheduled/planned use of RHR Loop B as a primary shutdown cooling method, despite a known valve deficiency.
 - Corrective actions taken on October 1, 1992, to preclude excessive vessel draining.

III. Closing Remarks

S. D. Ebceser