

LICENSEE EVENT REPORT

CONTROL BLOCK _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	M I P A L 1	2	0 0 - 0 0 0 0 0 - 0 0	3	4 1 1 1 1	4		5	
7	8	9	10	11	12	13	14	15	
LICENSEE CODE			LICENSE NUMBER			LICENSE TYPE			CAT 58

0 1	REPORT SOURCE	L	6	0 5 0 0 0 2 5 5	7	0 4 2 1 8 1	8	0 5 2 1 3 1	9
7	8	9	10	11	12	13	14	15	16
DOCKET NUMBER			EVENT DATE			REPORT DATE			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal power operation, both the primary and secondary dataloggers
 0 3 | failed. Condition is degraded mode of operation per TS 3.17, and is
 0 4 | reportable per TS 6.9.2.b2.

0 5 | Primary datalogger was restored in approximately 1.3 hours. No threat to
 0 6 | public health or safety existed. Refer to LER 81-10.

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE
7	8	9	10	11	12	13
I	D	E	A	I N S T R U	X	Z
11	12	13	14	15	16	17
LER NO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.	
17	18	19	20	21	22	23
8 1		0 1 6	0 3	L	0	
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	PRIME COMP SUPPLIER
24	25	26	27	28	29	30
B	X	Z	Z	0 0 0 0	N	N
33	34	35	36	37	38	39
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)						COMPONENT MANUFACTURER
						F 1 2 0
						44

1 0 | Primary datalogger failed due to faulty circuit board, which was replaced.
 1 1 | Secondary datalogger failure was caused by failure of typer. Replacement
 1 2 | of plant datalogging system equipment is being evaluated.

1 5	FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
7	8	9	10	11	12
E	0 9 8	N/A	A	Operator Observation	
16	ACTIVITY RELEASED	CONTENT	AMOUNT OF ACTIVITY	LOCATION OF RELEASE	
7	8	9	10	11	12
Z	Z	N/A	N/A		
17	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION		
7	8	9	10	11	12
0 0 0	Z	N/A			
18	PERSONNEL INJURIES NUMBER	DESCRIPTION			
7	8	9	10	11	12
0 0 0		N/A			
19	LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION			
7	8	9	10	11	12
Z		N/A			
20	PUBLICITY ISSUED	DESCRIPTION			
7	8	9	10	11	12
N		N/A			

NRC USE ONLY

8 1 0 6 0 2 0 3 1 3