

KANSAS GAS AND ELECTRIC COMPANY
WOLF CREEK GENERATING STATION

INSERVICE TESTING PROGRAM
FOR
PUMPS AND VALVES

REV. 4
July 19, 1985

PREPARED BY

Rocky A. Schultz

Rocky A. Schultz, IST Engineer

REVIEWED BY

C. Michael Estes

C. Michael Estes, Operations Coordinator-Projects & Planning

APPROVAL

J. A. Zell for

James A. Zell, Superintendent of Operations

8508010209 850729
PDR ADDCK 050004B2
PDR

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1.1	PIPING AND INSTRUMENTATION DIAGRAMS	2-3
3.1-1	INSERVICE VALVE TESTS	23-24
3.1-2	TEST FREQUENCY	25
		3

TABLE OF CONTENTS

	<u>Page</u>	
List of Tables	i	
1.0 INTRODUCTION	1	
2.0 TESTING PROGRAM FOR PUMPS	4	
2.1 General Information	4	
2.1.1 Applicable Code	4	
2.1.2 Pump Program Tables	4	
2.1.3 Measurement of Test Quantities	5	
2.1.4 Allowable Ranges of Test Quantities	5	
2.1.5 Instrument Accuracy	5	
2.2 Relief Requests for Pump Testing Program	6	
3.0 TESTING PROGRAM FOR VALVES	19	3
3.1 General Information	19	
3.1.1 Applicable Code	19	
3.1.2 Valve Program Tables	19	
3.1.3 Measurement of Test Quantities	21	
3.1.4 Allowable Ranges of Test Quantities	21	
3.1.5 Instrument Accuracy	22	
3.2 Relief Requests for Valve Testing Program	26	
Appendix A - Pump Testing Program	49	3
Appendix B - Valve Testing Program	52	3

1.0

INTRODUCTION

The Wolf Creek Generating Station ASME Inservice Testing Program for Pumps and Valves will be in effect through the first 120 month inspection period and will be updated in accordance with the requirements of 10CFR 50.55a(g).

This document outlines the inservice testing (IST) program based on the requirements of Section XI of the ASME Boiler & Pressure Vessel Code, 1980 Edition through the Winter 1981 Addenda. All references to IWP or IWV, respectively, of ASME Section XI, reflect the 1980 Edition through the Winter 1981 Addenda, unless otherwise noted.

The inservice inspection (ISI) classification boundaries are identical to the design classification or quality group boundaries shown on the plant piping and instrument diagrams (P&IDs) listed in Table 1.1. Some pumps and valves within the ISI boundaries are identified as non-classed (NC). This IST program was developed using the ISI classification boundaries and the following documents:

Title 10, Code of Federal Regulations, Part 50, paragraph 50.55a(g).

NRC Regulatory Guides Division 1

Standard Review Plan 3.9.6, "Inservice Testing of Pumps and Valves"

Division 1 (draft) Regulatory Guide and Value/Impact Statement, "Identification of Valves for Inclusion in Inservice Test Programs"

"NRC Staff Guidance for Preparing Pump and Valve Testing Programs and Associated Relief Request," January 1978

Fin 1 Safety Analysis Report, Wolf Creek Generating Station

Technical Specifications, Wolf Creek Generating Station

The inservice tests identified in this program will verify the operational readiness of pumps and valves whose functions are required to mitigate the consequences of an accident or to bring the reactor to a cold shutdown condition.

Table 1.1
PIPING AND INSTRUMENTATION DIAGRAMS

<u>SYSTEM</u>	<u>P&ID</u>	
MAIN STEAM SYSTEM	M-12AB01 M-12AB02	3
MAIN FEEDWATER SYSTEM	M-02AE01 M-02AE02	
AUXILIARY FEEDWATER SYSTEM	M-12AL01	3
REACTOR COOLANT SYSTEM	M-12BB01 M-12BB02 M-02BB03 M-12BB04	3
CHEMICAL & VOLUME CONTROL SYSTEM	M-12BG01 M-12BG02 M-12BG03 M-12BG04 M-12BG05	3
REACTOR MAKE-UP WATER SYSTEM	M-12BL01	3
STEAM GENERATOR BLOWDOWN SYSTEM	M-02BM01	
BORATED REFUELING WATER STORAGE SYSTEM	M-12BN01	3
FUEL POOL COOLING AND CLEAN-UP SYSTEM	M-12EC01 M-02EC02	3
ESSENTIAL SERVICE WATER SYSTEM	M-K2EF01 M-02EF01 M-02EF02	
COMPONENT COOLING WATER SYSTEM	M-12EG01 M-12EG02 M-02EG03	3
RESIDUAL HEAT REMOVAL SYSTEM	M-12EJ01	3
HIGH PRESSURE COOLANT INJECTION SYSTEM	M-02EM01 M-12EM02	3
CONTAINMENT SPRAY SYSTEM	M-02EN01	
ACCUMULATOR SAFETY INJECTION SYSTEM	M-02EP01	
AUXILIARY TURBINES-AUXILIARY FEEDWATER PUMP TURBINE	M-12FC02	3

Table 1.1
PIPING AND INSTRUMENTATION DIAGRAMS (continued)

<u>SYSTEM</u>	<u>P&ID</u>	
CONTAINMENT HYDROGEN CONTROL SYSTEM	M-12GS01	3
CONTAINMENT PURGE SYSTEM	M-12GT01	3
LIQUID RADWASTE SYSTEM	M-12HB01	3
DECONTAMINATION SYSTEM	M-02HD01	
EMERGENCY FUEL OIL SYSTEM	M-12JE01	3
COMPRESSED AIR SYSTEM	M-02KA01 M-02KA02 M-02KA05	
CONTAINMENT BREATHING AIR	M-12KB01	3
FIRE PROTECTION SYSTEM	M-02KC02	
STANDBY DIESEL GENERATOR	M-02KJ01 M-12KJ02 M-02KJ03 M-02KJ04 M-12KJ05 M-02KJ06	3
REACTOR BUILDING AND HOT MACHINE SHOP FLOOR AND EQUIPMENT DRAIN SYSTEM	M-12LF03 M-02LF09	3
NUCLEAR SAMPLING SYSTEM	M-12SJ01 M-12SJ04	3

2.0 INSERVICE TESTING PROGRAM FOR PUMPS

2.1 General Information

2.1.1 Applicable Code

This testing program for ISI Class 1, 2 and 3 pumps meets the requirements of Subsection IWP of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter of 1981 Addenda. Where these requirements are determined to be impractical, specific requests for relief have been written and included in Section 2.2.

2.1.2 Pump Program Tables

The tables in Appendix A list all pumps included in the Wolf Creek Generating Station (WCGS) IST Program. Data contained in these tables identifies those pumps subject to inservice testing, the inservice test quantities to be measured, the inservice testing frequency, and any applicable remarks. The column headings are listed and explained below:

PUMP IDENTIFICATION

PUMP NUMBER: The pump identification number.

SYSTEM: The system of which the pump is a component.

ISI CLASS: The ISI classification of the pump.

P&ID NUMBER: The WCGS drawing number for the P&ID referring to the pump.

P&ID COORD: The drawing coordinate location of the pump on the P&ID.

ISI REQUIREMENTS

PUMP SPEED, INLET (SUCTION) PRESSURE, DIFFERENTIAL PRESSURE (ΔP), FLOW RATE, VIBRATION, BEARING TEMPERATURE AND LUBRICANT LEVEL OR PRESSURE: When the word "YES" appears in a particular test quantity column, that quantity will be measured during inservice testing in accordance with Subsection IWP. If a modified test is planned or a test is being waived, a request for relief number will appear in the test quantity column referencing the pump relief request. Requests for relief are identified as PR-X, where X is the sequential number of the relief. The requests for relief are included in Section 2.2.

2.1.3

Measurement of Test Quantities

SPEED: Per IWP-4400, shaft speed need not be measured for pumps directly coupled to synchronous or induction type motor drivers. For variable speed pumps, the pump speed is set at the reference speed per IWP-3100.

INLET (SUCTION) PRESSURE: For submerged pumps, inlet pressure will be calculated (using appropriate correction factors) from a measured tank or basin level. All other inlet pressure measurements will be taken using pressure instruments at or near the pump inlet.

DIFFERENTIAL PRESSURE: Differential pressure will be calculated from inlet and discharge pressure measurements or by direct differential pressure measurement.

FLOW RATE: Flow rate will be measured using a rate or quantity meter installed in the pump test circuit.

VIBRATION: Pump vibration will be measured with one of the instruments referenced in IWP-4520.

BEARING TEMPERATURE: Pump bearing temperature(s) will not be measured. (Relief Request PR-1)

LUBRICANT LEVEL OR PRESSURE: Pump lubricant level or pressure will be observed during each inservice test when applicable.

2.1.4

Allowable Ranges of Test Quantities

The allowable ranges specified in Table IWP-3100-2 will be used for differential pressure, flow and vibration measurements with the following exceptions. The Acceptable Range (on the high side) for differential pressure (DP) and flow (Q) shall be 1.05 times the reference value. The Alert Range (High Values) shall be > 1.05 times the reference value for differential pressure and flow. Also for DP and Q the Required Action Range (High Values) will not be used. Should a measured test quantity fall outside the allowable range, the possibility of defining an expanded allowable range, in accordance with ASME Code interpretation XI-1-79-19, will be investigated.

2.1.5

Instrument Accuracy

Allowable instrument accuracies are given in Table IWP-4110-1. If the accuracies of the station's instruments are not acceptable, temporary instruments meeting those requirements in Table IWP-4110-1 will be used.

SECTION 2.2

RELIEF REQUESTS FOR PUMP TESTING PROGRAM

RELIEF REQUEST NO. PR-1

PUMPS:

PAL01 A and B, Motor Driven Aux. Feedwater Pumps; PAL02, Turbine Driven Aux. Feedwater Pump; PBG02 A and B, Boric Acid Transfer Pumps; PBG05 A and B, Centrifugal Charging Pumps; PEC01 A and B, Fuel Pool Cooling Pumps; PEF01 A and B, Essential Service Water Pumps; PEG01 A, B, C and D, Component Cooling Water Pumps; PEJ01 A and B, Residual Heat Removal Pumps; PEM01 A and B, Safety Injection Pumps; PEN01 A and B, Containment Spray Pumps; PJE01 A and B, Emergency Fuel Oil Transfer Pumps.

CLASS:

ISI Class 2 and 3

TEST REQUIREMENT:

The temperature of all centrifugal pump bearings outside the main flow path shall be measured at points selected to be responsive to changes in the temperature of the bearing. (IWP-4310)

BASIS FOR RELIEF:

- a) Bearings of certain pumps addressed in this relief request are cooled by their respective process fluid. Thus, bearing temperature measurements would be highly dependent on the temperature of the cooling medium.
- b) Bearing temperature taken at one-year intervals provide little data toward determining the incremental degradation of a bearing or providing any meaningful trend information.
- c) All pumps addressed by this relief request, except for the Emergency Fuel Oil Transfer Pumps, are subjected to vibration measurements on a quarterly basis in accordance with Subsection IWP-4500. Vibration measurements are a significantly more reliable indication of pump bearing degradation than are temperature measurements.

In summary, other measurable parameters are more indicative of pump performance and in some instances the measured temperature does not represent the actual bearing temperature. Therefore, pump bearing temperature will not be measured.

ALTERNATE TESTING:

None

RELIEF REQUEST NO. PR-2

PUMPS:

PAL01 A and B, Motor Driven Aux. Feedwater Pumps; PAL02, Turbine Driven Aux. Feedwater Pump; PBG02 A and B, Boric Acid Transfer Pumps; PBG05 A and B, Centrifugal Charging Pumps; PEC01 A and B, Fuel Pool Cooling Pumps; PEF01 A and B, Essential Service Water Pumps; PEG01 A, B, C and D, Component Cooling Water Pumps; PEJ01 A and B, Residual Heat Removal Pumps; PEM01 A and B, Safety Injection Pumps; PEN01 A and B, Containment Spray Pumps; PJE01 A and B, Emergency Fuel Oil Transfer Pumps.

CLASS:

ISI Class 2 and 3

TEST REQUIREMENT:

After completion of a pump test, test results shall be analyzed within 96 hours. (IWP-3220)

BASIS FOR RELIEF:

Test results are initially approved by on shift personnel using the acceptance criteria contained in the test to prove equipment operability. The analyzation of results for degradation requiring increased testing or engineering evaluation will then occur when the appropriate people are available for reviewing the IST. Appropriate personnel are not readily available for reviewing IST test results.

ALTERNATE TESTING:

Test data will be reviewed within four (4) working days following the | 3 test. Weekends (starting at 4:00 p.m. on the proceeding and ending at 8:00 a.m. the day following the weekend) and holidays will be excluded from the 96 hour time frame.

RELIEF REQUEST NO. PR-3

PUMPS:

PEFO1 A and B, Essential Service Water Pumps; PJE01 A and B, Emergency Fuel Oil Transfer Pumps.

CLASS:

ISI Class 3

TEST REQUIREMENT:

Measure pump inlet pressure before starting the pump and during the test.
(Table IWP-3100-1)

BASIS FOR RELIEF:

The essential service water and emergency fuel oil pumps are submerged and the pump inlet pressures are assumed to correspond to that of the static head of the medium in which the pumps reside. Since these levels remain essentially constant through the duration of the tests, only one measurement is required.

ALTERNATE TESTING:

For the ESW and emergency fuel oil transfer pumps, a single suction pressure will be calculated for each test based on the submergence of the pump.

RELIEF REQUEST NO. PR-4

PUMPS:

PJE01 A and B, Emergency Fuel Oil Transfer Pumps

CLASS:

ISI Class 3

TEST REQUIREMENT:

Pump vibration shall be measured during each Inservice Test. (IWP-3100)

BASIS FOR RELIEF:

The emergency fuel oil transfer pumps are submerged within the diesel fuel oil tanks, thus are inaccessible. Therefore, vibration measurement is impractical.

ALTERNATE TESTING:

None

RELIEF REQUEST NO. PR-5

PUMPS:

PBG02 A and B, Boric Acid Transfer Pumps; PJE01 A and B, Emergency Fuel Oil Transfer Pumps.

CLASS:

ISI Class 3

TEST REQUIREMENT:

Proper lubricant level or pressure shall be observed during each Inservice Test. (IWP-3100)

BASIS FOR RELIEF:

The Boric Acid Transfer Pumps and the Emergency Fuel Oil Transfer Pumps are canned motor-pumps. These pumps are continuously lubricated by their process fluid when the pump is running. There are no gauges installed to indicate lubricant level or pressure and it would be impractical to do so. Therefore, lubricant level or pressure will not be observed.

ALTERNATE TESTING:

None

RELIEF REQUEST NO. PR-6

PUMPS:

PBG02 A and B, Boric Acid Transfer Pumps

CLASS:

ISI Class 3

TEST REQUIREMENT:

Pump vibration shall be measured during each Inservice Test. On close-coupled pumps, the measurement point shall be as close as possible to the inboard bearing. (IWP-4510)

BASIS FOR RELIEF:

These are canned motor-pumps which have process fluid lubricated sleeve bearings. The process fluid has a damping effect such that vibration measurement, taken on the pump casing at the bearing sleeves, will not give true indication of actual vibration.

ALTERNATE TESTING:

Vibration measurements will be taken on the pumps' suction and discharge piping for indication of pump bearing degradation.

RELIEF REQUEST NO. PR-7

PUMPS:

PJE01 A and B, Emergency Fuel Oil Transfer Pumps

CLASS:

ISI Class 3

TEST REQUIREMENT:

Pump test results shall be analyzed per IWP-3200.

BASIS FOR RELIEF:

The ASME recognizes that the characteristics of systems containing other than steam or water (e.g. fuel oil) may not necessarily lend themselves to the type and detailed requirements of the testing as specified by Subsection IWP. This is so stated in the ASME response to WPPSS inquiry, File No. BC 77-666/NI 77-371 dated 1/8/79. In cases where test data is erratic or questionable, strict compliance with IWP-3200 could result in excessive testing of the pumps or needless maintenance.

ALTERNATE TESTING:

Analysis of quarterly test data will be based on IWP-3200. In those cases where the test results are erratic or could be misleading, the vendor will be contacted and an engineering evaluation made as to the necessity to develop new acceptance criteria.

RELIEF REQUEST PR-8

PUMPS:

PAL01 A and B, Motor Driven Aux. Feedwater Pumps; PAL02, Turbine Driven Aux. Feedwater Pump; PBG02 A and B, Boric Acid Transfer Pumps; PBG05 A and B, Centrifugal Charging Pumps; PJE01 A and B, Emergency Fuel Oil Transfer Pumps.

CLASS:

ISI Class 2 and 3

TEST REQUIREMENT:

Flow rate shall be measured using a rate or quantity meter installed in the pump test circuit. (IWP-4600)

BASIS FOR RELIEF:

- a) There is no flow instrumentation installed in the test flow path for the pumps listed above.
- b) All of the pump tests will be performed with the system lined up in a recirculation flow path or fixed resistance flow path. Therefore, system flow characteristics will be the same for each test.
- c) In a fixed resistance system (pump running in a recirculation test flow path) pump differential pressure is indicative of pump performance.

For the reasons stated above flow rates will not be measured.

ALTERNATE TESTING:

Pump suction and discharge pressure will be measured and differential pressure calculated instead of flow rate measurement for the Motor Driven and Turbine Driven Aux. Feedwater Pumps, Boric Acid Transfer Pumps, Centrifugal Charging Pumps, and the Emergency Fuel Oil Transfer Pumps.

RELIEF REQUEST NO. PR-9

PUMPS:

PEF01 A and B, Essential Service Water Pumps

CLASS:

ISI Class 3

TEST REQUIREMENT:

On a pump coupled to the driver the vibration measurement shall be taken on the bearing housing near the coupling. (IWP-4510)

BASIS FOR RELIEF:

The essential service water pumps are vertical, multistage pumps submerged in their process fluid and thus are inaccessible. Therefore, vibration measurement is impractical.

ALTERNATE TESTING:

Vibration measurements will be taken on the pumps' associated motor bearing housing for indication of pump bearing degradation.

RELIEF REQUEST NO. PR-10

PUMPS:

PJE01 A and B, Emergency Fuel Oil Transfer Pumps

CLASS:

ISI Class 3

TEST REQUIREMENT:

When measurement of bearing temperature is not required, each pump shall be run at least 5 min under conditions as stable as the system permits. [IWP-3500(a)]

BASIS FOR RELIEF:

The Emergency Fuel Oil Day Tanks have an automatic pump shutoff corresponding to a certain level of oil. The pumps would have reached the level of automatic pump shutoff before the 5 minutes had elapsed. Therefore a 5 min. pump run time is impractical.

ALTERNATE TESTING:

The Emergency Fuel Oil Transfer Pumps will be run for 30 seconds before specified measurements are recorded.

RELIEF REQUEST NO. PR-11

PUMPS:

All pumps

CLASS:

ISI Class 2 and 3

TEST REQUIREMENT:

The allowable ranges of inservice test quantities in relation to the reference values are tabulated in Table IWP-3100-2. This table limits the acceptable performance of each pump dependent variable (flowrate or differential pressure) to a maximum of 103 percent of the respective reference value. If the test parameter should exceed this limit, it shall be declared inoperative and removed from service. (IWP-3200)

BASIS FOR RELIEF:

The requirement to declare a pump inoperative when a test parameter exceeds the reference value by 3 percent is not technically justified, sound engineering judgement, nor acceptable plant operating practice for the following reasons:

- Indiscriminately declaring safety system pumps inoperative results in excessive and unneeded testing of other plant safeguard systems and components. Such testing could ultimately detract from the overall reliability of the plant safety systems. In addition, unwarranted testing unnecessarily adds to the burden of the operations force and dilutes efforts focused on the performance of their primary duties. Also, operators are subjected to additional, and unnecessary radiation exposure.
- The case where a test parameter exceeds the reference value is not necessarily indicative of pump degradation. It may merely signify that the reference value is probably at the lower side of the statistical scatter of the test data and the specific test in question is on the upper side. Note that the reference values are subject to the same elements of statistical error associated with any other individual test.

RELIEF REQUEST NO. PR-11 (CONT)

- The 3-percent limitation is overly restrictive when compared to the accuracy of the instrumentation used to gather the test data. Analysis has shown that, in order to consistently remain below the 3-percent limit, instrument loop accuracies in the range 0.5 to 0.75 percent would be required. This represents a significantly more restrictive requirement than that established by Paragraph IWP-4110 (± 2 percent).
- Power plant operating systems are not configured in a manner that provides the laboratory-type conditions demanded to meet the repeatability implied by the 3-percent restriction. Several of the tests require throttling with large gate or butterfly valves using remote manual control. Thus, non-quantifiable system flow conditions are created that are certain to affect measured test quantities.
- To ensure that reference values do not reflect operations at the lower end of the performance spectrum and, thus, ultimately be reflected in frequently exceeding the upper performance limits as a result of instrument drift, all related instrumentation is calibrated on a frequent basis.
- This requirement provides no additional measure of reliability to the equipment.
- When the upper limits are exceeded, the only reasonable way of correcting the inoperative condition is to conduct an analysis to ensure that the pump is indeed operable and capable of meeting its intended function. When this is done, in accordance with Subsubarticle IWP-3230 (c), a new reference value must be established. Due to the test conditions and methods of testing at WCGS, any change in the reference point eliminates the correlation of future test results with past pump performance. Because, the usefulness of any past data in determining a trend for pump performance is essentially eliminated a primary goal and basis for the inservice testing program could be jeopardized.

ALTERNATE TESTING:

Pumps will be tested in accordance with Subsection IWP with the following exceptions:

- a) The Required-action range (HIGH) will be eliminated for test quantities flowrate and differential pressure; and
- b) The Alert-range (HIGH) will be above a value equal to 105 percent of the reference value for test quantities of flowrate and differential pressure.

3.0 INSERVICE TESTING PROGRAM FOR VALVES

3.1 General Information

3.1.1 Applicable Code

This testing program for ISI Class 1, 2, 3, and NC valves meets the requirements of Subsection IWB of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter 1981 Addenda. Where these requirements are determined to be impractical, specific requests for relief have been written and included in Section 3.2.

3.1.2 Valve Program Tables

The tables in Appendix B list all ISI Class 1, 2, 3, and NC valves that have been assigned valve categories. Valves exempt per IWB-1200 are not listed. The following information is included for each valve:

VALVE IDENTIFICATION AND IST REQUIREMENTS

SYSTEM-P&ID: Located in the top right hand corner of the program table as drawing number (DWG. NO.). This identifies the valve's associated system and P&ID.

VALVE NO.: The valve identification number.

P&ID COOR.: The drawing coordinate location on the P&ID for the valve.

ISI CLASS: The ISI classification of the valve.

ISI CAT.: The category(s) assigned to the valve based on the definitions per IWB-2200. Four (4) separate categories are defined in the Code:

CATEGORY A - Valves for which seat leakage is limited to a specific maximum amount in the closed position for fulfillment of their function.

CATEGORY B - Valves for which seat leakage in the closed position is inconsequential for fulfillment of their function.

CATEGORY C - Valves which are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves).

CATEGORY D - Valves which are actuated by an energy source capable of only one operation, such as rupture disks or explosive-actuated valves.

VALVE SIZE: The nominal size of the valve in inches.

VALVE TYPE: The valve body design as indicated by the following abbreviations:

ANGLE	ANG
BALL	BAL
BUTTERFLY	BTF
CHECK	CK
DIAPHRAGM	DIA
GATE	GA
GLOBE	GL
RELIEF	RV
RUPTURE DIAPHRAGM	RPD
SAFETY	SV
STOP CHECK	SCK
THREE WAY	TWY

ACT. TYPE: The type of valve actuator as indicated by the following abbreviations:

MOTOR OPERATOR	MO
AIR OPERATOR	AO
SOLENOID OPERATOR	SO
HYDRAULIC OPERATOR	HO
MANUAL	M
SELF ACTUATED	SA

NORM. POS.: The position of the valve during normal plant operation, specified as follows:

O	Normally Open
C	Normally Closed

TEST RQMT: The test(s) that will be performed to fulfill the requirements of Subsection I.W.V. The test definitions and abbreviations used are identified in Table 3.1-1.

TEST FREQ.: The frequency at which the above mentioned tests will be performed. Test frequencies are defined in Table 3.1-2.

MAX STRK TIME: The limiting maximum value of full stroke time, in seconds, for power-operated valves in Category A or B.

MAX LEAKG: The maximum leakage allowed during the specified leaktest. The abbreviations for the units of measurement are:

- C Standard cubic centimeters per minute.
- P Pressure decay in pounds per square inch per minute.
- G Gallons per minute.
- M Milliliters per minute.

RELIEF REQUEST: The reference to a relief request in Section 3.2 for valve testing. Requests for relief are identified as VR-XX.

REMARKS: Remarks in the IST Program are coded as NOTE 1, NOTE 2, etc.

3.1.3 Measurement of Test Quantities

STROKE TIME: Stroke time is that time interval from initiation of the actuating signal to the end of the actuating cycle. Stroke time values for each power operated valve is specified in the valve program table. Stroke time is measured to the nearest second, for times 10 sec. or less, or 10% of the specified limiting stroke time for times longer than 10 sec.

POSITION INDICATION: Valve disk movement is determined by exercising the valve while observing an appropriate indicator which signals the required change of disk position, or observing indirect evidence, such as changes in system pressure, flow rate, level or temperature, which reflect stem or disk position.

SEAT LEAKAGE: Seat leakage is measured by one of the following methods:
(a) draining the line, closing the valve, bringing one side to test pressure, and measuring leakage through a downstream telltale connection, or
(b) by measuring the feed rate required to maintain pressure between two valves or between two seats of a gate valve, provided the total apparent leak rate is charged to the valve or gate valve seat being tested, and that the conditions required by IWW-3423 are satisfied.

3.1.4 Allowable Ranges of Test Quantities

STROKE TIME

- (a) If, for power operated valves, an increase in stroke time of 25% or more from the previous test for valves with stroke times greater than 10 sec. or 50% or more for valves with stroke times less than or equal to 10 sec. is observed, test frequency shall be increased to once each month until corrective action is taken. For valves with stroke times less than or equal to five seconds see Relief Request VR-2.
- (b) Valve stroke time shall not exceed its specified limiting stroke time value.

POSITION INDICATION: The valve disk shall move from the fully open position to the fully closed position or vice versa.

SEAT LEAKAGE: Valve leakage rates shall not exceed either the values specified by Wolf Creek Generating Station or those rates given in IWW-3426.

3.1.5 Instrument Accuracy

Instruments used to measure stroke times shall be capable of measurement to the nearest second.

TABLE 3.1-1

INSERVICE VALVE TESTS

<u>TEST</u>	<u>TEST NAME</u>	<u>TEST DESCRIPTION</u>
AT-1	Type C leaktest	Containment isolation valves will be seat leak tested in accordance with WCGS Technical Specification requirements and Appendix J, 10CFR50.
AT-2	Pressure isolation valve leaktest	Those valves so designated will be leak tested in accordance with WCGS Technical Specification 4.4.6.2.2.
AT-3	Accumulator check valve test	Check valves designed to maintain air-accumulator charge upon loss of normal plant service or instrument air will be subjected to air pressure drop.
BT-0	Full-stroke exercise test to the OPEN position (IWF-3412 and 3413)	Exercise testing in the open direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction tested and timed (open) is based on the direction the valve disk must travel to fulfill a safety function.
BT-C	Full-stroke exercise test to the CLOSED position (IWF-3412 and 3413)	Exercise testing in the closed direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction tested and timed (close) is based on the direction the valve disk must travel to fulfill a safety function.
BT-P	Partial-stroke exercise test (IWF-3412)	Partial-stroke exercise testing will be performed to confirm partial stroke capability of each valve. The stroke direction tested is based on the direction the valve disk must travel to fulfill a safety function.

TABLE 3.1-1

INSERVICE VALVE TESTS (continued)

<u>TEST</u>	<u>TEST NAME</u>	<u>TEST DESCRIPTION</u>
CVT-0	Check valve exercise test to OPEN position (IWF-3520)	Check valves will be exercised from the fully closed to the fully open positions. Verification of safety basis system flow or full stroke calculated flow through a check valve shall be an adequate demonstration that the valve is full open.
CVT-C	Check valve exercise test to CLOSED position (IWF-3520)	Check valves will be exercised from the fully open to the fully closed positions. The stroke direction tested (closed) is based on the direction the valve disk must travel to fulfill a safety function.
CVP-0	Partial check valve exercise test to OPEN position (IWF-3522)	Partial check valve exercise test to the open position.
RVT	Relief valve set point verification test (IWF-3510)	Relief and safety valve set point will be verified in accordance with IWF-3510.
FST	Fail-safe test (IWF-3415)	Valves with fail-safe actuators will be tested to verify proper fail-safe operation upon loss of actuator electric power.
PIT	Position indication checks (IWF-3300)	Valves with position indicators will be checked to verify that remote valve indicators accurately reflect valve position.
PAS	Indicates passive valve	This is a passive valve and does not require testing.

TABLE 3.1-2

TEST FREQUENCY

(1)

<u>TEST FREQUENCY</u>	<u>OPERATIONAL CONDITION</u>	<u>FREQUENCY OF TESTING</u>
Q	Power operation	At least once per 92 days
CS	Cold Shutdown	See (2) below
RR	Refueling	Not less than once every two years
5Y	No operational condition limitations	Every five years (see Article IWF-3511). Applies to RVT test.
2Y	No operational condition limitations	Every two years (see Article IWF-3300). Applies to PIT test.

- (1) Operational conditions are defined in WCGS Technical Specifications, page 1-9.
- (2) Inservice valve testing will commence within 72 hours of reaching the cold shutdown conditions as defined in the WCGS Technical Specifications. Testing not completed before startup may be completed during subsequent cold shutdowns. Valve testing need not be performed more often than once every three months. In the case of extended cold shutdowns, the testing need not be started within the 72 hours limitation. However, in these instances, all valve testing must be completed prior to startup.

NOTE: Completion of all valve testing during cold shutdowns is not required if plant operating conditions do not permit testing of specific valves.

SECTION 3.2

RELIEF REQUESTS FOR INSERVICE VALVE TESTING PROGRAM

RELIEF REQUEST NO. VR-1

VALVE(S):

See Appendix B

CATEGORY:

A and B

FUNCTION:

Various

TEST REQUIREMENT:

When practical, valves with fail-safe actuators shall be tested by observing the operation of the valves upon loss of actuator power. (IWW-3415)

BASIS FOR RELIEF:

Solenoid and air-operated valves that stroke upon loss of actuator power are the only type in the Wolf Creek IST Program. De-energizing the solenoid or pilot valve during normal valve exercising effectively simulates loss of actuator power.

ALTERNATE TESTING:

Valves which must stroke to a specified position upon loss of actuator power will be exercised in accordance with Paragraph IWW-3412 to their respective fail-safe position. This test will constitute the fail-safe test. No additional testing will be conducted.

RELIEF REQUEST NO. VR-2

VALVE(S):

See Appendix B

CATEGORY:

A and B

FUNCTION:

Various

TEST REQUIREMENT:

Stroke time shall be compared to previous test results and if the stroke time has increased by 50% or more since the last test, then the frequency of testing shall be increased to once each month. (IWF-3417(a))

BASIS FOR RELIEF:

It is impractical to apply the strict requirements of Paragraph IWF-3417(a) in any meaningful way without installing sophisticated timing devices. Operator reaction time could easily vary by 0.5 seconds thereby adding considerable error to test results of quick-acting valves.

ALTERNATE TESTING:

The stroke times of all valves with stroke times less than or equal to five (5) seconds will be measured and, when required, corrective action will be taken in accordance with Paragraph IWF-3417(b).

Rev. 4
07/85

Page 28 of 115

RELIEF REQUEST NO. VR-3

VALVE(S):

BB V-118, BB V-148, BB V-178, RB V-208, BG V-135, BG 8381, BL 8046, EG V-204
EM V-006, EP V-046, KA V-039, KA V-204, KC V-478, SJ V-111

CATEGORY:

A, C

FUNCTION:

Various depending on component and system function.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWW-3522. (IWW-3521)

BASIS FOR RELIEF:

When these valves are in operation there is no practical means to test valve closure. Therefore a seat leak test will be conducted to verify valve closure.

ALTERNATE TESTING:

Verification of valve closure will be done in conjunction with the 10 CFR 50 Appendix J Type C leak tests (AT-1) conducted during each refueling outage

RELIEF REQUEST NO. VR-4

VALVE(S):

BB 8948A through D, BB 8949A through D, BB V-001, BB V-022, BB V-040,
BB V-059, EJ 8841A, EJ 8841B, EM 8815, EP 8818A through D, EP 8956A | 3
through D, EP V-010, EP V-020, EP V-030, EP V-040.

CATEGORY:

A, C and C

FUNCTION:

Reactor coolant system pressure boundary isolation.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

- a) Exercising these valves to the open direction during power operation can not be done due to the systems not being able to overcome Reactor Coolant System Pressure. The high pressure coolant injection valves are an exception to this but would cause a power decrease due to the injection of boric acid into the Reactor Coolant System.
- b) Testing of these valves during cold shutdown is impractical due to the inherent danger of cold over pressurization of the RCS.
- c) The only practical method of verifying valve closure is to conduct a seat leak test.

ALTERNATE TESTING:

Valves will be full-stroked in the open direction during each reactor refueling outage. Verification of valve closure will be done in conjunction with intersystem LOCA leak testing (AT-2) which will be performed at each refueling outage.

RELIEF REQUEST NO. VR-5

VALVE(S):

See Appendix B

CATEGORY:

A and A, C

FUNCTION:

Various

TEST REQUIREMENT:

Category A valves shall be leak tested. (IWF-3420)

BASIS FOR RELIEF:

Section XI testing requirements are essentially the same as those of Appendix J and therefore it would be impractical to perform separate leak tests.

ALTERNATE TESTING:

These valves will be leak tested in accordance with the Appendix J requirements of 10 CFR 50.

RELIEF REQUEST NO. VR-6

VALVE(S):

See Appendix B

CATEGORY:

A and A, C

FUNCTION:

Various

TEST REQUIREMENT:

For valves 6 in. nominal pipe size and larger, if a leakage rate exceeds the rate determined by the previous test by an amount that reduces the margin between measured leakage rate and the maximum permissible rate by 50% or greater, the test frequency shall be doubled. (IWF-3427(b))

BASIS FOR RELIEF:

These valves are located inside containment and testing on an increased frequency would increase exposure for testing personnel. Testing is now being performed during mode 3 to minimize exposure. With increased frequency, operational constraints would be placed upon the plant requiring possible shut down for testing. Therefore, corrective action per IWF-3427(b) will not be used due to ALARA considerations and operational constraints on the plant.

ALTERNATE TESTING:

Valves will be replaced or repaired as required when the leakage rate exceeds the one (1) gpm maximum leakage rate as stated in Wolf Creek Generating Station Technical Specifications.

RELIEF REQUEST NO. VR-7

VALVE(S):

BG 8546A and B

CATEGORY:

C

FUNCTION:

Provide flowpaths to the centrifugal charging pumps from the refueling water storage tank.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

- a) Full-stroke or partial-stroke exercising of these valves during normal operation would increase the boron inventory in the reactor coolant system thus increasing the potential for plant shutdown.
- b) Exercising of these valves during cold shutdown requires using the safety injection flowpath which could result in potential reactor coolant system overpressurization.

ALTERNATE TESTING:

Valves will be full-stroke exercised open during each refueling outage.

RELIEF REQUEST NO. VR-8

VALVE(S):

See Appendix B

4

CATEGORY:

A and A, C

FUNCTION:

Various

TEST REQUIREMENT:

For valves 6 in. nominal pipe size and larger, if a leakage rate exceeds the rate determined by the previous test by an amount that reduces the margin between measured leakage rate and the maximum permissible rate by 50% or greater, the test frequency shall be doubled; the tests shall be scheduled to coincide with a cold shutdown until corrective action is taken, and a projection based on three or more tests indicates that the leakage rate of the next scheduled test will exceed the maximum permissible leakage rate by greater than 10%, the valve shall be replaced or repaired. [IWF-3427(b)]

BASIS FOR RELIEF:

- a) Past experience at other utilities indicates that no reliable trend can be established for leakage rates. Past experience also indicates that the difference between leakage rates from one test to another is more likely due to other factors or plant conditions and usually not valve degradation.
- b) A recent draft of the ANSI/ASME OM-10 standard (Inservice Testing of Valves) has deleted these test requirements from the corrective action paragraph for valve leak rate testing.

ALTERNATE TESTING:

None. Valves will be replaced or repaired when the permissible leakage rate is exceeded as stated in IWF-3427(a).

RELIEF REQUEST NO. VR-9

VALVE(S):

EF V-241, EF V-242

CATEGORY:

C

FUNCTION:

Provide flowpaths from service water system A and B trains to the ultimate heat sink and pressure isolation of the service water system from the ultimate heat sink.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

Valve location does not permit adequate reverse flow for check valve stroke testing. Therefore the only positive means to verify that the disk is on its seat is to disassemble and observe valve operability.

ALTERNATE TESTING:

Valves will be disassembled and inspected for operability during each reactor refueling outage.

RELIEF REQUEST NO. VR-10

NOT USED

Rev. 4
07/85
Page 36 of 115

RELIEF REQUEST NO. VR-11

VALVE(S):

EJ HV-8811 A and B

CATEGORY:

B

FUNCTION:

RHR containment sump isolation valve. Isolate the containment sump from the RHR pumps and open in the recirculation mode to line up RHR pumps to the sump.

TEST REQUIREMENT:

Category A and B valves shall be exercised at least once every 3 months, except as provided by IWF-3412(a), IWF-3415, and IWF-3416. (IWF-3411)

BASIS FOR RELIEF:

Opening these valves during normal operation or cold shutdown will drain the RHR system to the containment sump.

ALTERNATE TESTING:

These valves will be exercised during each reactor refueling outage.

2

RELIEF REQUEST NO. VR-12

VALVE(S):

EM V-001, EM V-002, EM V-003, EM V-004, EM 8922A and B

CATEGORY:

A, C and C

FUNCTION:

V-001, V-002, V-003, V-004: Pressure boundary isolation valves for safety injection pump hot leg injection.
8922A and B: Safety injection pumps discharge check valves.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

- a) During normal operation these valves will not stroke against full RCS pressure.
- b) Stroking these valves during cold shutdown could result in overpressurization of the RCS.

ALTERNATE TESTING:

Valves will be full-stroke exercised open during each reactor refueling outage.

RELIEF REQUEST NO. VR-13

VALVE(S):

EM V-001, EM V-002, EM V-003, EM V-004, EM 8815

CATEGORY:

A. C

FUNCTION:

V-001, V-002, V-003 and V-004: Pressure boundary isolation valves for safety injection pump hot leg injection.
8815: Pressure isolation for high pressure coolant injection line.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

The only practical method of verifying valve closure is to conduct a seat leak test.

ALTERNATE TESTING:

Verification of valve closure will be done in conjunction with intersystem LOCA leak testing (AT-2) which will be performed at each refueling outage.

RELIEF REQUEST NO. VR-14

VALVE(S):

EM 8926 A and B

CATEGORY:

C

FUNCTION:

Opens on flow from the Refueling Water Storage Tanks to the suction of the Safety Injection Pumps.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

- a) Full-stroke exercising during normal operation cannot be accomplished since safety injection pump discharge pressure is not enough to overcome reactor coolant pressure.
- b) Exercising these valves during cold shutdown could result in overpressurization of the reactor coolant system.

ALTERNATE TESTING:

Valves will be partial-stroke exercised quarterly and full-stroke exercised open during each refueling outage.

RELIEF REQUEST NO. VR-15

VALVE(S):

EN V-002, EN V-008, EN V-013, EN V-017

CATEGORY:

C

FUNCTION:

V-002, V-008: Prevent draining RWST and containment spray system to the containment sump.

V-013, V-017: Containment spray containment isolation valves; open to pressurize containment spray headers.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

No means exist for testing these valves open without taking a suction from the containment sump or discharging water through the spray headers.

ALTERNATE TESTING:

Valves will be disassembled and inspected for operability during each refueling outage.

RELIEF REQUEST NO. VR-16

VALVE(S):

EN HV-1, EN HV-7

CATEGORY:

B

FUNCTION:

Provides flow path from containment recirculation sump to containment spray pumps.

TEST REQUIREMENT:

Category A and B valves shall be exercised at least once every 3 months, except as provided by IWF-3412 (a), IWF-3415, and IWF-3416. (IWF-3411)

BASIS FOR RELIEF:

Upon exercising these valves during normal operation or cold shutdown there exists the possibility of draining the containment spray pumps suction lines which could severely effect the containment spray pumps' operation.

ALTERNATE TESTING:

Valves will be full-stroke exercised both open and close during each refueling outage.

RELIEF REQUEST NO. VR-17

VALVE(S):

EN V-003, EN V-004, EN V-009, EN V-010

CATEGORY:

C

FUNCTION:

Provide flow path from refueling water storage tank to the spray headers.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

The flow path that would provide sufficient flow to fully open these valves cannot be utilized since it could result in spraying containment.

ALTERNATE TESTING:

Valves will be partial-stroke exercised open every 3 months.

RELIEF REQUEST NO. VR-18

VALVE(S):

EP HV-8950 A through F

CATEGORY:

B

FUNCTION:

Safety injection accumulator vent valves

TEST REQUIREMENT:

Category A and B valves shall be exercised at least once every 3 months, except as provided by IWF-3412(a), IWF-3415, and IWF-3416. (IWF-3411)

BASIS FOR RELIEF:

Opening these valves could bleed down the associated safety injection accumulators and if the valves failed open it would render a portion of the ECCS inoperable forcing plant shutdown.

ALTERNATE TESTING:

These valves will be fail-safe tested and full-stroke exercised both open and close during each refueling outage.

RELIEF REQUEST NO. VR-19

VALVE(S):

KA FV-29, KA HV-30

CATEGORY:

A and B respectively

FUNCTION:

FV-29 provides containment isolation from the instrument air supply.
HV-30 provides isolation from instrument air supply to the hydrogen control system.

TEST REQUIREMENT:

Category A and B valves shall be exercised at least once every 3 months, except as provided by IWF-3412(a), IWF-345, and IWF-3416. (IWF-3411)

BASIS FOR RELIEF:

- a) Stroking FV-29 would interrupt the supply of instrument air to valves and equipment necessary for system control and operation during all phases of plant operation.
- b) Stroking HV-30 would reduce the supply of instrument air to valves and equipment necessary for plant operation.

ALTERNATE TESTING:

Valves FV-29 and HV-30 will be fail-safe tested, full-stroke exercised close and full-stroke exercised open, respectively, during each refueling outage.

RELIEF REQUEST NO. VR-20

VALVE(S):

KA V-648, KA V-649, KA V-650, KA V-651

CATEGORY:

A, C

FUNCTION:

These valves maintain the auxiliary feedwater control/main steam atmosphere relief valve accumulators (TKA02 through 05) pressurized in the event that the service air is lost.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

There is no convenient means to verify operation of these valves without adversely affecting the availability of the associated safety-related components.

ALTERNATE TESTING:

Verification of valve closure will be done in conjunction with pressure drop testing (AT-3) which will be performed at each refueling outage.

RELIEF REQUEST NO. VR-21

VALVE(S):

KJ V-711 A and B, KJ V-712 A and B

CATEGORY:

A, C

FUNCTION:

These valves maintain the diesel generator starting air tanks pressurized in the event that the normal starting air supply line is broken.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by I WV-3522. (I WV-3521)

BASIS FOR RELIEF:

There is no convenient means to verify operation of these valves without disabling the diesel generators.

ALTERNATE TESTING:

Verification of valve closure will be done in conjunction with pressure drop testing (AT-3) which will be performed at each refueling outage.

RELIEF REQUEST NO. VR-22

VALVE(S):

EM V-240 and EM V-241

CATEGORY:

C

FUNCTION:

Provides flow from the centrifugal charging pumps to the boron injection tank.

TEST REQUIREMENT:

Check valves shall be exercised at least once every 3 months, except as provided by IWF-3522. (IWF-3521)

BASIS FOR RELIEF:

During normal operation stroking these valves would result in injecting borated water into the RCS and thus could result in a decrease in power and thermal shock the reactor coolant piping. Stroking these valves during cold shutdown could result in overpressurization of the RCS.

ALTERNATE TESTING:

Valves will be full-stroke exercised open during each refueling outage.

APPENDIX A
PUMP TESTING PROGRAM

Rev. 4
07/85
Page 49 of 115

WOLF CREEK NUCLEAR PLANT
INSERVICE TESTING PROGRAM PUMPS

Page 1 of 2

PUMP IDENTIFICATION				1ST REQUIREMENTS								
PUMP NUMBER	SYSTEM	ISI CLASS	P&ID NUMBER	P&ID COORD	SPEED	SUCT. PRESS	DIFF. PRESS	FLOW RATE	VIBRA	BRG. TEMP	LUBRICANT LEV OR PRESS	REMARKS
PAL01 A	AUX FD	3	M-12AL01	E-4	N/A ¹	YES	YES	PR-8	YES	PR-1	YES	PR-2
PAL01 B	AUX FD	3	M-12AL01	H-4	N/A ¹	YES	YES	PR-8	YES	PR-1	YES	PR-2
PAL02	AUX FD	3	M-12AL01	B-4	YES	YES	YES	PR-8	YES	PR-1	YES	PR-2
PBG02 A	CVCS	3	M-12BG05	B-6	N/A ¹	YES	YES	PR-8	PR-6	PR-1	PR-5	PR-2
PBG02 B	CVCS	3	M-12BG05	A-6	N/A ¹	YES	YES	PR-8	PR-6	PR-1	PR-5	PR-2
PBG05 A	CVCS	2	M-12BG03	C-5	N/A ¹	YES	YES	PR-8	YES	PR-1	YES	PR-2
PBG05 B	CVCS	2	M-12BG03	B-5	N/A ¹	YES	YES	PR-8	YES	PR-1	YES	PR-2
PEC01 A	FPC	3	M-12EC01	H-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2
PEC01 B	FPC	3	M-12EC01	E-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2
PEF01 A	ESU	3	M-K2EF01	G-6	N/A ¹	PR-3	YES	YES	PR-9	PR-1	YES	PR-2
PEF01 B	ESU	3	M-K2EF01	C-6	N/A ¹	PR-3	YES	YES	PR-9	PR-1	YES	PR-2
PEG01 A	CCW	3	M-12EG01	G-4	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2
PEG01 B	CCW	3	M-12EG01	D-4	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2

- NOTE:
- IWP-4400 states that for pumps directly coupled to synchronous or induction type motor drivers, pump speed need not be measured.
 - Frequency of testing will be in accordance with IWP-3400 which requires an inservice test to be run every three months during normal operation.

WOLF CREEK NUCLEAR PLANT
INSERVICE TESTING PROGRAM PUMPS

Page 2 of 2

PUMP IDENTIFICATION				IST REQUIREMENTS									
PUMP NUMBER	SYSTEM	ISI CLASS	P&ID NUMBER	P&ID COORD	SPEED	SUCT. PRESS	DIFF. PRESS	FLOW RATE	VIBRA	BRG. TEMP	LUBRICANT	LEV OR PRESS	REMARKS
PEG01 C	CCW	3	M-12EG01	E-4	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEG01 D	CCW	3	M-12EG01	B-4	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEJ01 A	RHR	2	M-12EJ01	G-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEJ01 B	RHR	2	M-12EJ01	C-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEM01 A	SIS	2	M-02EM01	E-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEM01 B	SIS	2	M-02EM01	D-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEN01 A	CS	2	M-02EN01	G-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PEN01 B	CS	2	M-02EN01	B-6	N/A ¹	YES	YES	YES	YES	PR-1	YES	PR-2	
PJE01 A	FOT	3	M-12JE01	E-7	N/A ¹	PR-3	YES	PR-8	PR-4	PR-1	PR-5	PR-2	PR-7
PJE01 B	FOT	3	M-12JE01	A-7	N/A ¹	PR-3	YES	PR-8	PR-4	PR-1	PR-5	PR-2	PR-7

3

3

3

- NOTE:
1. IWP-4400 states that for pumps directly coupled to synchronous or induction type motor drivers, pump speed need not be measured.
 2. Frequency of testing will be in accordance with IWP-3400 which requires an inservice test to be run every three months during normal operation..

APPENDIX B
VALVE TESTING PROGRAM

** THE MAPPER SYSTEM **

DATE 071985

PAGE 142

• DATE 07 MAR 85 15:48:05 RID 2 04 MAR 85 LYON
 • SYSTEM: MAIN STEAM WCGB INSERVICE TESTING PROGRAM DWG. NO.: M-02AB01
 • VALVE • PLID. • ISI. • IST. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF.
 • NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT. • FRE. • TIME • LEAKG. • REQUEST. • REMARKS
 • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ======

PV-1	G-2	2	B	10	GL	AO	C	ET-C CS 20	VR-1	NOTE 1
								BT-0 CS 20		
								FST CS		
								PIT 2Y		
PV-2	O-3	2	B	10	GL	AO	C	BT-C CS 20	VR-1	NOTE 1
								BT-0 CS 20		
								FST CS		
								PIT 2Y		
PV-3	O-6	2	B	10	GL	AO	C	BT-C CS 20	VR-1	NOTE 1
								BT-0 CS 20		
								FST CS		
								PIT 2Y		
PV-4	G-6	2	B	10	GL	AO	C	BT-C CS 20	VR-1	NOTE 1
								BT-0 CS 20		
								FST CS		
								PIT 2Y		

***** END REPORT *****

• DATE 19 JUN 85 15:42:20 RID	3	04 MAR 85 RAYMOND	WCFS INSERVICE TESTING PROGRAM DWG. NO.: M-02AB02
• SYSTEM: MAIN STEAM			
• VALVE • .PCID. • .IST. • .IST. • .VALVE. • .VALVE. • .ACT. • .NORM. • .TEST. • .TST. • .MAX STRK. • .MAX. • .RELIEF.			
• NO. • .COOR. • .CLASS. • .CAT. • .SIZE. • .TYPE. • .TYPE. • .POS. • .RQMT. • .FRE. • .TIME. • .LEAKG. • .REQUEST. • .REMARKS			
HV-5 D-4 2 B 4 GL AO C	BT-0 Q 10	VR-1	
HV-6 C-4 2 B 4 GL AO C	FST Q PIT 2Y BT-0 Q 10	VR-1	
HV-11 H-2 2 B 28 GA AO O	PIT 2Y BT-C CS 5	VR-2	NOTE 2
HV-12 G-3 2 B 2 GL AO C	BT-P Q PIT 2Y BT-C CS 10		3
HV-14 F-3 C B 28 GA AO O	BT-P Q FST CS PIT 2Y BT-C CS 5	VR-2	NOTE 2
HV-15 F-3 2 B 2 GL AO C	PIT 2Y BT-C CS 10 BT-P Q FST CS		3
HV-17 D-3 2 B 28 GA AO O	PIT 2Y BT-C CS 5 BT-P Q	VR-2	NOTE 2
HV-18 D-3 2 B 2 GL AO C	PIT 2Y BT-C CS 10 BT-P Q FST CS		3
HV-20 C-3 2 B 28 GA AO O	PIT 2Y BT-C CS 5 BT-P Q PIT 2Y BT-C CS 10	VR-2	NOTE 2
HV-21 C-3 2 B 2 GL AO C	BT-P Q FST CS PIT 2Y BT-C CS 10		3
HV-48 D-4 2 B 1 GL AO O	PIT 2Y BT-C Q 5 FST Q PIT 2Y	VR-1 VR-2	
HV-49 C-4 2 B 1 GL AO O	BT-C Q 5 FST Q PIT 2Y	VR-2 VR-3	
LV-7 B-4 2 B 2 GL AO C	BT-C Q 5 FST Q PIT 2Y		
LV-8 D-5 2 B 2 GL AO C	BT-C Q 5 FST Q PIT 2Y		
LV-9 E-4 2 B 2 GL AO C	BT-C Q 5 FST Q PIT 2Y		
LV-10 G-4 2 B 2 GL AO C	BT-C Q 5 FST Q PIT 2Y		
V045 H-7 2 C b SV SA C RVT SY			
V046 H-7 2 C b SV SA C RVT SY			
V047 H-6 2 C b SV SA O RVT SY			

VU46	H-5	2	C	b	SV	SA	C	RVT	SY
VU47	H-5	2	C	b	SV	SA	C	RVT	SY
VU55	F-7	2	C	b	SV	SA	C	RVT	SY
VU56	F-7	2	C	b	SV	SA	C	RVT	SY
VU57	F-6	2	C	b	SV	SA	C	RVT	SY
VU58	F-5	2	C	b	SV	SA	C	RVT	SY
VU59	F-5	2	C	b	SV	SA	C	RVT	SY
VU5A	D-7	2	C	b	SV	SA	C	RVT	SY
VU5B	D-7	2	C	b	SV	SA	C	RVT	SY
VU5C	D-6	2	C	b	SV	SA	C	RVT	SY
VU5D	D-6	2	C	b	SV	SA	C	RVT	SY
VU5E	D-5	2	C	b	SV	SA	C	RVT	SY
VU5F	D-5	2	C	b	SV	SA	C	RVT	SY
VU5G	C-7	2	C	b	SV	SA	C	RVT	SY
VU5H	C-7	2	C	b	SV	SA	C	RVT	SY
VU5I	C-6	2	C	b	SV	SA	C	RVT	SY
VU5J	C-5	2	C	b	SV	SA	C	RVT	SY
VU5K	C-5	2	C	b	SV	SA	C	RVT	SY

***** END REPORT *****

** STATE ** MAR 85 CS:50:03 RID 48 04 MAR 85 LYON
 ** SYSTEM: MAIN FEEDWATER WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02AE01
 ** VALVE * .PLID. .IST. .VALVE. .ACT. .NORM. .TEST. .MAX STRK. .MAX. .RELIEF.
 ** NO. .COOR. .CLASS. .CAT. .SIZE. .TYPE. .TYPE. .POS. .ROMT. .FRE. .TIME. .LEAKG. .REQUEST. .REMARKS
 FCV-510 E-7 N B 14 ANG AO 0 BT-C CS 5 VR-1 NOTE 3
 FST CS VR-2
 PIT 2Y
 FCV-511 C-7 N B 14 ANG AO 0 BT-C CS 5 VR-1 NOTE 3
 FST CS VR-2
 PIT 2Y
 FCV-530 A-7 N B 14 ANG AO 0 BT-C CS 5 VR-1 NOTE 3
 FST CS VR-2
 PIT 2Y
 FCV-540 G-7 N B 14 ANG AO 0 BT-C CS 5 VR-1 NOTE 3
 FST CS VR-2
 PIT 2Y
 FCV-550 E-7 N B 4 GL AO C BT-C CS 5 VR-1 NOTE 4
 FST CS VR-2
 PIT 2Y
 FCV-560 C-7 N B 4 GL AO C BT-C CS 5 VR-1 NOTE 4
 FST CS VR-2
 PIT 2Y
 FCV-570 A-7 N B 4 GL AO C BT-C CS 5 VR-1 NOTE 4
 FST CS VR-2
 PIT 2Y
 FCV-580 G-7 N B 4 GL AO C BT-C CS 5 VR-1 NOTE 4
 FST CS VR-2
 PIT 2Y

***** END REPORT *****

DATE 19 JUN 85 15:44:04 RID 4 04 MAR 85 RAYMOND
 SYSTEM: MAIN FEEDWATER WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02AED2
 VALVE . . PVID . . ISI . . IST . . VALVE . . ACT . . NORM . . TEST . . TST . . MAX STRK . . MAX . . RELIEF . .
 NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT . . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .
 FV-39 C-3 2 B 14 GA AO 0 BT-C CS S VR-1 NOTE 5
 BT-P Q VR-2
 FST CS
 PIT 2Y
 FV-40 C-3 2 B 14 GA AO 0 BT-C CS S VR-1 NOTE 5
 BT-P Q VR-2
 FST CS
 PIT 2Y
 FV-41 C-3 2 B 14 GA AO 0 BT-C CS S VR-1 NOTE 5
 BT-P Q VR-2
 FST CS
 PIT 2Y
 FV-42 G-6 C B 14 GA AO 0 BT-C CS S VR-1 NOTE 5
 BT-P Q VR-2
 FST CS
 PIT 2Y
 FV-43 G-4 N B 1 GL AO C PAS NA
 FV-44 D-4 N B 1 GL AO C PAS NA
 FV-45 D-7 N B 1 GL AO C PAS NA
 FV-46 G-7 N B 1 GL AO C PAS NA
 V110 C-4 N C 14 CK SA O CVT-O Q CVT-C CS NOTE 5
 V121 F-4 2 C 14 CK SA O CVT-O Q CVT-C CS NOTE 5
 V122 F-7 2 C 14 CK SA O CVT-O Q CVT-C CS NOTE 5
 V123 C-7 2 C 14 CK SP O CVT-O Q CVT-C CS NOTE 5
 V124 C-3 N C 4 CK SA C CVT-O CS NOTE 6
 V125 F-3 N C 4 CK SA C CVT-O CS NOTE 6
 V126 F-5 N C 4 CK SA C CVT-O CS NOTE 6
 V127 C-5 N C 4 CK SA C CVT-O CS NOTE 6
 V128 C-3 N C 1 CK SA C PAS NA
 V129 F-3 N C 1 CK SA C PAS NA
 V130 E-6 2 C 1 CK SA C PAS NA
 V131 C-6 2 C 1 CK SA C PAS NA

***** END REPORT *****

*DATE 20 JUN 85 12:45:50 RIO

5 29 MAR 85 RAYMOND

WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02AL03

• SYSTEM: AUXILIARY FEEDWATER	• PLID. • ISI. • 1ST. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF.	• COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT. • FRE. • TIME. • LEAKG. • REQUEST. • REMARKS
VU01	E-4 3 C 10 CK SA C	CVT-O Q
VU02	D-4 C 10 CK SA C	CVT-O Q
VU03	H-4 C 10 CK SA C	CVT-O Q
VU04	F-4 C 10 CK SA C	CVT-O Q
VU05	E-4 C 10 CK SA C	CVT-O Q
VU12	C-4 C 10 CK SA C	CVT-O Q
VU13	B-4 C 10 CK SA C	CVT-O Q
VU14	E-5 C 10 CK SA C	CVT-O Q
VU23	F-7 C 4 CK SA C	CVT-O CS
VU32	H-7 C 4 CK SA C	CVT-O CS
VU41	F-5 C 4 CK SA C	CVT-O Q
VU42	D-5 C 4 CK SA C	CVT-O CS
VU43	C-7 C 4 CK SA C	CVT-O CS
VU44	D-7 C 4 CK SA C	CVT-O CS
VU45	R-5 C 3 CK SA C	CVT-O Q
VU54	B-5 C 4 CK SA C	CVT-O CS
VU58	E-7 C 4 CK SA C	CVT-O CS
VU62	C-7 C 4 CK SA C	CVT-O CS
VU67	D-7 C 4 CK SA C	CVT-O CS
VU70	B-7 C 4 CK SA C	CVT-O CS
VV-5	H-7 C 4 GL MO O	NA NA
HV-6	G-6 B 4 GL AO O	PAS NA
HV-7	F-6 B 4 GL MO O	NA NA
HV-8	E-6 B 4 GL AO O	PAS NA
HV-9	C-6 B 4 GL MO O	NA NA
HV-10	D-6 B 4 GL AO O	PAS NA
HV-11	C-6 B 4 GL MO O	NA NA
HV-12	B-6 B 4 GL AO O	PAS NA
HV-13	F-3 B 6 BTF MO C	BT-O 0 15 PIT 2Y
HV-14	E-3 B 6 BTF MO C	BT-O 0 15 PIT 2Y
HV-15	C-3 B 6 BTF MO C	BT-O 0 15 PIT 2Y
HV-16	B-3 B 6 BTF MO C	PIT 2Y BT-O 0 15 PIT 2Y
HV-17	H-3 B 6 GA MO O	BT-C 0 30 PIT 2Y
HV-18	D-3 B 6 GA MO O	BT-C 0 30 PIT 2Y
HV-19	B-3 B 10 GA MO O	BT-C 0 30 PIT 2Y

***** END REPORT *****

WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028801						
ITEM	DESCRIPTION	TEST	TEST	MAX STRK.	RELIEF	REMARKS
P-378A	E-4 1 C B CK SA O	CVT-0 Q				
P-378B	E-4 1 C B CK SA O	CVT-0 Q				
P-378A	E-7 1 C B CK SA O	CVT-0 Q				
P-378B	E-7 1 C B CK SA O	CVT-0 Q				
P-378A	E-4 1 A,C 10 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378B	D-4 2 A,C 10 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378C	D-6 1 A,C 10 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378D	E-4 1 A,C 10 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378A	E-5 1 A,C B CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378B	C-5 1 A,C B CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378C	E-6 1 A,C B CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
P-378D	G-F 2 A,C B CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
VU01	D-5 1 A,C 1.5 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
VU02	D-4 2 A,C 1.5 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
VU03	D-6 2 A,C 1.5 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
VU04	E-6 1 A,C 1.5 CK SA C	AT-2 RR CVT-0 RR CVT-C RR	1.0 G	VR-4 VR-6		3
PV-6702A	E-4 2 A 12 GA MO C	AT-2 RR BT-0 CS 120 BT-C CS 120	1.0 G	VR-6	NOTES E,3b	3
PV-6702B	H-b 1 A 12 GA MO C	PIT 2Y AT-2 RR BT-0 CS 120 BT-C CS 120 PIT 2Y	1.0 G	VR-6	NOTES B,3b	3

***** END REPORT *****

• DATE 15 JUL 85 16:45:25 RID	?	04 MAR 85 RAYMOND	WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02BB02
• SYSTEM: REACTOR COOLANT	• PLEID.. .IST.. .VALVE.. .VALVE.. .ACT ..NORM.. .TEST.. .TST.. .MAX STRK.. . MAX ..RELIEF ..		
• NO. . COOR. .CLASS. .CAT. . SIZE. . TYPE. . POS. .RQMT . .FRE. . TIME . .LEAKG. .REQUEST. . REMARKS			
AUDGA H-7 1 C b SV SA C RVT SY			
AUDGB H-6 1 C b SV SA C RVT SY			
AUDGC H-5 1 C b SV SA C RVT SY			
AUDGH C-4 1 C b CK SA C PAS NA			NOTE 9
HV-5000A E-7 1 B 3 GA MO 0 BT-O Q 10			NOTE 36
	BT-C Q 10		
	PIT 2Y		
HV-5000B E-7 1 B 3 GA MO 0 BT-O Q 10			NOTE 36
	BT-C Q 10		
	PIT 2Y		
HV-5026 E-3 2 A 1 DIA AO C AT-1 RR 650 C VR-1			13
	BT-C Q 10		VR-5
	FST Q		VR-6
	PIT 2Y		
HV-5027 E-3 2 A 1 DIA AO C AT-1 RR 650 C VR-1			13
	BT-C Q 10		VR-5
	FST Q		VR-6
	PIT 2Y		
HV-5037A E-5 3 B 4 GA MO C BT-O Q 15			NOTE 36
	BT-C Q 15		
	PIT 2Y		
HV-5037B E-5 3 B 4 GA MO C BT-O Q 15			NOTE 36
	BT-C Q 15		
	PIT 2Y		
AUDGA E-2 3 C 3 CK SA C PAS NA			
AUDGB E-2 3 C 3 CK SA C PAS NA			
HV-157A E-1 3 B 1 GL SO C BT-O Q 10			
	FST Q		
	PIT 2Y		
HV-5157B E-1 3 B 1 GL SO C BT-O Q 10			
	FST Q		
	PIT 2Y		
FCV-455A E-7 1 d 3 GL SO C BT-O CS 2		VR-1	NOTE 10
	BT-C CS 2		VR-2
	FST CS		
	PIT 2Y		
FCV-455B A-4 1 B 4 BAL AO O/C PAS NA			
FCV-455C E-4 1 B 4 EAL AO O/C PAS NA			
FCV-455A E-5 2 B 3 GL SO C BT-O CS 2		VR-1	NOTE 10
	BT-C CS 2		VR-2
	FST CS		
	PIT 2Y		

***** END REPORT *****

• DATE 18 JUL 85 16:47:43 RID 8	04 MAR 85 RAYMOND	WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028B03
• SYSTEM: REACTOR COOLANT		
• VALVE • PLID • ISI • IST • VALVE • VALVE • ACT • NORM • TEST • TST • MAX STRK • MAX • RELIEF •		
• NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT • FRE. • TIME • LEAKG. • REQUEST. • REMARKS		
V110 C-5 E A,C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V111 C-4 1 C 2 CK SA 0	CVT-0 Q VR-S	
V112 C-4 2 C 2 CK SA 0	CVT-C PR VR-E	14,3
V113 C-4 3 C 3 CK SA 0	CVT-0 Q	
V114 P-3 3 C .75 RV SA C	CVT-0 Q	
V115 E-5 2 A,C 2 CK SA 0	CVT-C CS NOTE 31	13
V116 E-6 1 C 2 CK SA 0	RVT 5Y	
V117 E-6 2 C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V118 E-6 3 C 3 CK SA 0	CVT-0 Q VR-S	
V119 E-6 4 A,C 2 CK SA 0	CVT-C CS VR-B	14,3
V120 E-6 1 C 2 CK SA 0	CVT-0 Q	
V121 E-6 2 C 2 CK SA 0	CVT-0 Q	
V122 E-6 3 C 3 CK SA 0	CVT-0 CS	
V123 E-6 4 A,C 2 CK SA 0	CVT-C CS	
V124 D-6 3 C .75 RV SA C	RVT 5Y	
V125 E-6 2 A,C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V126 E-6 3 C 2 CK SA 0	CVT-0 Q VR-S	
V127 E-6 4 C 3 CK SA 0	CVT-C RR VR-B	14,3
V128 E-6 1 C 2 CK SA 0	CVT-0 Q	
V129 E-6 2 C 2 CK SA 0	CVT-0 Q	
V130 E-6 3 C 3 CK SA 0	CVT-0 CS	
V131 E-6 4 A,C 2 CK SA 0	CVT-C CS NOTE 31	13
V132 E-6 1 C 2 CK SA 0	RVT 5Y	
V133 E-6 2 C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V134 E-6 3 C 3 CK SA 0	CVT-0 Q VR-S	
V135 E-6 4 A,C 2 CK SA 0	CVT-C CS VR-B	14,3
V136 E-6 1 C 2 CK SA 0	CVT-0 Q	
V137 E-6 2 C 2 CK SA 0	CVT-0 Q	
V138 E-6 3 C 3 CK SA 0	CVT-0 CS	
V139 E-6 4 A,C 2 CK SA 0	CVT-C CS	
V140 D-6 3 C .75 RV SA C	RVT 5Y	
V141 E-6 2 A,C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V142 E-6 3 C 2 CK SA 0	CVT-0 Q VR-S	
V143 E-6 4 C 3 CK SA 0	CVT-C CS VR-B	14,3
V144 E-6 1 C 2 CK SA 0	CVT-0 Q	
V145 E-6 2 C 2 CK SA 0	CVT-0 Q	
V146 E-6 3 C 3 CK SA 0	CVT-0 CS	
V147 E-6 4 A,C 2 CK SA 0	CVT-C CS	
V148 D-6 3 C .75 RV SA C	RVT 5Y	
V149 E-6 2 A,C 2 CK SA 0	AT-1 RR 1300 C VR-3	13
V150 E-6 3 C 2 CK SA 0	CVT-0 Q VR-S	
V151 E-6 4 C 3 CK SA 0	CVT-C CS VR-B	14,3
HV-14 C-6 3 B 3 GA MO 0	PIT 2Y	
HV-15 C-6 3 B 3 GA MO 0	BT-0 CS 30	
HV-16 C-6 3 B 3 GA MO 0	BT-C CS 30	
HV-5141A E-3 2 B .75 GL AO 0	PIT 2Y	
HV-5141B C-6 2 B .75 GL AO 0	BT-0 CS 30	
HV-5141C C-6 2 B .75 GL AO 0	BT-C CS 30	
HV-5141D C-6 2 B .75 GL AO 0	PAS NA	
HV-5251A C-5 2 A 2 GL MO 0	AT-1 RR 1300 C VR-5 NOTES 12,36	13
HV-5251B C-6 2 A 2 GL MO 0	BT-0 CS 10 VR-6	
HV-5251C C-6 2 A 2 GL MO 0	BT-C CS 10	
HV-5351A C-6 2 A 2 GL MO 0	PIT 2Y	
HV-5351B C-6 2 A 2 GL MO 0	AT-1 RR 1300 C VR-5 NOTES 12,36	13
HV-5351C C-6 2 A 2 GL MO 0	BT-0 CS 10 VR-6	
HV-5351D C-6 2 A 2 GL MO 0	BT-C CS 10	

** THE MAPPER SYSTEM **

DATE 071985

PAGE 33

HV-3351C	C-6	2	A	2	GL	MO	O	PIT	2Y				
								AT-1	RR				
								BT-0	CS	10		1300 C	VR-5
								BT-C	CS	10			VR-8
								PIT	2Y				
HV-3351D	C-6	2	A	2	GL	MO	O	AT-1	RR				
								BT-0	CS	10		1300 C	VR-5
								BT-C	CS	10			VR-8
								PIT	2Y				

***** END REPORT *****

• DATE 22 MAR 85 08:47:50 RID 9 04 MAR 85 LYON
 • SYSTEM: REACTOR COOLANT WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028RD4
 • VALVE . . PGID . . ISI . . IST . . VALVE . . VALVE . . ACT . . NORM . . TEST . . TST . . MAX STRK . . MAX . . RELIEF . .
 • NO. . . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .
 • HV-5001A F-4 2 B 1 GL SO C BT-O CS 10 VR-1 NOTE 13
 • BT-C CS 10
 • FST CS
 • PIT 2Y
 • HV-5001B F-4 2 B 1 GL SO C BT-O CS 10 VR-1 NOTE 13
 • BT-C CS 10
 • FST CS
 • PIT 2Y
 • HV-5002A F-3 2 B 1 GL SO C BT-O CS 10 VR-1 NOTE 13
 • BT-C CS 10
 • FST CS
 • PIT 2Y
 • HV-5002B F-3 2 B 1 GL SO C BT-O CS 10 VR-1 NOTE 13
 • BT-C CS 10
 • FST CS
 • PIT 2Y

***** END REPORT *****

** DATE 19 JUL PS 08:26:11 RID 10 04 MAR 85 RAYMOND
 ** SYSTEM: CHEM. & VOL. CONTROL WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028601
 ** VALVE . PEID. . ISI . IST. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX . RELIEF .
 ** NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT. . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .
 ** F381 F-4 2 A,C 3 CK SA 0 AT-1 RR 1950 C VR-3 13
 CVT-O Q VR-S
 CVT-C RR VR-B
 PAS NA
 AT-1 RR 487.5C VR-3 14,3
 CVT-C RR VR-S,B
 VJ1 E-7 2 C .75 CK SA 0 RVT SY 14,3
 V135 D-2 2 A,C .75 CK SA C RVT SY 14,3
 V112 H-3 2 C 2 RV SA C RVT SY 14,3
 V173 E-7 2 C .75 RV SA C RVT SY 14,3
 V121 D-3 2 C 2 RV SA C RVT SY 14,3
 HV-1112 D-2 2 A 2 GL MO 0 AT-1 RR 1300 C VR-5 NOTES 14,36 13
 BT-C CS 10 VR-B
 PIT 2Y
 AT-1 RR 1300 C VR-5 NOTES 14,36 14
 BT-C CS 10 VR-B
 PIT 2Y
 HV-1143 E-3 2 B 1 TW MO 0 PAS NA 13
 HV-1145 G-7 2 B 2 GL AO C PAS NA
 HV-1146 F-7 2 B 3 GL AO 0 PAS NA
 HV-1147 F-7 2 B 3 GL AO C PAS NA
 HV-1152 G-2 2 A 3 GL AO 0 AT-1 RR 1950 C VR-1 NOTE 15 13
 BT-C CS 10 VR-S
 FST CS VR-B 14
 PIT 2Y
 HV-1153A D-7 1 B 1 GL SO C BT-0 Q 10 VR-1
 HT-C Q 10
 FST Q
 PIT 2Y
 BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 HV-1153B D-7 1 B 1 GL SO C BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 HV-1154A D-8 1 B 1 GL SO C BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 HV-1154B D-8 1 B 1 GL SO C BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 BT-0 Q 10 VR-1
 BT-C Q 10
 FST Q
 PIT 2Y
 HV-1160 F-3 2 A 3 GL SO 0 AT-1 RR 1950 C VR-1 NOTE 15 13
 BT-C CS 10 VR-S
 FST CS VR-B 14
 HCV-123 E-5 2 B 1 GL AO C BT-C Q 60 VR-1
 FST Q
 PIT 2Y
 BT-C CS >15 VR-1 > OR = TO 15
 FST CS NOTE 16
 PIT 2Y
 LCV-459 G-7 2 B 3 GL AO 0 BT-C CS >15 VR-1 > OR = TO 15
 FST CS NOTE 16
 PIT 2Y
 LCV-460 G-7 1 B 3 GL AO 0 BT-C CS >15 VR-1 > OR = TO 15
 FST CS NOTE 16
 PIT 2Y

***** END REPORT *****

** THE MAPPER SYSTEM **

DATE 071985

PAGE 13

*DATE 19 JUN 85 16:50:12 RID 11 04 MAR 85 RAYMOND
*SYSTEM: CHEM. & VOL. CONTROL WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02BG02

* VALVE . PEID. . ISI . IST. . VALVE. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX. . RELIEF. .
* NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT. . FRE. . TIME. . LEAKG. . REQUEST. . REMARKS .

VALVE	PEID	ISI	IST	VALVE	VALVE	ACT	NORM	TEST	TST	MAX STRK	MAX	RELIEF	REQUEST	REMARKS
V020	G-6	3	C	.75	RV	SA	C	RVT	SY					
S-14	G-4	2	C	2	RV	SA	C	RVT	SY					
TV-20	H-5	3	B	6	BT	AO	O	PAS	NA					
LLV-112A	E-2	2	B	3	TWY	AO	NA	PAS	NA					

***** END REPORT *****

DATE 18 JUL 85	16:50:11	RID	12	04 MAR 85	RAYMOND	WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028G03		
* SYSTEM: CHEM. E VOL. CONTROL								
* VALVE	* PLID.	* ISI	* 1ST	* VALVL.	* VALVE	* ACT.	* NORM.	* TEST
* NO.	* COOR.	* CLASS.	* CAT.	* SIZE.	* TYPE.	* TYPE.	* POS.	* RQMT.
* F123	H-2	C	2	RV	SA	C	RVT	SY
B440	F-6	C	4	CK	SA	C	RVT	SY
B461A	C-4	C	4	CK	SA	C	CVT-O	O
B461B	B-4	C	4	CK	SA	C	CVT-O	O
B497	E-4	C	3	CK	SA	O	CVT-C	O
B546A	C-7	C	6	CK	SA	C	CVT-O	RR
B546B	B-7	C	6	CK	SA	C	CVT-O	RR
V091	E-4	C	2	CK	SA	C	CVT-O	VR-7
V075	E-4	C	2	CK	SA	C	CVT-O	VR-7
HV-0105	E-2	C	3	GA	MO	O	AT-1	RR
							BT-C	CS 10 VR-5
							PIT	2Y VR-4
HV-0116	E-2	B	3	GA	MO	O	BT-C	CS 10
							PIT	2Y
HV-0119	E-5	B	2	GL	MO	C	PAS	NA
HV-0110	E-4	B	2	GL	MO	O	BT-O	O 10
							BT-C	J 10
HV-0111	E-4	B	2	GL	MO	O	PIT	2Y
							BT-O	O 10
							BT-C	O 10
							PIT	2Y
FCV-1c1	D-4	B	3	GL	MO	O	PAS	NA
FLV-1c2	E-3	B	3	GL	AO	O	PAS	NA
LCV-1128	F-6	B	4	GA	MO	O	BT-C	CS 10
							PIT	2Y
LCV-1120	F-6	B	4	GA	MO	O	BT-C	CS 10
							PIT	2Y
V589	B-4	C	1	CK	SA	C	CVT-O	O
							CVT-C	O
V590	C-4	C	1	CK	SA	C	CVT-O	O
							CVT-C	O
V591	D-3	C	2	CK	SA	C	CVT-C	CS
HV-0357A	C-4	B	1	GL	SO	C	BT-O	O 10
							BT-C	O 10
HV-0357B	B-4	B	1	GL	SO	C	PIT	2Y
							BT-O	O 10
							BT-C	O 10
FLV-1118	G-5	B	2	DIA	AO	C	PIT	2Y
V524	C-6	C	8	RV	SA	C	PAS	NA
V525	A-6	C	8	RV	SA	C	RVT	SY
F120	G-7	C	3	RV	SA	C	RVT	SY
F134	C-7	C	8	RV	SA	C	RVT	SY
Vc07	G-4	C	8	RV	SA	C	RVT	SY
***** END REPORT *****								

DATE 23 MAR 85 16:20:47 RID 49 04 MAR 85 LYON

WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02BG04

SYSTEM: CHEM. & VOL. CONTROL VALVE PCTD. IST. IST. VALVE. VALVE. ACT. NORM. TEST. TST. MAX STRK. MAX RELIEF

NO. COOR. CLASS. CAT. SIZE. TYPE. TYPE. POS. RQMT. FRE. TIME. LEAKG. REQUEST. REMARKS

7006 E-4 2 C E RV SA C RVT SY

***** END REPORT *****

*DATE 20 JUN 75 07:44:33 RID 13 04 MAR 85 RAYMOND
 *SYSTEM: CHEM. & VOL. CONTROL WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-028605
 * VALVE * PLID * IST * IST * VALVE * VALVE * ACT * NORM * TEST * TST * MAX STRK * MAX * RELIEF *
 * NO. * COOR. * CLASS * CAT * SIZE * TYPE * TYPE * POS * RQMT * FRE * TIME * LEAKG * REQUEST * REMARKS

V145	B-8	3	C	3	CK	SA	C	CVT-0	Q
V147	B-4	3	C	3	CK	SA	C	CVT-0	Q
V155	B-6	3	C	75	CK	SA	C	PAS	NA
V154	B-7	3	C	3	CK	SA	C	PAS	NA
V165	A-6	3	C	3	CK	SA	C	CVT-0	Q
V174	A-4	3	C	3	CK	SA	C	CVT-0	CS
V120	E-2	3	C	3	CK	SA	C	PAS	NA
V174	A-4	3	C	3	CK	SA	C	PAS	NA
HV-104	A-4	3	C	3	UL	M0	C	BT-0	Q 10
								PIT	2Y
FCV-110A	B-2	3	B	2	GL	A0	C	BT-0	Q 10
								FST	QY
								PIT	2Y
V167	B-4	3	C	75	CK	SA	C	PAS	NA
V172	B-2	3	C	1	CK	SA	C	PAS	NA

NOTE 19

NOTE 36

VR-1

***** END REPORT *****

DATE 18 JUL 85 16:52:56 RID 14 04 MAR 85 RAYMOND
 SYSTEM: REACTOR MAKE-UP WATER WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02BL01
 VALVE . PLID. . ISI. . IST. . VALVE. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX. . RELIEF.
 NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT. . FRE. . TIME. . LEAKG. . REQUEST. . REMARKS
 1248 B-3 C A,C 3 CK SA 0 AT-1 RR 1950 C VR-3
 12-047 B-4 C A 3 DIA AD 0 AT-1 RR VR-5,8
 ET-C 0 10 VR-1
 FST 0 VR-5,8
 PIT 2Y

***** END REPORT *****

DATE 18 JUL 85 16:54:05 RID 15 04 MAP 85 RAYMOND
 SYSTEM: STEAM GEN. BLOWDOWN
 VALVE * PEID * ISI * IST * VALVE * VALVE * ACT * NORM * TEST * TST * MAX STRK * MAX * RELIEF
 NO. * COOR. * CLASS. * CAT. * SIZE. * TYPE. * TYPE. * POS. * ROMT * FRE. * TIME * LEAKG. * REQUEST. * REMARKS
 VCG2 A-4 2 A 3 GA M C AT-1 RR 1950 C VR-5,B
 V4L E-3 2 A 3 GA M C AT-1 RR 1950 C VR-5,B
 HV-1 F-5 2 B 4 GL AO O BT-C Q 10 VR-1 NOTE 20
 HV-2 E-5 2 B 4 GL AO O PIT 2Y
 HV-3 C-5 C 3 4 GL AO O BT-C Q 10 VR-1 NOTE 20
 HV-4 A-5 2 B 4 GL AO O FST Q
 HV-10 G-7 2 B 1 GL SO C PIT 2Y
 HV-10 E-7 2 B 1 GL SO C BT-C Q 5 VR-1
 HV-10 FST Q VR-2
 HV-11 D-7 2 B 1 GL SO C PIT 2Y
 HV-11 BT-C Q 5 VR-1
 HV-11 FST Q VR-2
 HV-12 B-7 2 B 1 GL SO C PIT 2Y
 HV-12 BT-C Q 5 VR-1
 HV-12 FST Q VR-2
 HV-13 G-7 2 B 1 GL SO C BT-C Q 5 VR-1
 HV-13 FST Q VR-2
 HV-14 E-7 2 B 1 GL SO C PIT 2Y
 HV-14 BT-C Q 5 VR-1
 HV-14 FST Q VR-2
 HV-15 C-7 2 B 1 GL SO C PIT 2Y
 HV-15 BT-C Q 5 VR-1
 HV-15 FST Q VR-2
 HV-16 B-7 2 B 1 GL SO C PIT 2Y
 HV-16 BT-C Q 5 VR-1
 HV-16 FST Q VR-2
 HV-17 C-7 2 B 1 GL SO C PIT 2Y
 HV-17 BT-C Q 5 VR-1
 HV-17 FST Q VR-2
 HV-18 B-7 2 B 1 GL SO C PIT 2Y
 HV-18 BT-C Q 5 VR-1
 HV-18 FST Q VR-2
 HV-19 G-6 2 B 1 GL SO C PIT 2Y
 HV-19 BT-C Q 5 VR-1
 HV-19 FST Q VR-2
 HV-20 E-6 2 B 1 GL SO C PIT 2Y
 HV-20 BT-C Q 5 VR-1
 HV-20 FST Q VR-2
 HV-21 C-6 2 B 1 GL SO C PIT 2Y
 HV-21 BT-C Q 5 VR-1
 HV-21 FST Q VR-2
 HV-22 B-6 2 B 1 GL SO C PIT 2Y
 HV-22 BT-C Q 5 VR-1
 HV-22 FST Q VR-2
 **** END REPORT ****

4,3

DATE 07 JUN 85 05:25:03 RID 16 04 MAR 85 RAYMOND
 SYSTEM: BUR, REF, WTR, STOR. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02BND1
 • VALVE • PLID • ISI • IST • VALVE • ACT • NORM • TEST • TST • MAX STRK • MAX • RELIEF
 • NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT • FRE. • TIME • LEAKG. • REQUEST. • REMARKS
 HV-3 C-3 E B 1P GA MO 0 BT-O Q 65 NOTE 36
 BT-C Q 65
 PIT 2Y
 BT-O Q 65
 BT-C Q 65
 HV-4 A-3 E B 12 GA MO 0 NOTE 36
 BT-O Q 15
 BT-C Q 15
 PIT 2Y
 BT-O Q 15
 BT-C Q 15
 HV-2806A B-5 E B 6 GA MO 0 NOTE 36
 PIT 2Y
 BT-O Q 15
 BT-C Q 15
 HV-2806B E-3 E B 6 GA MO 0 NOTE 36
 PIT 2Y
 BT-O Q 15
 BT-C Q 15
 HV-2812A B-3 E B 14 GA MO 0 NOTE 36
 PIT 2Y
 BT-O Q 17
 BT-C Q 17
 HV-2812B D-3 E B 14 GA MO 0 NOTE 36
 PIT 2Y
 BT-O Q 17
 BT-C Q 17
 HV-2813 B-7 E B 2 GL MO 0 NOTE 21,36
 BT-C CS 10
 PIT 2Y
 LCV-8330A E-5 E B 3 GL AO C PAS NA
 LCV-8600H E-5 E B 3 GL AO C PAS NA
 LCV-1120 A-5 E B 8 GA MO C BT-O CS 15 NOTE 22,36
 BT-C CS 15
 PIT 2Y
 LCV-1120E E-3 E B 8 GA MO C BT-O CS 15 NOTE 22,36
 BT-C CS 15
 PIT 2Y

***** END REPORT *****

*DATE 20 JUN 85 07:48:36 RID 17 04 MAR 85 RAYMOND

*SYSTEM: FUEL POOL COOL. & CL.

WCGS INSERVICE TESTING PROGRAM DWG. NO.: H-02ECD1

* VALVE . . PLID. . . ISI. . . IST. . . VALVE. . . ACT. . . NORM. . . TEST. . . TST. . . MAX STRK. . . MAX. . . RELIEF. . .

* NO. . . COOR. . . CLASS. . . CAT. . . SIZE. . . TYPE. . . POS. . . RQMT. . . FRE. . . TIME. . . LEAKG. . . REQUEST. . . REMARKS . . .

===== . . ===== . . ===== . . ===== . . ===== . . ===== . . ===== . . ===== . . ===== . . ===== . . ===== . . =====

HV-11 H-S 3 B 12 BTF MO 0 BT-C Q 60 NOTE 36

HV-12 F-S 3 B 12 BTF MO 0 BT-C Q 60 NOTE 36

PIT 2Y

PIT 2Y

PIT 2Y

V104 H-b 3 C 10 CK SA C CVT-O Q

V113 E-b 3 C 10 CK SA C CVT-O Q

V115 E-L 3 C A RV SA C RVT SY

V117 G-L 3 C A RV SA C RVT SY

V118 E-S 3 C A RV SA C RVT SY

V119 G-S 3 C A RV SA C RVT SY

***** END REPORT *****

DATE 18 JUL 85 16:55:01 RID 18 04 MAR 85 RAYMOND
 SYSTEM: FUEL POOL COOL. E CL. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EC02
 VALVE . P#ID . ISI . IST . VALVE . ACT . NORM . TEST . TST . MAX_STRK . MAX . RELIEF .
 NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. REQUEST . REMARKS
 VU73 C-5 u A b GA M C AT-1 RR 3900 C VR-5,8 4,
 VU74 C-5 u A b GA M C AT-1 RR 3900 C VR-5,8 3
 VU77 D-7 u A b GA M C AT-1 RR 3900 C VR-5,8
 VU73 D-7 u A b GA M C AT-1 RR 3900 C VR-5,8
 VU75 B-5 u A 3 GA M C AT-1 RR 1950 C VR-5,8
 VU76 B-5 u A 3 GA M C AT-1 RR 1950 C VR-5,8

***** END REPORT *****

* DATE 20 JUN AS 07:51:32 RID 19 04 MAR 85 RAYMOND

* SYSTEM: ESSENTIAL SEPV. WTR.

* VALVE * * PCID... * ISI... * IST... * VALVE... * ACT... * NORM.

* NO. * COOR. * CLASS. * CAT. * SIZE. * TYPE. * POS. * TEST... * MAX STRK. * MAX RELIEF * REQUEST * REMARKS

* VCLC F-4 3 C 30 CK SA C LVT-O 0

* VCLC C-4 3 C 30 CK SA C CVT-C 0

* VCLC F-2 3 C 30 CK SA C CVT-C 0

* VCLC F-2 3 C 30 CK SA C CVT-C 0

* VCLC F-2 3 B 30 STF MO O CVT-C RR

* VCLC C-2 3 B 30 BTF MO O BT-C Q

* VCLC C-2 3 B 30 BTF MO O PIT 2Y

* VCLC F-4 3 B 3 GA MO C PIT 2Y

* VCLC C-4 3 B 3 GA MO C ET-O 0

* VCLC C-4 3 B 3 GA MO C PIT 2Y

* VCLC E-5 3 B 3 GA MO C BT-O 0

* VCLC E-5 3 B 3 GA MO C PIT 2Y

* VCLC A-5 3 B 3 GA MO O BT-C Q

* VCLC F-4 3 B 3 GA MO O BT-C Q

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

* VCLC B-4 3 B 3 GA MO C BT-O 0

* VCLC B-4 3 B 3 GA MO C PIT 2Y

***** END REPORT *****

** THE MAPPER SYSTEM **

DATE 071985

PAGE 22

* DATE 20 JUN 85 07:51:56 RID 20 04 MAR 85 RAYMOND
* SYSTEM: ESSENTIAL SERV. WTR. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EF01
* VALVE * PLID... ISI... IST... VALVE... VALVE... ACT... NORM. TEST... TST... MAX STRK... MAX... RELIEF...
* NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. REQUEST. . REMARKS
* HV-23 F-7 3 8 30 BTF MO 0 BT-C Q 30 NOTE 36
* HV-24 E-7 3 3 30 BTF MO 0 PIT 2Y
* HV-25 F-7 3 8 30 BTF MO 0 BT-C Q 30 NOTE 36
* HV-26 E-7 3 8 30 BTF MO 0 PIT 2Y
* HV-44 P-7 3 8 2 GL AO 0 BT-C Q 5 VR-1
* VR-2
* VU76 B-6 3 C 2.5 CK SA C FST Q VR-2
* CVT-C Q
**** END REPORT ****

DATE 17 JUL 85	07:0A:15	RIO	21	04 MAH 85 RAYMOND
SYSTEM: ESSENTIAL SERV. WTR.				WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EF02
* VALVE . . . PLID. . . ISI. . . IST. . . VALVE . . . ACT. . . NORM. . . TEST . . . TST. . . MAX STRK. . . MAX. . . RELIEF . . .				
* NO. . . COOR. . . CLASS. . . CAT. . . SIZE. . . TYPE. . . POS. . . TIME . . . FRE. . . RQMT. . . REQUEST. . . REMARKS . . .				
VU4-2 F-4 3 C 2.5 CK SA Q CVT-C Q				
HV-1 L-7 A 4 BTF MO 0 AT-1 RR VR-S NOTE 3b				
HV-32 B-7 2 A 14 BTF MO 0 AT-1 BT-C Q VR-B NOTE 3b				
HV-3 G-7 2 A 14 BTF MO 0 AT-1 PIT 2Y VR-D NOTE 3b				
HV-34 B-7 2 A 14 BTF MO 0 AT-1 RR 2Y VR-E NOTE 3b				
HV-37 G-2 3 A 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-38 C-2 3 B 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-39 F-2 3 B 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-40 D-2 3 B 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-41 F-2 3 B 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-42 D-2 3 B 30 BTF MO C BT-C Q VR-L NOTE 3b				
HV-43 E-7 3 B 2 GL AO 0 BT-C Q VR-L NOTE 3b				
HV-45 G-6 2 A 14 BTF MO 0 AT-1 FST Q VR-E NOTE 3b				
HV-46 E-6 2 A 14 BTF MO 0 AT-1 ET-C Q VR-B NOTE 3b				
HV-47 G-6 2 A 10 BTF MO 0 AT-1 PIT 2Y VR-B NOTE 3b				
HV-48 C-6 2 A 10 BTF MO 0 AT-1 RR 2Y VR-B NOTE 3b				
HV-49 G-6 2 A 14 BTF MO C AT-1 RR 2Y VR-B NOTE 3b				
HV-50 B-6 2 A 14 BTF MO 0 AT-1 BT-C Q VR-B NOTE 3b				
HV-51 G-4 3 B 24 BTF MO 0/C BT-O Q VR-B NOTE 3b				
HV-52 C-4 3 B 24 BTF MO 0/C BT-O Q VR-B NOTE 3b				
HV-53 G-3 3 B 24 BTF MO 0/C BT-C Q VR-B NOTE 3b				
HV-60 C-3 3 B 24 BTF MO 0/C BT-C Q VR-B NOTE 3b				
HV-57 E-3 3 B 1 GA SO 0 BT-C Q VR-E NOTE 23				

Rev 07/85

Page 115

DATE 071985

PAGE 24

IV-CB	D-3	B	1	GA	50	0	FST PIT	0	2Y
							BT-C	0	
							FST	0	
							PIT	0	2Y

***** END REPORT *****

NOTE 23

VR-2

NOTE 23

* DATE 20 JUN 85 07:56:36 RID 22 04 MAR 85 RAYMOND
 * SYSTEM: COMPONENT COOLING WTR. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EG01
 * VALVE . . . PVID. . . ISI. . . IST. . . VALVE. . . VALVE. . . ACT. . . NORM. . . TEST. . . TST. . . MAX STRK. . . MAX. . . RELIEF . .
 * NO. . . COOR. . . CLASS. . . CAT. . . SIZE. . . TYPE. . . TYPE. . . POS. . . RQHT. . . FRE. . . TIME. . . LEAKG. . . REQUEST. . . REMARKS . .
 * VU01 G-3 3 C 20 CK SA C CVT-O Q
 * VU02 F-3 3 C 20 CK SA C CVT-C Q
 * VU03 LVT-O Q
 * VU04 CVT-C Q
 * VU05 CVT-O Q
 * VU06 CVT-C Q
 * VU07 CVT-C Q
 * VU08 CVT-O Q
 * VU09 CVT-C Q
 * VU10 CVT-O Q
 * VU11 CVT-C Q
 * VU12 D-6 3 C 18 CK SA O/C CVT-O CS
 * VU13 D-6 3 C 1A CK SA O/C CVT-O CS NOTE 24
 * VU14 G-6 3 C 2 RV SA C RVT SY
 * VU15 C-4 3 C 2 RV SA C RVT SY
 * VU16 G-6 3 C 1 RV SA C RVT SY
 * VU17 C-6 3 C 1.5 RV SA C RVT SY
 * HV-11 F-7 3 B 1.5 GL MO C BT-O Q 23 NOTE 36
 * HV-12 C-7 3 B 1.5 GL MO C BT-O Q 23 NOTE 36
 * HV-13 F-7 3 B 1.5 GL MO C BT-O Q 23 NOTE 36
 * HV-14 C-7 3 B 1.5 GL MO C BT-O Q 23 NOTE 36
 * HV-15 D-6 3 B 18 BTF MO O BT-C CS 60 NOTES 24,36
 * HV-16 D-6 3 B 18 BTF MO O BT-C CS 60 NOTES 24,36
 * LV-1 G-7 3 B 3 GL AO C PIT 2Y
 * LV-2 C-7 3 B 3 GL AO C PAS NA
 * LV-3 G-6 3 B 2 GL AO O BT-C Q 5 VR-1
 * FV-10 C-6 3 B 2 GL AO O FST Q VR-2
 * FV-11 FV-12
 * FV-13 FV-14
 * FV-15 FV-16

***** END REPORT *****

	DATE 20 JUN 85	08:16:48	RID	23	04 MARS 85 RAYMOND	WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EG02
*	SYSTEM: COMPONENT COOLING WTR.					WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EG02
*	VALVE	PLID	ISI	VALVE	NORM	MAX STRK. MAX RELIEF
*	NO.	COOR.	CLASS.	ACT.	TEST	TST. MAX STRK. MAX RELIEF
*			CAT.	SIZE.	TIME	TIME
*				TYPE	POS.	LEAKG. REQUEST
*				TYPE	TYPE	REQUEST
*	VU3b	G-5	C	18	CK	0 CVT-0 Q
*	VU4	C-H	C	6	RV	0 CVT-0 Q
*	VU5	C-b	C	6	RV	0 CVT-0 Q
*	VU1	F-5	C	18	CK	0 CVT-0 Q
*	VU24	G-b	C	6	RV	0 CVT-0 Q
*	VU27	G-b	C	6	RV	0 CVT-0 Q
*	VU23	G-5	B	18	BTF	0 CVT-0 Q
*	VU14	E-5	B	18	BTF	0 CVT-0 Q
*	VU10	G-4	B	18	BTF	0 CVT-0 Q
*	HV-402	C-4	B	18	BTF	0 CVT-0 Q
*	TU-29	G-b	B	20	BTF	0 CVT-0 Q
*	HV-30	C-b	B	20	BTF	0 CVT-0 Q
*	HV-72	G-2	B	2	GL	0 CVT-0 Q
*	HV-73	G-2	B	2	GL	0 CVT-0 Q
*	HV-74	G-1	B	2	GL	0 CVT-0 Q
*	HV-75	G-1	B	2	GL	0 CVT-0 Q

NOTE 3b

NOTE 3b

VR-1

VR-1

NOTE 3b

NOTE 3b

NOTE 3b

NOTE 3b

***** END REPORT *****

DATE 19 JUL 85 07:10:36 RID 24 04 MAR 85 RAYMOND									
SYSTEM: COMPONENT COOLING WTR. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EG03									
VALVE . PGID . ISI . IST . VALVE . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .									
NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .									
V124	D-4	3	C	4	CK	SA	0	PAS	NA
V125	D-5	3	C	12	CK	SA	0	PAS	NA
V274	H-4	E	A,C	12	CK	SA	0	AT-1	RR
								CVT-0	Q
								CVT-C	RR
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q
								PIT	2Y
								AT-1	RR
								BT-C	Q

DATE 071985

PAGE 26

DT-C
PTI
0 30
2Y

***** END REPORT *****

DATE 19 JUL 85 07:11:58 RID 25 04 MAR 85 RAYMOND							
SYSTEM: RESIDUAL HEAT REMOVAL				WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EJ01			
*	VALVE	P.ID.	ISI	IST.	VALVE	VALVE	ACT.
*	NO.	COOR.	CLASS.	CAT.	SIZE.	TYPE.	NORM.
*						TYPE.	TEST.
*						POS.	TST.
*						RQMT.	MAX STRK.
*						FRE.	MAX.
*						TIME	RELIEF
*						LEAKG.	REQUEST.
*							REMARKS
7715A	F-7	E	C	3	PV	SA	C
7716P	C-7	C	C	3	PV	SA	C
7731A	G-4	2	C	10	CK	SA	C
7731P	C-4	2	C	10	CK	SA	C
F641A	E-2	1	C	6	CK	SA	C
						RVT	5Y
						RVT	5Y
						CVT-O	Q
						CVT-O	Q
						AT-2	RR
						CVT-O	CS
						CVT-C	RR
						AT-2	RR
						CVT-O	CS
						CVT-C	RR
						1.0 G	VR-6
						VR-4	NOTE 37
							3
6418	D-2	1	C	6	CK	SA	C
						AT-2	RR
						CVT-O	CS
						CVT-C	RR
						1.0 G	VR-6
						VR-4	NOTE 37
							3
6458A	F-6	2	C	14	CK	SA	C
8458B	B-6	2	C	14	CK	SA	C
E1L7A	G-3	2	C	8	CK	SA	C
E1H10	A-4	2	C	8	CK	SA	C
HV-14	H-5	2	B	1	GL	SO	C
HV-15	A-5	2	B	1	GL	SO	C
HV-4701A	F-8	1	A	12	GA	MO	C
						CVT-O	Q
						CVT-O	Q
						CVT-O	CS
						CVT-C	CS
						PAS	NA
						PAS	NA
						AT-2	RR
						BT-0	CS 120
						BT-C	CS 120
						PIT	2Y
						AT-2	RR
						BT-0	CS 120
						BT-C	CS 120
						PIT	2Y
HV-4701B	B-2	1	A	12	GA	MO	C
						BT-0	CS 120
						BT-C	CS 120
						PIT	2Y
						BT-0	CS 12
						BT-C	CS 12
						PIT	2Y
HV-4716A	E-3	2	B	10	GA	MO	O
						BT-0	CS 12
						BT-C	CS 12
						PIT	2Y
HV-4716B	D-3	2	B	10	GA	MO	O
						BT-0	CS 12
						BT-C	CS 12
						PIT	2Y
HV-8804A	G-4	2	B	8	GA	MO	C
						BT-0	CS 10
						PIT	2Y
HV-8804B	A-4	2	B	8	GA	MO	C
						BT-0	CS 10
						PIT	2Y
HV-8809A	G-3	2	B	10	GA	MO	O
						BT-0	CS 15
						BT-C	CS 15
						PIT	2Y
HV-8809B	C-3	2	B	10	GA	MO	O
						BT-0	CS 15
						BT-C	CS 15
						PIT	2Y
HV-6811A	E-7	2	B	14	GA	MO	C
						BT-0	RR 18
						BT-C	RR 18
						PIT	2Y
HV-6811B	D-7	2	B	14	GA	MO	C
						BT-0	RR 18
						BT-C	RR 18
						PIT	2Y
HV-4840	E-3	2	B	10	GA	MO	C
						BT-0	CS 15
						BT-C	CS 15
						PIT	2Y
FCV-610	H-6	2	B	2	GA	MO	O
						BT-C	Q 10
						PIT	2Y
FCV-611	A-5	2	B	2	GA	MO	O
						BT-C	Q 10
						PIT	2Y
FCV-618	F-5	2	B	8	BTF	AO	C
						PAS	NA
FCV-619	B-5	2	B	8	BTF	AO	C
						PAS	NA

**** THE MAPPER SYSTEM ****

DATE 07/1985

PAGE 30

HCV-606	E-4	2	B	10	BTF	A0	0	PAS	NA		
HCV-607	C-4	2	B	10	BTF	A0	0	PAS	NA		
HCV-5525	E-2	2	B	.75	GL	A0	C	BT-C	Q	10	VR-1
								FST	Q		
								PIT	2Y		
HCV-5590A	F-2	2	B	.75	GL	A0	C	BT-C	Q	10	VR-1
								FST	Q		
HCV-5590B	C-2	2	B	.75	GL	A0	C	PIT	2Y		
								BT-C	Q	10	VR-1
								FST	Q		
HV-21	E-7	2	B	1	GL	S0	C	PIT	2Y		
								BT-C	Q	5	VR-1
								FST	Q		VR-2
HV-22	D-7	2	B	1	GL	S0	C	PIT	2Y		
								BT-C	Q	5	VR-1
								FST	Q		VR-2
HV-23	F-7	2	A	1	GA	S0	C	PIT	2Y		
								AT-1	RR	650 C	VR-1
								BT-C	Q	5	VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-24	D-6	2	A	1	GA	S0	C	AT-1	RR	650 C	VR-1
								BT-C	Q	5	VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-25	F-6	2	A	1	GA	S0	C	AT-1	RR	650 C	VR-1
								BT-C	Q	5	VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-26	D-6	2	A	1	GL	S0	C	AT-1	RR	650 C	VR-1
								BT-C	Q	5	VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
V124	H-5	3	C	1.5	RV	SA	C	RVT	5Y		
V125	D-5	3	C	1.5	RV	SA	C	RVT	5Y		
V156	G-5	3	C	.5	RV	SA	C	RVT	5Y		
V157	D-6	3	C	.5	RV	SA	C	RVT	5Y		

***** END REPORT *****

SYSTEM: HIGH PRESSURE COOLANT INJECTN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EM01													
VALVE	PLID.	ISI	1ST.	VALVE.	VALVE.	ACT.	NORM.	TEST	TST.	MAX STRK.	MAX	RELIEF	REMARKS
NO.				COOR.	CLASS.	CAT.	SIZE.	TYPE.	TYPE.	POS.	RQMT.	FRE.	TIME
													LEAKG.
													REQUEST.
													REMARKS
2472A	E-5	2	C	4	CK	SA	C	CVT-O	RR			VR-12	
2472B	D-5	2	C	4	CK	SA	C	CVT-O	RR			VR-12	
2472A	E-7	2	C	5	CK	SA	C	CVP-O	Q			VR-14	
								CVT-U	RR				
								CVP-O	Q			VR-14	
								CVT-O	RR				
VU01	F-3	2	A,C	2	CK	SA	C	AT-2	RR		1.0 G	VR-6	1.3
								LVT-O	RR			VR-12	
								CVT-C	RR			VR-13	
VU02	E-3	1	A,C	2	CK	SA	C	AT-2	RR		1.0 G	VR-6	1.3
								CVT-O	RR			VR-12	
								CVT-C	RR			VR-13	
VU03	D-3	1	A,C	2	CK	SA	C	AT-2	RR		1.0 G	VR-6	1.3
								CVT-O	RR			VR-12	
								CVT-C	RR			VR-13	
VU04	C-3	1	A,C	2	CK	SA	C	AT-2	RR		1.0 G	VR-6	1.3
								CVT-O	RR			VR-12	
								CVT-C	RR			VR-13	
VU05	A-6	2	C	1.5	CK	SA	C	CVT-O	Q				
VU06	F-6	2	A,C	1	CK	SA	C	AT-1	RR		650 C	VR-5	1.3
								CVT-C	RR			VR-5,8	
VU07	A-5	2	C	1.5	CK	SA	C	CVT-O	Q				1.3,4
HV-5802A	E-4	2	B	4	GA	MO	C	BT-O	Q	10			NOTE 36
								BT-C	Q	10			
								PIT	2Y				
HV-5802B	D-4	2	B	4	GA	MO	C	BT-O	Q	10			NOTE 36
								BT-C	Q	10			
								PIT	2Y				
V156	D-6	3	C	.8	RV	SA	C	RVT	SY				
V157	F-6	3	C	.8	RV	SA	C	RVT	SY				
HV-5807A	G-7	2	B	b	GA	MO	C	BT-O	Q	15			NOTE 36
								PIT	2Y				
HV-5807B	F-7	2	B	b	GA	MO	C	ET-O	Q	15			NOTE 36
								PIT	2Y				
HV-5814A	B-6	2	B	1.5	GL	MO	O	BT-C	Q	10			NOTE 36
								PIT	2Y				
HV-5814B	B-5	2	B	1.5	GL	MO	O	BT-C	Q	10			NOTE 36
								PIT	2Y				
HV-5821A	E-4	2	B	4	GA	MO	O	BT-C	Q	10			NOTE 36
								PIT	2Y				
HV-5821B	D-4	2	B	4	GA	MO	O	BT-C	Q	10			NOTE 36
								PIT	2Y				
HV-5823	C-4	2	B	.75	GL	AO	C	BT-C	Q	10		VR-1	
								FST	Q				
								PIT	2Y				
HV-5824	D-3	2	B	.75	GL	AO	C	BT-C	Q	10		VR-1	
								FST	Q				
								PIT	2Y				
HV-5835	B-4	2	B	4	GA	MO	O	BT-O	CS	10			NOTES 30,36
								BT-C	CS	10			
								PIT	2Y				
HV-5871	H-5	2	A	.75	GL	AO	C	AT-1	RR		487.5 C	VR-1	1.3
								BT-C	Q	10		VR-5	
								FST	Q			VR-E	
								PIT	2Y				1.4

** THE MAPPER SYSTEM **

DATE 071985

PAGE 324

HV-1863	G-4	E	B	.75	GL	AO	C	BT-C	Q	10		VR-1		
HV-1863	F-6	E	A	1	GL	AO	C	AT-1	RR					
HV-1863	F-6	E	A	1	GL	AO	C	BT-C	Q	5	650 C	VR-2		13
HV-1863	F-6	E	A	1	GL	AO	C	FST	Q			VR-5		
HV-1863	F-6	E	A	1	GL	AO	C	PIT	2Y			VR-6		13,4
HV-1869A	G-7	1	B	.75	GL	AO	C	PAS	NA					
HV-1869B	G-7	1	B	.75	GL	AO	C	PAS	NA					
HV-1869C	G-7	1	B	.75	GL	AO	C	PAS	NA					
HV-1869D	G-7	1	B	.75	GL	AO	C	PAS	NA					
HV-1869E	E-7	2	B	b	GA	MO	O	PAS	NA					
HV-1869F	D-7	2	B	b	GA	MO	O	PAS	NA					
HV-1869G	G-8	2	B	b	GA	MO	O	PAS	NA					
HV-1869H	H-5	2	A	.75	GL	AO	C	AT-1	RR		487.5 C	VR-1		13
HV-1869I	H-5	2	A	.75	GL	AO	C	BT-C	Q	10		VR-5		
HV-1869J	H-5	2	A	.75	GL	AO	C	FST	Q			VR-8		14
HV-1869K	H-5	2	A	.75	GL	AO	C	PIT	2Y					

***** END REPORT *****

*DATE 20 JUN 85 08:50:10 RIO 27 04 MAR 85 RAYMOND
 *SYSTEM: HIGH PRESSURE COOLANT INJECTN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EM02
 * VALVE . . PVID . . ISI . . IST . . VALVE . . VALVE . . ACT . . NORM . . TEST . . TST . . MAX STRK . . MAX . . RELIEF . .
 * NO. . . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT . . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .

Ref	D-3	A	C	3	CK	SA	C	AT-2	RR	1.0 G	VR-6	13
VOL4	E-6	2	C	1	CK	SA	O	NA	NA			NOTE 32
VOL7	D-6	2	C	1	CK	SA	O	NA	NA			NOTE 32
V240	C-7	2	C	1	CK	SA	O	CVT-O	RR		VR-22	
V241	B-7	2	C	1	CK	SA	O	CVT-O	RR		VR-22	
HV-801A	D-4	2	B	4	GA	MO	C	BT-O	Q 10			NOTE 36
								BT-C	Q 10			3
								PIT	2Y			
HV-8801B	D-4	2	B	4	GA	MO	C	BT-O	Q 10			NOTE 36
								BT-C	Q 10			3
								PIT	2Y			
HV-8803A	E-4	2	C	1	RV	SA	C	RVT	5Y			
	C-7	2	B	4	GA	MO	C	BT-O	Q 10			NOTE 36
								BT-C	Q 10			3
HV-8803B	A-7	2	B	4	GA	MO	C	PIT	2Y			NOTE 36
								BT-O	Q 10			3
								BT-C	Q 10			
								PIT	2Y			
HV-8837A	C-7	2	B	1	GL	SO	C	BT-O	Q 10		VR-1	
								BT-C	Q 10			3
								FST	Q			
HV-8837B	B-7	2	B	1	GL	SO	C	PIT	2Y			
								BT-O	Q 10		VR-1	
								BT-C	Q 10			3
								FST	Q			
HV-8843	C-4	2	B	.75	GL	AO	C	PIT	2Y			
								BT-C	Q 10		VR-1	
								FST	Q			
								PIT	2Y			
HV-8870A	E-5	2	B	1	GL	AO	C	FAS	NA			
HV-8870B	E-5	2	B	1	GL	AO	C	PAS	NA			
HV-8882	C-3	2	B	.75	GL	AO	C	PAS	NA			
HV-8883	D-6	2	B	.75	GL	AO	C	PAS	NA			

***** END REPORT *****

*DATE 20 JUN 85 08:31:35 RID 26 04 MAR 85 RAYMOND
 *SYSTEM: CONTAINMENT SPRAY WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02END01
 * VALVE . P&ID . ISI . IST . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .
 * NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 VUD1 G-7 2 C 12 CK SA C CVT-O RR VR-15
 VUD2 G-7 2 C 12 CK SA C CVP-O Q VR-17
 VUD4 G-5 2 C 10 CK SA C CVP-O Q VR-17
 VUD5 B-7 2 C 12 CK SA C CVT-O RR VR-15
 VUD6 B-7 2 C 12 CK SA C CVP-O Q VR-17
 VUD8 B-5 2 C 10 CK SA C CVP-O Q VR-17
 VUD9 B-4 2 C 10 CK SA C CVT-O RR VR-15
 VUL1 B-4 2 C 10 CK SA C CVT-O RR VR-15
 VUL2 B-4 2 C 10 CK SA C CVT-O RR VR-15
 HV-12 E-4 2 B 10 GA MO C dT-O Q 15 NOTE 36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 BT-C Q 15
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y
 HV-15 E-6 2 B 3 GA MO C BT-O CS 5 VR-2 NOTES 33,36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y
 HV-16 D-4 2 B 3 GA MO C BT-O CS 5 VR-2 NOTES 33,36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y
 VU57 F-5 2 C 75 RV SA C RVT 5Y
 VU58 F-5 2 C 1 RV SA C RVT 5Y
 VU59 F-5 2 C 3 CK SA C CVT-O Q
 V101 C-6 2 C 3 CK SA C CVT-O Q
 V102 F-5 2 C 1 RV SA C RVT 5Y
 HV-1 G-7 2 B 12 GA MO C BT-O RR 30 VR-16 NOTE 36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 BT-C RR 30
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y
 HV-16 G-4 2 B 10 GA MO C BT-O Q 15 NOTE 36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 BT-C Q 15
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y
 HV-17 B-7 2 B 12 GA MO C BT-O RR 30 VR-16 NOTE 36
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 BT-C RR 30
 *----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
 PIT 2Y

***** END REPORT *****

DATE 19 JUL 85 07:15:10 RID 29	04 MAR 85 RAYMOND	WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02EP01
* SYSTEM: ACC. SAFETY INJECTION	* PGID. ISI VALVE VALVE ACT NORM TEST TST MAX STRK MAX RELIEF	REMARKS
* VALVE	*	
* NO. . . COOR. . CLASS. . CAT. . SIZE. . TYPE. . POS. . RQMT . . FPE. . TIME . . LEAKG. . REQUEST. .		
P05A G-3 1 A,C 6 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
E815B F-3 1 A,C 6 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
E815C D-3 1 A,C 6 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
E815D C-3 1 A,C 6 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
E815E H-7 2 C 1 RV SA C RVT SY		
E815F F-7 2 C 1 RV SA C RVT SY		
E815G D-7 2 C 1 RV SA C RVT SY		
E815H C-7 2 C 1 RV SA C RVT SY		
E815A G-4 2 A,C 10 CK SA C AT-2 RR 1.0 G VR-6		13
	CVT-O RR	
	CVT-C RR	
A75EE E-4 2 A,C 10 CK SA C AT-2 RR 1.0 G VR-6		13
	CVT-O RR	
	CVT-C RR	
E95EC C-4 1 A,C 10 CK SA C AT-2 RR 1.0 G VR-6		13
	CVT-O RR	
	CVT-C RR	
E95ED B-4 1 A,C 10 CK SA C AT-2 RR 1.0 G VR-6		13
	CVT-O RR	
	CVT-C RR	
V01U G-3 1 A,C 2 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
V02U F-3 1 A,C 2 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
V03U D-3 1 A,C 2 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
V04U C-3 1 A,C 2 CK SA C AT-2 RR 1.0 G VR-4		13
	CVT-O RR	
	CVT-C RR	
V04E A-5 2 A,C 1 CK SA C AT-1 RR 150 C VR-3		13
	CVT-C RR	
HV-3815B A G-5 2 B 10 GA MO 0 ET-0 CS 12		NOTES 29,36
	BT-C CS 12	
	PIT 2Y	
Rev EHV-3815B C-5 2 B 10 GA MO 0 BT-0 CS 12		NOTES 29,36
	BT-C CS 12	
	PIT 2Y	
HV-3815D B-5 2 B 10 GA MO 0 BT-0 CS 12		NOTES 29,36
	BT-C CS 12	
	PIT 2Y	
HV-3875A H-6 2 B 1 GL AO C PAS NA		

HV-#	TYPE	SIZE	SHAPE	ANGLE	GLASS	AO	C	PAS	NA
HV-875B	F-6	2	B	1	GL	AO	C	PAS	NA
HV-875C	D-6	2	B	1	GL	AO	C	PAS	NA
HV-875D	C-6	2	B	1	GL	AO	C	PAS	NA
HV-8877A	F-4	2	B	.75	GL	AO	C	PAS	NA
HV-8877B	E-4	2	B	.75	GL	AO	C	PAS	NA
HV-8877C	C-4	2	B	.75	GL	AO	C	PAS	NA
HV-8877D	A-4	2	B	.75	GL	AO	C	PAS	NA
HV-8878A	G-5	2	B	1	GL	AO	C	PAS	NA
HV-8878B	E-5	2	B	1	GL	AO	C	PAS	NA
HV-8878C	D-5	2	B	1	GL	AO	C	PAS	NA
HV-8878D	C-2	2	B	1	GL	AO	C	PAS	NA
HV-8879A	G-4	2	B	.75	GL	AO	C	PAS	NA
HV-8879B	E-4	2	B	.75	GL	AO	C	PAS	NA
HV-8879C	D-4	2	B	.75	GL	AO	C	PAS	NA
HV-8879D	C-2	2	B	.75	GL	AO	C	PAS	NA
HV-8950A	H-7	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8950B	F-5	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8950C	F-7	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8950D	D-8	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8950E	D-7	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8950F	C-8	2	B	1	GL	SO	C	BT-O	RR 10 VR-1
								BT-C	RR 10 VR-18
								FST	RR
								PIT	2Y
HV-8860	A-4	2	A	2	GL	AO	C	AT-1	RR 1300 C VR-5
								BT-C	Q 10 VR-2
								FST	Q
								PIT	2Y

***** END REPORT *****

DATE 20 JUN 85 08:38:01 RID 30 04 MAR 85 RAYMOND
 SYSTEM: AUX TURB-AUX FD FMP TURB WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-Q2FC02
 VALVE . PLID . ISI . IST . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .
 NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .
 VJ01 G-b 2 C 4 CK SA C CVT-0 Q
 VJ02 G-b 2 C 4 CK SA C CVT-0 Q
 VJ03 G-b 3 C 4 CK SA C PAS NA
 VJ04 G-b 2 C 4 CK SA C CVT-0 Q
 VJ05 G-b 2 C 4 CK SA C CVT-0 Q
 FV-310 D-7 3 B 1 GL AO 0 BT-C Q S VR-1
 FST Q VR-2
 PIT 2Y
 FV-312 F-5 3 B 4 GA MO C BT-0 Q 10 NOTE 36
 LV-10 D-b 3 B 1 GL AO C PAS NA
 VJ94 E-3 N C .5 RV SA C RVT SY

***** END REPORT *****

DATE 19 JUL 85 07:16:56 RIO 31 04 MAR 85 RAYMOND
 SYSTEM: CONTAINMENT HYDROGEN CONTROL WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02GS01

VALVE * PLID * ISI * VALVE * ACT * NORM * TEST * TST * MAX STRK. * MAX RELIEF * REQUEST * REMARKS
 NO. * COOR. * CLASS. * CAT. * SITE. * TYPE. * POS. * ROHT. * TIME * LEAKG. *
 HV-3 E-5 A-1 GA 50 C AT-1 RR 650 C VR-1 3

HV-4	F-6	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 3
HV-5	D-5	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 3
HV-6	B-6	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 4
HV-7	P-L	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 4
HV-8	E-4	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 4
HV-9	F-5	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 4
HV-10	D-5	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 3
HV-11	B-4	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 3
HV-12	P-S	2	A	1	GA	50	C	AT-1	RR	5	650 C	VR-1	1 4
HV-13	F-4	2	A	b	BT	MO	C	AT-1	RR	5	3900 C	VR-1	1 3
HV-14	F-5	2	A	b	BT	MO	C	AT-1	RR	5	3900 C	VR-1	1 4
HV-15	F-4	2	A	b	BT	MO	C	AT-1	RR	5	3900 C	VR-1	1 3
HV-16	F-4	2	A	b	BT	MO	C	AT-1	RR	5	3900 C	VR-1	1 4

** 8100 - M-16A2 STICK M 41

DATE 8/24/05

٢٧

HV-30	E-2	2	B	1	GA	SO	C	PIT	2Y		
HV-31	D-4	2	A	1	GA	SO	0	PAS	NA		
								AT-1	RR		650 C VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-32	D-3	2	A	1	GA	SO	0	AT-1	RR		VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-33	C-4	2	A	1	GA	SO	0	PIT	2Y		VR-8
								AT-1	RR		VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
HV-34	C-4	2	A	1	GA	SO	0	PIT	2Y		VR-8
								AT-1	RR		VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-35	F-7	2	B	1	GA	SO	C	PAS	NA		
HV-36	D-6	2	A	1	GA	SO	0	AT-1	RR		3900 C VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-37	D-7	2	A	b	GA	SO	0	AT-1	RR		3900 C VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-38	C-h	2	A	b	GA	SO	0	AT-1	RR		3900 C VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
HV-39	C-e	2	A	b	GA	SO	0	AT-1	RR		3900 C VR-1
								BT-C	Q S		VR-2
								FST	Q		VR-5
								PIT	2Y		VR-8
VLE4	B-3	2	C	*75	CK	SA	C	PAS	NA		
VLE5	B-5	2	C	*75	CK	SA	C	PAS	NA		

END REPORT

*DATE 19 JUL 85 07:20:14 PID 32 04 MAR 85 RAYMOND

*SYSTEM: CONTAINMENT PURGE

* VALVE . PEID . ISI . IST . VALVE . ACT . NORM . TEST . MAX STRK . MAX RELIEF .

* NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .

H2-4	D-4	E	A	18	BTF	AO	0	AT-1	RR	21000C	VR-1	13
								BT-C	Q 3		VR-2	
								FST	Q		VR-5	
								PIT	2Y		VR-6	
								AT-1	RR	21000C	VR-1	14
								BT-C	Q 3		VR-2	
								FST	Q		VR-5	
								PIT	2Y		VR-6	
								AT-1	RP	23400C	VR-5	14
								BT-C	Q 10		VR-6	
								FST	Q			
								PIT	2Y			
								AT-1	RR	23400C	VR-5	13
								BT-C	Q 10		VR-6	
								FST	Q			
								PIT	2Y			
								AT-1	RR	23400C	VR-5	13
								BT-C	Q 10		VR-6	
								FST	Q			
								PIT	2Y			
								AT-1	RR	23400C	VR-5	13
								BT-C	Q 10		VR-6	
								FST	Q			
								PIT	2Y			
								AT-1	RR	21000C	VR-1	13
								BT-C	Q 3		VR-2	
								FST	Q		VR-5	
								PIT	2Y		VR-6	
								AT-1	RR	21000C	VR-1	14
								BT-C	Q 3		VR-2	
								FST	Q		VR-5	
								PIT	2Y		VR-6	

***** END REPORT *****

• DATE 19 JUL 85 07:20:51 RID 33 04 MAR 85 RAYMOND
 • SYSTEM: LIQUID RADWASTE WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02H801
 • VALVE • .PCID. • ISI • .1ST. • .VALVE. • .ACT. • .NORM. • .TEST. • .TST. • .MAX STRK. • .MAX. • .RELIEF. • .
 • NO. • .COOR. • .CLASS. • .CAT. • .SIZE. • .TYPE. • .TYPE. • .POS. • .RQMT. • .FRE. • .TIME. • .LEAKG. • .REQUEST. • . REMARKS • .
 • =====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.=====.

VU36	C-3	3	C	.75	RV	SA	C	RVT	5Y				
HV-7126	H-4	4	A	.75	DIA	AO	O	AT-1	RR	487.5C	VR-1	13	
								BT-C	Q	10	VR-5		
								FST	Q		VR-6	14	
								PIT	2Y				
HV-7136	F-3	2	A	3	DIA	AO	O	AT-1	RR	1950 C	VR-1	13	
								BT-C	Q	10	VR-5		
								FST	Q		VR-6	14	
								PIT	2Y				
HV-7150	H-5	2	A	.75	DIA	AO	O	AT-1	RR	487.5C	VR-1	13	
								BT-C	Q	10	VR-5		
								FST	Q		VR-6	14	
HV-7176	F-3	2	A	3	DIA	AO	O	AT-1	RR	1950 C	VR-1	13	
								BT-C	Q	10	VR-5		
								FST	Q		VR-6	14	
								PIT	2Y				

***** END F RT *****

• DATE 19 JUL 85 07:21:22 RID 34 04 MAR 85 RAYMOND
• SYSTEM: DECONTAMINATION WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02H001
• VALVE • .PCID. • ISI • .IST. • VALVE. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF. •
• NO. • .COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT. • FRE. • TIME. • LEAKG. • REQUEST. • REMARKS •
• ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== • ===== •
VOL1 P-7 2 A 2 GL M C AT-1 RR 1300 C VR-5,B 3,4
VOL2 P-7 2 A 2 GL M C AT-1 RR 1300 C VR-5,B 3,4
***** END REPORT *****

*DATE 20 JUN 85 DB:50:28 RID 35 04 MAR 85 RAYMOND
*SYSTEM: EMERGENCY FUEL OIL WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02JED1
* VALVE . PLID . ISI . IST . VALVE . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .
* NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. . REQUEST. . REMARKS .

V005 H-4 3 C 2 CK SA C CVT-0 Q
V072 D-4 3 C E CK SA C CVT-0 Q
***** END REPORT *****

DATE 19 JUL 85 07:21:51 RID 36 04 MAR 85 RAYMOND

SYSTEM: COMPRESSED AIR WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KA01

VALVE . PGID. . ISI . IST . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX RELIEF .

NO. COOR. CLASS. CAT. SIZE. TYPE. POS. RQMT. FRE. TIME LEAKG. REQUEST. REMARKS

V204	C-2	2	A,C	1.5	CK	SA	0	AT-1	RR	975 C	VR-3	3
FV-9	D-2	2	A	2	GL	AO	0	CVT-C	RR		VR-5,8	3
								AT-1	RR	1300 C	VR-1	
								BT-C	RR		VR-2	
								FST	RR		VR-5,8	4
								PIT	2Y		VR-19	
HV-10	C-1	2	3	1.5	GA	MO	C	BT-0	RR	12	VR-19	NOTE 36
								PIT	2Y			

***** END REPORT *****

DATE 071485

PAGE 72

DATE 19 JUL 85 07:22:50 RID 37 04 MAR 85 RAYMOND
 SYSTEM: COMPRESSED AIR WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KA02
 VALVE . . PCLD. . IST. . IST. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX RELIEF . .
 NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT. . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .
 V014 5-4 2 A,C 4 CK SA C AT-1 RR 2600 C VR-3 3
 V1- D-6 2 A 4 GL H C CVT-C RR VR-5,8 3,4
 V1- D-6 2 A 4 GL H C AT-1 RR 2600 C VR-5,8 3,4
 **** END REPORT ****

• DATE 20 JUN 85 08:53:51 RID 36 04 MAR 85 RAYMOND
 • SYSTEM: COMPRESSED AIR WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KA05
 • VALVE . . PVID . . ISI . . IST . . VALVE . . VALVE . . ACT . . NORM . . TEST . . TST . . MAX STRK . . MAX . . RELIEF . .
 • NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .
 • Vb43 G-L 3 A,C .75 CK SA C AT-3 RR 1.0 P VR-20 | 3
 • Vb47 F-S 3 A,C .75 CK SA C AT-3 RR 1.0 P VR-20 | 3
 • Vb50 D-E 3 A,C .75 CK SA C AT-3 RR 1.0 P VR-20 | 3
 • Vb51 B-S 3 A,C .75 CK SA C AT-3 RR 1.0 P VR-20 | 3
 • V723 H-? 3 C .8 RV SA C RVT SY
 • V724 F-E 3 C .8 RV SA C RVT SY
 • V725 D-7 3 C .8 RV SA C RVT SY
 • V726 B-B 3 C .8 RV SA C RVT SY

***** END REPORT *****

DATE 19 JUL 85 07:23:18 RID 39 04 MAR 85 RAYMOND
SYSTEM: CONTAINMENT BREATH AIR WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-12K801
VALVE . . PGID . . IST . . IST . . VALVE . . VALVE . . ACT . . NORM. . TEST . . TST . . MAX STRK. . . MAX . . RELIEF . .
NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . . FRE. . TIME . . LEAKG. . REQUEST. . REMARKS . .
VLO1 E-3 2 A Z GL M C AT-1 RR 1300 C VR-5,8 | 3,4
VLO2 E-4 2 A Z GL M C AT-1 RR 1300 C VR-5,8 | 3,4
***** END REPORT *****

• DATE 19 JUL 85 07:24:06 RID 40 04 MAR 85 RAYMOND
 • SYSTEM: FIRE PROTECTION CGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KCD2
 • VALVE • PLID. • IST. • VALVE. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF. •
 • NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • ROMT. • FPE. • TIME. • LEAKG. • REQUEST. • REMARKS
 • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== • ====== •
 V47C 2-b 2 A,C 4 CK SA C AT-1 RR 2600 C VR-3 3
 CVT-C RR VR-5,B
 HV-2F3 3-b 2 A 4 GA MO C AT-1 RR 2600 C VR-5 3
 BT-C Q 30 VR-6 NOTE 36 3
 PIT 2Y VR-6 4

***** END REPORT *****

*DATE 21 MAR 85 16:12:23 RID 41 04 MAR 85 LYON
*SYSTEM: STANDBY DIESEL GEN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ01
* VALVE . PLID. . ISI . IST. . VALVE. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX. . RELIEF .
* NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT. . FRE. . TIME. . LEAKG. . REQUEST. . REMARKS .
*----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- . ----- .
*V-1 A-6 3 B 1 GA MO 0 GT-C 0 12 NOTE 36
PIT 2Y

***** END REPORT *****

• DATE 04 JUL 85 15:55:54 RID 50 04 MAR 85 RAYMOND
 • SYSTEM: STANDBY DIESEL GFN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ02
 • VALVE • PLID • ISI • TEST • ACT • NORM • TEST • MAX STRK. • MAX RELIEF •
 • NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • POS. • RQMT. • FRE. • TIME • LEAKG. • REQUEST. • REMARKS •
 • V712A P-S 3 A,C .75 CK SA C AT-3 RR 1.33 P VR-1 1.3
 • V712A P-2 3 A,C .75 CK SA C LVT-C RR 1.33 P VR-1 1.3
 • V-1A F-3 3 B .4 GL SO C AT-3 RR 1.33 P VR-1 1.3
 • PV-1C F-3 3 B .4 GL SO C CVT-C RR 1.33 P VR-1 1.3
 • PIT BT-0 Q S
 • ***** END REPORT *****

• DATE 11 JUN 85 10:54:58 RID 42 04 MAR 85 LYON
• SYSTEM: STANDBY DIESEL GEN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ03
• VALVE • PEID. • ISI. • IST. • VALVE. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF. •
• NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT. • FRE. • TIME. • LEAKG. • REQUEST. • REMARKS. •
• A-V-C A-6 3 B 1 GA MO 0 UTC-Q 12
PIT 2Y NOTE 36

***** END REPORT *****

• DATE 01 MAR 85 15:05:41 RID 43 04 MAR 85 LYON
• SYSTEM: STANDBY DIESEL GEN. WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ04
• VALVE • PCTD. • IST. • VALVE. • VALVE. • ACT. • NORM. • TEST. • TST. • MAX STRK. • MAX. • RELIEF. •
• NO. • COOR. • CLASS. • CAT. • SIZE. • TYPE. • TYPE. • POS. • RQMT. • FRE. • TIME. • LEAKG. • REQUEST. • REMARKS •
HV-101 A-b 3 6 1 GA MO 0 BT-C Q 12 PIT 2Y NOTE 36
•
***** END REPORT *****

*DATE 08 JUL 85 15:56:52 RID 51 04 MAR 85 RAYMOND
 *SYSTEM: STANDBY DIESEL GEN. *CGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ05
 * VALVE * PETO . IST . VALVE . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .
 * NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . ROMT . FRE. . TIME . LEAKG. REQUEST. . REMARKS .
 ----------*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*-----*
 PV-101A F-3 3 B .4 GL SO C BT-0 Q S VR-1
 PIT 2Y
 PV-102B F-3 3 B .4 GL SO C BT-0 Q S VR-1
 PIT 2Y
 V7119 B-2 3 A,C .75 CK SA C AT-3 RR 1.33 P VR-1 13
 CVT-C RR
 V7120 D-5 3 A,C .75 CK SA C AT-3 RR 1.33 P VR-21 13
 CVT-C RR

***** END REPORT *****

RATE 21 MAR 85 15:04:59 RID 44 04 MAR 85 LYON
SYSTEM: STANDBY DIESEL GEN. CGS INSERVICE TESTING PROGRAM DWG. NO.: M-02KJ06
VALVE . PEID. . IST. . VALVE. . VALVE. . ACT. . NORM. . TEST. . TST. . MAX STRK. . MAX. . RELIEF .
NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT. . FRE. . TIME. . LEAKG. . REQUEST. . REMARKS
RV-102 A-5 3 6 1 GA MO 0 2T-C 0 1P PIT 2Y NOTE 36
***** END REPORT *****

*DATE 24 MAR 85 15:04:36 RID 52 04 MAR 85 LYC.

*SYSTEM: FLOOR AND EQUIP. DRAINS

WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02LF03

* VALVE * PEID. * IST. * VALVE. * VALVE, * ACT. * NORM. * TST. * TST. * MAX STRK. * MAX. * RELIEF. *

* NO. * COOR. * CLASS. * CAT. * SIZE. * TYPE. * TYPE. * POS. * RQMT. * FRE. * TIME. * LEAKG. * REQUEST. * REMARKS

HV-101 C-5 3 B b GA MO 0 BT-C 0 30

NOTE 36

HV-101 C-4 3 B b GA MO 0 BT-C 0 30

NOTE 36

***** END REPORT *****

DATE 19 JUL 75 07:24:32 RID 45 04 MAR 65 RAYMOND
SYSTEM: FLOOR AND EQUIP. DRAINS WCGS INSERVICE TESTING PROGRAM DWG. NO.: M-02LF09
VALVE .PLID .ISI .IST .VALVE .ACT .NORM .TEST .TST .MAX STRK .MAX .RELIEF .
NO. .COOR. .CLASS. .CAT. .SIZE. .TYPE. .TYPE. .POS. .RGHT .FRE. TIME .LEAKG. REQUEST. REMARKS
TV-15 F-2 2 A b LA MO 0 AT-1 RR 3900 C VR-5 NOTE 36 3
BT-C 0 30 VR-6 4
PIT 2Y VR-5 13
FV-46 F-2 2 A b GA MO 0 AT-1 RR 3900 C VR-1 14
BT-C 0 4 VR-2
FST 0 VR-5
PIT 2Y VR-6 14

***** END REPORT *****

DATE 19 JUL FS 07:25:26 RID 46 04 MAR 85 RAYMOND

SYSTEM: NUCLEAR SAMPLING

VALVE . PEOID . IST . IST . VALVE . ACT . NORM . TEST . TST . MAX STRK . MAX . RELIEF .

NO. . COOR. . CLASS. . CAT. . SIZE. . TYPE. . TYPE. . POS. . RQMT . FRE. . TIME . LEAKG. REQUEST. . REMARKS

HV-12	F-7	2	A	1	GL	SO	C	AT-1	RR	650 C	VR-1	13
								BT-C	Q	5	VR-2	
								FST	Q		VR-3	
								PIT	2Y		VR-4	
								AT-1	RR		VR-1	14
								BT-C	Q	5	VR-2	13
								FST	Q		VR-3	
								PIT	2Y		VR-4	
HV-14	G-4	2	B	1	GL	SO	0	PAS	NA			14
HV-15	G-4	4	B	1	GL	SO	0	PAS	NA			
HV-16	G-4	4	B	4	GL	SO	0	PAS	NA			
HV-17	G-4	4	B	4	GL	SO	0	PAS	NA			
HV-18	F-4	4	B	4	GL	SO	C	AT-1	RR	650 C	VR-1	13
								BT-C	Q	5	VR-2	
								FST	Q		VR-3	
								PIT	2Y		VR-4	
								AT-1	RR		VR-1	14
								BT-C	Q	5	VR-2	13
								FST	Q		VR-3	
								PIT	2Y		VR-4	
HV-19	E-3	2	A	1	GL	SO	C					14

***** END REPORT *****

***** END REPORT *****

NOTES

1. Operating these valves during normal operation would cause a decrease in pressure in the respective main steam header. This could introduce a severe transient in the main steam header which is unacceptable from an operational viewpoint. Valve testing will be performed during cold shutdown.
2. Closure of the main steam isolation valves during unit operation could result in reactor trip and safety injection actuation which would introduce a severe transient in the main steam lines which is unacceptable from an operational viewpoint. Testing by isolating each main steam header is also possible but would cause a power reduction which is also unacceptable from an operational viewpoint. These valves will be partially stroked every three months and full-stroke tested along with a fail safe test during cold shutdown.
3. Exercising these valves during normal operation is considered impractical. Stroking these valves would isolate feedwater to the steam generators which could result in a severe transient, possibly causing a unit trip. Valve testing will be performed during cold shutdown.
4. Exercising these valves during normal operation is considered impractical. Stroking these valves could result in a loss of steam generator level control on the corresponding steam generator, possibly causing a unit trip. Valve testing will be performed during cold shutdown.
5. During normal operation exercising these valves would be impractical. Closing these valves during operation would isolate feedwater to the steam generators which could result in a severe transient, possibly causing a unit trip. Valves FV-39, 40, 41 and 42 will be partial stroke tested during normal operation while the remaining testing on all the valves pertaining to this NOTE will be performed during cold shutdown.
6. Exercising these valves during normal operation would introduce cold auxiliary feedwater into the steam generators and therefore would cause an unnecessary thermal shock to the auxiliary feed nozzles. Valve testing will be done during cold shutdown.
"
7. Valves AL HV-5, AL HV-7, AL HV-9, and AL HV-11 are flow control valves. Therefore these valves are neither active or passive and thus testing requirements are NA.
8. These valves have an interlock which prevents their opening when reactor coolant system pressure is above 360 PSIG. Valve testing will be performed during cold shutdown.

9. This valve is passive since it is in series with a normally closed non-safety-related, air operated valve (BG HV-8145) and does not have to change positions to perform a safety-related function.
10. The power-operated relief valves have a history of failures and should not be challenged at power. Valve testing will be performed during cold shutdown.
11. Failure of these valves in the closed position during normal operation would inhibit flow to the reactor coolant pump thermal barriers. This is not desirable during pump operation. Valve testing will be performed during cold shutdown.
12. Failure of these valves in the closed position during normal operation would inhibit flow to the reactor coolant pump seals which could damage the reactor coolant pump seals. Valve testing will be performed during cold shutdown.
13. Failure of these valves in the open position during normal operation would put the reactor in a potential small break LOCA situation. Valve testing will be performed during cold shutdown.
14. Failure of these valves in the closed position during normal operation would result in a loss of seal water flow to the reactor coolant pumps and could cause pump seal damage. Valve testing will be performed during cold shutdown.
15. Failure of one of these valves in the closed position during normal operation would result in loss of pressurizer level control and may cause plant shutdown. Valve testing will be performed during cold shutdown.
16. Failure of these valves in the closed position during normal operation would inhibit letdown flow to the regenerative heat exchanger which would effect normal letdown and charging operation. Valve testing will be performed during cold shutdown.
17. Closure of one of these valves during normal operation would isolate charging flow to the reactor coolant system which could result in loss of pressurizer level control and cause plant shutdown. Valve testing will be performed during cold shutdown.
18. The normal charging pumps' suction would be isolated upon closure of one of these valves during normal operation. Alternate suction flow paths (e.g. aligned with the refueling water storage tank) would cause a sudden increase in reactor coolant system boron inventory, thereby a plant transient. Also, seal water injection to the reactor coolant pumps would be inhibited which could result in damage to the seals. Valve testing will be performed during cold shutdown.

19. Testing this valve during normal operation would introduce boric acid to the primary side causing unwanted negative reactivity addition. Valve testing will be performed during cold shutdown.
20. Exercising these valves during normal operation would result in isolating accumulator injection flowpaths and safety injection system hot leg recirculation loops 2 and 3. Valve testing will be performed during cold shutdown. 3
21. Failure of this valve in the closed position during normal operation could cause a failure of both SI pumps by isolating the miniflow recirculation path for both pumps. Valve testing will be performed during cold shutdown.
22. Failure of these valves in the open position during normal operation could result in introduction of borated water into the reactor coolant system, which could possibly cause plant shutdown. Valve testing will be performed during cold shutdown.
23. These are solenoid valves of a hermetically enclosed, seal welded design with internally mounted reed switches for position indication. Visual verification of valve position is not possible unless the valve is removed from service and disassembled. Valve position will be verified by observation of flow.
24. Testing these valves during normal operation would result in interruption of component cooling water flow for equipment necessary for normal operation. Valve testing will be performed during cold shutdown.
25. Testing the valve during normal operation would interrupt component cooling water flow to the reactor coolant pumps and possibly damage the pumps. Valve testing will be performed during cold shutdown.
26. Testing these valves would require stroking valves EJ HV-8804 A and B. Valve HV-8804 A and B have control interlocks with other ECCS valves and cannot be exercised during normal operation. Valve testing will be performed during cold shutdown.
27. These valves have control interlocks with other ECCS valves and cannot be exercised during normal operation. Valve testing will be performed during cold shutdown.
28. These valves have their power removed during normal operation so that the ECCS flowpath can be maintained operable per Technical Specifications. Valve testing will be performed during cold shutdown.

29. These valves are locked open with power removed during normal operation with RCS pressure above 1000 PSIG as required by Technical Specifications. Valve testing will be performed during cold shutdown.
30. Failure of this valve in the closed position during normal operation would inhibit a portion of the emergency core cooling system. Valve testing will be performed during cold shutdown.
31. Exercising of these valves during normal operation would result in interruption of Component Cooling Water flow to the Reactor Coolant Pump's Thermal Barrier Cooling Coil. Valve testing will be performed during cold shutdown. | 3
32. Valves EM V-014 and V-017 have no safety function.
33. Testing these valves during normal operation would require isolating the spray additive tanks which would violate Technical Specifications. Valve testing will be performed during cold shutdown.
34. Not used. | 3
35. Not used. | 3
- .
36. All motor operated valves fail-as-is and therefore do not require a fail safe test per IWW-3415.
37. Exercising these valves during normal plant operation is not possible because valves cannot be opened against reactor coolant pressure. Valve testing will be performed during cold shutdown.
38. Exercising this valve during normal operation would inhibit flow to the reactor coolant pump seals which could damage the reactor coolant pump seals. Valve testing will be performed during cold shutdown.