

MAR 1 1523

MEMORANDUM FOR: C. Thomas, Chief

Standardization and Special Projects Branch, DST

FROM:

W. Butler, Chief

Containment Systems Branch, DSI

SUBJECT:

RECOMMENDED CHANGE TO THE STANDARD TECHNICAL SPECIFICATIONS

Surveillance requirement, 4.6.1.2, Item C.1 of the Standard Technical Specifications, which is identical to Item III.A.3.b of Appendix J to 10 CFR Part 50 is not well worded since if the test is properly performed, the difference between the supplemental and the Type A tests can never be 40.25 La. Therefore, it-is recommended that Item 4.6.1.2.c.1 of the Standard Technical Specifications be changed to read either of the following two ways:

- "Confirms the accuracy of the test by verifying that the contairment leakage rate, L'v, calculated in accordance with ANSI N 45.4 -1982, Appendix C, is within 25 percent of the containment leakage rate, Lv, measured prior to the introduction of the superimposed leak"; or,
- "Confirms the accuracy of the test by verifying that the supplemental test result, Lc, minus the sum of the Type A and the superimposed leak, Lo, are equal to or less than 0.25 La".

In addition, it is recommended that Item C.3 of the same surveillance requirements be changed to read as follows: ナノイナナ

"Requires the quantity of gas injected into the contairment or bled from the containment during the supplemental test be between 0.75 La and 1.25 La".

The reason for this change is that Appendix C to ANSI N 45%.4 - 1972 requires the superimposed leakage rate to be approximately equivalent to La. The new ANSI/ANS 56.8 sets the limits between 0.75 and 1.25 La.

By copy of this memorandum, we recommend that these changes be made a part of the Standard Technical Specifications for both BWR's and PWR's.

8303090590XA

Walter R. Butler, Chief Containment Systems Branch Division of Systems Integration

cc: R. Mattson

R. Houston

R. Bottimore