

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077-0004

December 30, 1992

JOHN D. SIEBER
Vice President - Nuclear Group

04121393 5296

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPP-73
Proposed Operating License Change Request
No. 16, Revision 1
(TAC 77640)


Enclosed are the following:

1. An application for amendment to the above license to change Specification 3/4.3.4 by extending the test interval for reheat stop and intercept valves to eighteen (18) months.
2. Documents designated Attachments A, B, C, and D which set forth, respectively, the change in technical specifications, the safety analysis (including the no significant hazards evaluation), the typed replacement technical specification pages, and UFSAR changes.

This submittal replaces Revision 0 of Request Number 16 in its entirety. This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is April 30, 1993.

Sincerely,


J. D. Sieber

120087

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. De Agazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. M. L. Bowling (VEPCO)

9301130047 921230
PDR ADOCK 05000412
P PDR

ADD 1