

TEXAS UTILITIES GENERATING COMPANY

SKYWAY TOWER \* 400 NORTH OLIVE STREET, L.B. 81 \* DALLAS, TEXAS 75201

J.R. WELLS  
DIRECTOR  
QUALITY ASSURANCE

June 11, 1985  
TXX-4489

Mr. D.R. Hunter, Chief  
Reactor Project Branch 2  
U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos.: 50-445  
50-446


COMANCHE PEAK STEAM ELECTRIC STATION  
CONDUIT SUPPORT SPANS  
QA FILE: CP-85-19, SDAR-180  
FILE NO.: 10110

Dear Mr. Hunter:

On May 15, 1985 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding the use of a nonrepresentative sample in determining generic values for typical conduit span calculations.

We are continuing our evaluation and anticipate completion by August 15, 1985.

Very truly yours,



JRW:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8506240549 850611  
PDR ADOCK 05000445  
S PDR

85-465

IE-27

CP-85-19, SDAR-180, TXX-4489 was transmitted to you on June 10, 1985 with an incorrect completion due date of July 3, 1985. It should have been August 15, 1985. Please discard the incorrect copy and replace it with the attached.