

File
L-275

LOCKHEED-GEORGIA COMPANY

A DIVISION OF LOCKHEED AIRCRAFT CORPORATION

MARIETTA, GEORGIA 30060



LGD/306563

2 June 1971

United States Atomic Energy Commission
Division of Compliance, Region II
230 Peachtree Street N.W., Suite 818
Atlanta, Georgia 30303

Attention: Mr. John G. Davis, Director

Subject: Letter from Mr. John G. Davis dated 5-22-71 with Attached Form
AEC-592 Relating to an Item of Noncompliance Under AEC License
R-86.

Dear Sir:

With reference to the subject letter and attachment, the particulate air sampler filter, located at the RER demineralizer building entrance, has been sampled on a biweekly schedule since 1 February 1971. This change in schedule took place through a misinterpretation of instructions. Although only one air sampler is required for compliance with the Technical Specification for License No. R-86, a total of five continuous particulate air samples have been maintained in operation. Filter samples from four are to be taken on a biweekly basis, with the one under discussion sampled weekly. This schedule was reestablished on 19 May 1971 and will be maintained until such time that the technical specifications relieve the requirement.

Sincerely Yours,

LOCKHEED-GEORGIA COMPANY

R. B. Orsby
R. B. Orsby

Vice President - Engineering

REO:bs

8505200279 841025
PDR FOIA
BREMAN84-737 PDR