

1901 Chouteau Avenue  
Post Office Box 143  
St. Louis, Missouri 63166  
314.621-3272



January 12, 1993

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

ULNRC-2746

Gentlemen:

DOCKET NUMBER 50-483  
CALLAWAY PLANT  
AMENDMENT NUMBER 74

This is to inform the Commission of the implementation of Amendment No. 74 to the Callaway Facility Operating License No. NPF-30. Amendment No. 74 approved a Technical Specification change to the "4 kV Undervoltage-Grid Degraded Voltage" protection function described in Technical Specification Table 3.3-4, "Engineered Safety Features Actuation System Instrumentation Trip Setpoint," Functional Unit 8.b. The changes have been issued to all controlled Technical Specification holders and became effective on December 29, 1992.

Very truly yours,

A. C. Passwater  
Manager  
Licensing and Fuels

GAC/dls

190073

9301210206 930112  
PDR ADOCK 05000483  
P PDR

A001  
110

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cermak  
CFA, Inc.  
18225-A Flower Hill Way  
Gaithersburg, MD 20879-5334

L. Robert Greger  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Steedman, Missouri 65077

L. R. Wharton (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102