

June 13, 1985

Docket Nos. 50-348
and 50-364

<u>Distribution</u>	<u>Docket file</u>
NRC PDR	L PDR
ORB#1 RDG	Gray file
HThompson	OELD
EJordan	JPartlow
bGrimes	EReeves (2)
CParrish	ACRS (10)
NMerriweather	

Mr. R. P. McDonald
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. McDonald:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - ITEM 3.2.2 OF GENERIC
LETTER 83-28 JOSEPH M. FARLEY NUCLEAR PLANT UNITS 1 AND 2

We have completed a preliminary review of your letters dated September 6 and November 4, 1983, and February 6 and 15, and June 25, 1984 in response to Generic Letter (GL) 83-28 "Required Actions Based on Generic Implications of Salem ATWS Events." The review was performed to assess the completeness and adequacy of your response to GL 83-28, Items 3.1.1, 3.1.2, 3.2.1, 3.2.2, 4.1 and 4.5.1. For the Farley Units, your response to Item 3.2.2 was found to be incomplete.

Brief descriptions of the deficiencies are given as guidelines for corrective action in the enclosure. In order to maintain our present review schedule, you are requested to provide supplementary information within 30 days of receipt of this letter.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/SAVarga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
06/13/85

ORB#1:DL
EReeves/ts
06/13/85

BC-ORB#1:DL
SVarga
06/13/85

B506260066 B50613
PDR ADOCK 05000348
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 13, 1985

Docket Nos. 50-348
and 50-364

Mr. R. P. McDonald
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. McDonald:


SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - ITEM 3.2.2 OF GENERIC
LETTER 83-28 JOSEPH M. FARLEY NUCLEAR PLANT UNITS 1 AND 2

We have completed a preliminary review of your letters dated September 6 and November 4, 1983, and February 6 and 15, and June 25, 1984 in response to Generic Letter (GL) 83-28 "Required Actions Based on Generic Implications of Salem ATWS Events." The review was performed to assess the completeness and adequacy of your response to GL 83-28, Items 3.1.1, 3.1.2, 3.2.1, 3.2.2, 4.1 and 4.5.1. For the Farley Units, your response to Item 3.2.2 was found to be incomplete.

Brief descriptions of the deficiencies are given as guidelines for corrective action in the enclosure. In order to maintain our present review schedule, you are requested to provide supplementary information within 30 days of receipt of this letter.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. R. P. McDonald
Alabama Power Company

Joseph M. Farley Nuclear Plant

cc:

Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

D. Biard MacGuineas, Esquire
Volpe, Boskey and Lyons
918 16th Street, N.W.
Washington, DC 20006

Mr. Louis B. Long, General Manager
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Charles R. Lowman
Alabama Electric Corporation
Post Office Box 550
Andalusia, Alabama 36420

Chairman
Houston County Commission
Dothan, Alabama 36301

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

Robert A. Buettner, Esquire
Balch, Bingham, Baker, Hawthorne,
Williams and Ward
Post Office Box 306
Birmingham, Alabama 35201

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 24 - Route 2
Columbia, Alabama 36319

State Department of Public Health
ATTN: State Health Officer
State Office Building
Montgomery, Alabama 36104

REQUEST FOR ADDITIONAL INFORMATION

GENERIC LETTER 83-28

FARLEY UNITS 1 AND 2

Item 3.2.2 - Incomplete

The licensee has not performed a review of vendor and engineering recommendations as required by Generic Letter (GL) 83-28. This review is to ensure that appropriate vendor and engineering test guidance is included in the test and maintenance procedures or the Technical Specifications. The licensee needs to perform the above review as required by GL 83-28 and submit a statement confirming that Action Item 3.2.2 has been implemented.