

PROPOSED TECHNICAL SPECIFICATION CHANGE

SPECIAL TEST EXCEPTIONS

3/4.10.5 OXYGEN CONCENTRATION

LIMITING CONDITION FOR OPERATION

3.10.5 The provisions of Specification 3.6.6.2 may be suspended during the performance of the Startup Test Program until the reactor has operated for 120 effective full power days.

APPLICABILITY: OPERATIONAL CONDITION 1.

ACTION

With the requirements of the above specification not satisfied, be in at least STARTUP within 6 hours.

SURVEILLANCE REQUIREMENTS

4.10.5 The number of effective full power days of operation since initial criticality shall be verified to be less than or equal to 120, by calculation, at least once per 7 days during the Startup Test Program. These calculations shall be performed once Power Ascension Testing above 5% of rated THERMAL POWER occurs.

8506260541 850619
PDR ADOCK 05000322
P PDR