

### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

OFFICE OF THE SECRETARY

November 1, 1976

Director Office of the Federal Register National Archives and Records Service Washington, D. C. 20408

Dear Sir:

Enclosed for publication in the Federal Register are an original and two certified copies of a document entitled:

NORTHERM STATES POWER COMPANY

#### Docket No. 50-263

NOTICE OF ISSUANCE OF AMENDMENT TO PROVISIONAL OPERATING LICENSE

Fublication of the above document at the earliest possible date would be appreciated.

Sincerely,

Samuel J. Chilk Secretary of the Commission

Enclosures: Original and 2 certified copies

bcc: CRecords Facility Branch

Public Affairs Executive Legal Director Office of Congressional Affairs Office of the General Counsel SECY - C&R Lranch

211190293 PDR ADOCK

### UNITED STATES NUCLEAR REGULATORY COMMISSION

# DOCKET NO. 50-263

## NORTHERN STATES POWER COMPANY

## NOTICE OF ISSUANCE OF AMENDMENT TO PROVISIONAL OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 25 to Provisional Operating License No. DPR-22, issued to Northern States Power Company (the licensee), which revised Technical Specifications for operation of the Monticello Nuclear Generating Plant (the facility) located in Wright County, Minnesota. The amendment is effective as of its date of issuance.

The amendment modified the existing Monticello Technical Specifications to (1) delete the requirement that the initial inspection be performed within 6 months of issuance of Amendment No. 12 which was issued on September 15, 1975, and (2) delete the requirement to disassemble two snubbers during each refueling outage.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

9165090393

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated October 1, 1976, (?) Amendment No. 25 to License No. DPR-22, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at The Environmental Conservation Library, Minneapolis Public Library, 300 Nicollet Mall, Minneapolis, Minnesota 55401. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 27 day of October, 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Dennis L. Ziemann, Chief Operating Reactors Branch #2 Division of Operating Reactors