



File: RR 2 P-12-85-05  
E 2.40.1.1.2  
G85 402AL

June 12, 1985

Ohio Environmental Protection Agency  
Technical Records Section  
P.O. Box 1049  
Columbus, Ohio 43216

Gentlemen:

Attached is a copy of the May 1985 Ohio EPA Discharge Monitoring Report for Davis-Besse Nuclear Power Station.

An exceedence for the month of May for Total Suspended Solids (TSS) was recorded at Outfall 002 (Area Runoff). An exceedence notification regarding this situation was sent on May 5, 1985.

Also included is a corrected copy of Form EPA - 4500 for April 1985, Outfall 002 (Area Runoff). The NPDES Permit No. 2IB00011\*DD calls for the total non-filterable residue to be reported as a 30-day weighted average. This calculation would result in a concentration of 57 mg/l total non-filterable residue for this outfall, instead of the 48 mg/l which was previously reported.

Yours truly,

Stephen M. Quennoz  
Plant Manager  
Davis-Besse Nuclear Power Station  
(419) 249-5000, Ext. 223

SMQ/PJM/yml  
encl.

cc: J. E. Sullivan  
W. G. Rogers, U.S. NRC Resident Inspector  
J. L. Scott-Wasilk  
J. F. Stolz, NRC

50-346

8506260592 850612  
PDR ADOCK 05000346  
R PDR

IE25  
11