

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
McGuire

Docket Nos. 50-369 and 50-370
License Nos. NPF-9 and NPF-17

The following violation was identified during an inspection conducted on March 4 - 8, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50 Appendix B Criterion III and the licensee's accepted QA program Section 17.2.3 collectively require that measures be established to assure that applicable regulatory requirements are correctly translated into specifications, drawings, procedures and instructions. The QA Program endorses Regulatory Guide 1.64, Revision 2, and ANSI N45.2.11-1974, Quality Assurance Requirements for the Design of Nuclear Power Plants. Paragraph 3.2.20 of this standard states that the design input shall include test requirements including in-plant tests and the conditions under which they will be performed.

Contrary to the above, Duke's Design Engineering Department does not specify post-modification acceptance test requirements and test acceptance criteria for station modifications designed by the Design Engineering Department.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: April 23, 1985

8505220063 850423
PDR ADDCK 05000369 PDR
Q