

ENCLOSURE 1

NOTICE OF VIOLATION

Virginia Electric and Power Company  
North Anna Unit 2

Docket No. 50-339  
License No. NPF-7

The following violation was identified during an inspection conducted on April 1 - May 5, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification surveillance requirement 4.8.2.3.2 requires in part that each 125 volt battery be verified OPERABLE at least once per seven days by ensuring the electrolyte level of each pilot cell is between the minimum and maximum level indication marks. 2-PT-85 (D.C. Distribution System) is the procedure the licensee uses to verify the requirements of Technical Specification surveillance 4.8.2.3.2. Step 5.2 of 2-PT-85 requires that individual performing the procedure verify electrolyte of the pilot cells is between the maximum level and one inch below that level.

Contrary to the above, when 2-PT-85 was performed on April 30, 1985, the electrolyte levels were initialed as satisfactory when, in fact, electrolyte level for the pilot cell on at least one battery (2-II) was above the maximum level indication mark.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

MAY 22 1985

Date: \_\_\_\_\_

8506270648 850522  
PDR ADOCK 05000338  
Q PDR