

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-295

UNIT NAME Zion Unit 1

DATE 11/24/92

COMPLETED BY D. Kennedy

TELEPHONE (708) 746-2084 x3169

REPORT MONTH October 1992

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
	03:092	F	692.0	F	5				Limit to 96% due to Delta T fluctuation.
	*170992	F	52.59	H	4				Heat Up and Rx Critical

\*Correction made to this page.

1

F: Forced  
S: Scheduled

2

Reason:

A-Equipment Failure (Explain)

B-Maintenance of Test

C-Refueling

D-Regulatory Restriction

E-Operator Training &amp; Licensee Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3

Method

1-Manual

2-Manual Trip

3-Auto Trip

4-Continued

5-Reduced Load

4

Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets for Licensee  
Event Report (LER) File  
(NUREG-0161)

5

Exhibit I - Same Source