

Attachment 1

Proposed Change to the Fermi 2 Technical Specifications

Page attached: 3/4 3-48

8507010288 850627
PDR ADDCK 05000341
P PDR

Attachment 2

Justification for Proposed Change to
Fermi 2 Technical Specifications

Table 3.3.7.1-1

The proposed change corrects an earlier oversight. There are two monitors installed in the single makeup air intake. This change is consistent with the current action statement and eliminates the ambiguity that exists otherwise.

In addition the word "normal" clarifies that the monitor referred to is on the normal makeup intake rather than the emergency makeup air intake.

TABLE 3.3.7.1-1

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENTATION</u>	<u>Normal</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE CONDITIONS</u>	<u>ALARM/TRIP SETPOINT</u>	<u>ACTION</u>
1. Control Center Air Radiation Monitor	↓ Makeup	1/intake 2	1,2,3,5 and *	< 340 cpm (<u>≤</u> 5 mR/hr)	70
2. Area Monitors					
a. Criticality Monitors					
1) New Fuel Vault		1	#	<u>≥</u> 5 mR/hr and <u>≤</u> 20 mR/hr ^(a)	71
2) Fuel Storage Pool		1	##	<u>≥</u> 5 mR/hr and <u>≤</u> 20 mR/hr ^(a)	71
b. Control Room Direct Radiation Monitor		1	At all times	<u>≤</u> 0.5 mR/hr ^(a)	71