

TABLE 3.6-1 (continued)
CONTAINMENT ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>ISOLATION TIME</u> (seconds)
LRV-45	iso. LR test panel from RB	NA
LRV-44	"	NA
LRV-46	"	NA
LRV-87 & 88*	iso. H ₂ recombiner ports from RB	NA
LRV-89 & 90*	"	NA
LRV-91 & 92*	"	NA
LRV-93 & 94*	"	NA
3. MSV-146 #	iso. misc. waste storage tank from RCSG-1B	NA
MSV-128 #	"	NA
4. NGV-62	iso. NG system from steam generators	NA
NGV-81 #	"	NA
NGV-82	iso. NG system from pzs.	NA
5. SAV-24	iso. SA from RB	NA
SAV-23 & 122	"	NA
6. SFV-18	iso SF system	NA
SFV-19	"	NA
SFV-119 #	iso. Fuel Transfer tubes from F.T. Canal	NA
SFV-120 #	"	NA
7 WSV-1	iso. containment monitoring system from RB	NA
WSV-2	"	NA
D. PENETRATIONS REQUIRING TYPE B TESTS		
Blind Flange 119	iso. RB	NA
Blind Flange 120	"	NA
Blind Flange 202	"	NA

8507010303 850625
PDR ADDCK 05000302
P PDR