



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

ACC/ACB (RIB9)

JAN 25 1993

Docket No. 50-440
License No. NPF-58

Centerior Service Company
ATTN: Mr. Robert A. Stratman
Vice President
Nuclear - Perry
c/o The Cleveland Electric
Illuminating Company
10 Center Road
Perry, OH 44081

SUBJECT: NOTICE OF VIOLATION (NRC INSPECTION REPORT NO. 50-440/92022(DRP))

Dear Mr. Stratman:

This will acknowledge receipt of your letter dated January 8, 1993, in response to our letter dated December 10, 1992, transmitting a Notice of Violation associated with the failure to enter technical specification (TS) 3.0.3 and comply with the associated action statement when secondary containment bypass leakage TS limits were exceeded at the Perry Nuclear Power Plant. We have reviewed your corrective actions and have no further questions at this time. These corrective actions will be examined during future inspections.

Sincerely,

L. Robert Greger, Chief
Reactor Projects Branch 3

See Attached Distribution:

9301290045 930125
PDR ADDCK 05000440
G PDR

TEO
1/0

JAN 25 1993

Centerior Service Company

2

Distribution

cc:

F. R. Stead, Director, Nuclear
Support Department
D. P. Igyarto, General Manager,
Perry Nuclear Power Plants
Kevin P. Donovan, Manager
Licensing and Compliance Section
S. F. Kensicki, Director, Perry
Nuclear Engineering Dept.
H. Ray Caldwell, General
Superintendent Nuclear Operations
DCD/DCB(RIDS)
Licensing Fee & Debt Collection
Branch
Resident Inspector, RIII
Terry J. Lodge, Esq.
James R. Williams, State of Ohio
Robert E. Owen, Ohio
Department of Health
A. Grandjean, State of Ohio,
Public Utilities Commission
Clinton SRI