

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Brunswick Steam Electric Plant Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 2 5 1	PAGE (3) 1 OF 0 1
--	--	----------------------

TITLE (4) Primary Containment Group 6 Isolation, Reactor Building Ventilation Isolation, and Automatic Start of Reactor Building Standby Gas Treatment System Train 1B

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)
0 5	0 2	8 5	8 5	0 2 2	0 1	0 6	2 1	8 5				0 5 0 0 0
												0 5 0 0 0

OPERATING MODE (9) 5	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)									
POWER LEVEL (10) 0 0 0	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(a)	<input checked="" type="checkbox"/> 20.406(a)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 20.36(a)(1)	<input type="checkbox"/> 20.73(a)(2)(v)	<input type="checkbox"/> 73.71(a)						
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 20.36(a)(2)	<input type="checkbox"/> 20.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input type="checkbox"/> 20.73(a)(2)(i)	<input type="checkbox"/> 20.73(a)(2)(viii)(A)							
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 20.73(a)(2)(ii)	<input type="checkbox"/> 20.73(a)(2)(viii)(B)							
	<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 20.73(a)(2)(iii)	<input type="checkbox"/> 20.73(a)(2)(ix)							

LICENSEE CONTACT FOR THIS LER (12)

NAME M. J. Pastva, Jr., Regulatory Technician	TELEPHONE NUMBER 9 1 9 4 5 7 - 2 3 1 5
--	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPDOS	CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPDOS
X	B	H	3 0 A	1 6 0	Yes				

SUPPLEMENTAL REPORT EXPECTED (14)

<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
--	--	-------------------------------	-------	-----	------

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During a Unit 1 refuel/maintenance outage, on 5-02-85, at 1407, a primary containment Group 6 isolation occurred, the Reactor Building ventilation system automatically isolated, and train 1B of the Reactor Building Standby Gas Treatment (SBGT) System automatically started. A Reactor Building fire watch had observed smoke emanating from SBGT train 1A and reported the discovery to the Control Room. Operations personnel assessed the problem and deenergized the power supply (circuit breaker No. 25 in power supply panel 1C) to the Trouble Start Control Relay circuitry of SBGT train 1A, thereby resulting in the event. Relay CR-4, which is in the circuitry to the unit SBGT trains' high temperature Control Room annunciator, had overheated and caught fire. The fire was reported out at 1418.

SBGT train 1B was secured and returned to standby, and the isolation signals were reset. The involved smoke did not affect operability of SBGT train 1B. On 5-07-85, CR-4 (Allen-Bradley Part No. 700DC-N200Z1) to SBGT 1A was replaced. The failure of CR-4 is attributed to relay coil insulation breakdown resulting from indeterminate causes.

The CR-4 relays in SBGT 1B and Unit 2 SBGTs 2A and 2B were visually inspected for signs of overheating or physical degradation with no problems found.

8507010620 850621
PDR ADOCK 05000325
S PDR

IE27
1/



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
June 21, 1985

FILE: B09-13510C
SERIAL: BSEP/85-1178

NRC Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
REVISION 1 TO LICENSEE EVENT REPORT 1-85-022

Gentlemen:

In accordance with Title 10 to the Code of Federal Regulations, the enclosed revised Licensee Event Report is submitted. The original report fulfilled the requirement for a written report within thirty (30) days of a reportable occurrence and was submitted in accordance with the format set forth in NUREG-1022, September 1983.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/ag

Enclosure

cc: Dr. J. N. Grace

IE22
1/1